

COMMISSION ACTION MATRIX - YELLOW
2019 CALIFORNIA BUILDING CODE, TITLE 24, PART 2, 11B (2018 INTERNATIONAL BUILDING CODE)
AGENCY: DIVISION OF STATE ARCHITECT (DSAAC 01/19)

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

ACCESS CODE ADVISORY COMMITTEE

CHAPTER 2 – DEFINITIONS.
Amend Section 202.

Item Number 2.01	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-01	<i>BLENDED TRANSITION</i>	Approve as Submitted	Accept	<p>1st 45-day comments: Alejandra Warner Recommend: Approve as Amended Natasha Reyes & Dara Schur Recommend: Approve</p>	<p>Amend definition replace term "pedestrian access route" with <u>circulation path</u> and include additional amendments for clarity.</p> <p>At the July Commission meeting this item was sent back with four other items related to circulation paths and detectable warnings for further study. DSA revised two of the five items with the intent of resubmitting the entire group of items for approval at the October Commission meeting.</p>	

**CHAPTER 2 – DEFINITIONS.
Amend Section 202.**

Item Number 2.03	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-03	CIRCULATION PATH	Approve as Submitted	Accept	<p>1st 45-day comments: Stubbie Barr Recommend: Further Study, Mehdi Shadyab Recommend: Approve as Amended Natasha Reyes & Dara Schur Recommend: Approve</p> <p>3rd 45-day comments: Michael Gibbens, Kerwin Lee Recommend: Disapprove Mehdi Shadyab & Alejandra Warner Recommend: Approve as Amended Natasha Reyes, Dara Schur & CALBO Recommend: Approve</p>	<p>Amend definition to clarify that a circulation path describes all prepared surfaces for pedestrian travel, accessible and non-accessible.</p> <p>At the July Commission meeting this item was sent back with four other items related to circulation paths and detectable warnings for further study. DSA revised two of the five items with the intent of resubmitting the entire group of items for approval at the October Commission meeting.</p>	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.
Amend Section 11B Circulation paths.

Item Number 11B.19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-19	11B-250.1	Disapprove	Disagree	<p>1st 45-Day Comments: Mehdi Shadyab, Cory Cabral, Stubbie Barr, Recommend: Further Study Eugene Lozano Jr, Janis Kent + 17 additional Identical comments Recommend: Approve as Amended</p> <p>15-Day Comments: Liliana Vasquez Recommend: Approve Bill Zelmer: Recommend: Approve as Amended Michael Healy Recommend: Further Study</p> <p>3rd 45-day comments: Michael Gibbens, Kerwin Lee Recommend: Disapprove John Caparelli, CALBO & Mark Wood Recommend: Approve Eugene Lozano Jr, Michael Ellars, Dara Schur, Natasha Reyes, Alejandra Warner & Mehdi Shadyab Recommend: Approve as Amended</p>	<p>Amend section to require circulation paths be physically separated from vehicular traffic in all locations, with several exceptions provided. Public comments received during the 1st 45 Day public comment period, DSA addressed language in ISOR for an additional 15-day Public Comment Period.</p> <p>At the July Commission meeting this item was sent back with four other items related to circulation paths and detectable warnings for further study. DSA revised two of the five items with the intent of resubmitting the entire group of items for approval at the October Commission meeting.</p>	