

Thanks, Kevin! Appreciate the info.

Please see below for one comment. If you want to have a call to go over the comment, I'd be happy to schedule a quick call.

Cheers,  
John

**In regard to the PDFs titled, "Express Terms 7.18.16" and "BSC AB 2282 Draft ET-PT5":**

- This document considers "recycled water" to be "on-site treated non-potable water". This is not a change from the previous plumbing code. However, the term "recycled water" refers to municipally supplied water that meets applicable water quality requirements of the California Code of Regulations for disinfected tertiary recycled water and the applicable recycled water use. Inherently, "recycled water" is not "on-site treated nonpotable water". Unlike graywater and rainwater that is "on-site". Therefore, "recycled water" should be removed, and "blackwater" should be added to the definition instead.
  - ***On-Site Treated Nonpotable Water [BSC]. [Also adopted by HCD]*** *Nonpotable water that has been collected, treated, and intended to be used on-site and is suitable for direct beneficial use. Sources for on-site treated nonpotable water include, but are not limited to, gray water; rainwater; stormwater; ~~reclaimed (recycled) recycled water~~ **blackwater**; cooling tower blow-down water; and foundation drainage.*

John Scarpulla  
SFPUC – Policy & Government Affairs  
[jscarpulla@sfgov.org](mailto:jscarpulla@sfgov.org) | 415-934-5782