

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Janis Kent
Date: Thursday, April 23, 2020 7:26:59 PM

Commenter Contact Information

Name: Janis Kent
Date:
Representing: Stepping Thru Accessibility
Mailing Address
Number and Street: 3553 Atlantic Ave #575
City: Long Beach
State: CA
Zip Code: 90807
Telephone #: 5624269363
Email: janisk@steppingthruaccessibility.com

Proposed Building Standard

Title 24 Part #: Part 11
Section #: 11B-604.8.1.2
Proposing State Agency: DSA
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Disapprove

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

This proposed language does not comply with ADA which specifically states compartment openings are located 4" from the adjacent partition/wall. The size of the compartment is irrelevant. It is my belief that we should not have any regulations that are not in compliance with the ADA Standards - there is no reason to change what we currently have which complies.

This existing section should remain with none of the proposed changes

9 Point Criteria Info:
18930(a) 3