

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Mehdi Shadyab
Date: Monday, April 27, 2020 8:38:02 AM

Commenter Contact Information

Name: Mehdi Shadyab
Date: 4/27/2020 12:00:00 AM
Representing: City of San Diego
Mailing Address
Number and Street: 1222 First Avenue
City: San Diego
State: California
Zip Code: 92101
Telephone #: 6194465067
Email: mshadyab@sandiego.gov

Proposed Building Standard

Title 24 Part #: Part 2
Section #: Chapter 11B, Section 202, CIRCULATION PATH
Proposing State Agency: Division of State Architect
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

In this definition Circulation Path should also include 'Corridors'. Corridors are also considered as circulation paths. Corridor is a defined term in California Building Code. It is defined as " An enclosed exit access component that defines and provides a path of egress travel. This section as amended should read: CIRCULATION PATH. [DSA-AC] An accessible or non-accessible prepared exterior or interior way of passage provided for pedestrian travel, including but not limited to, walks, sidewalks, corridors, hallways, courtyards, elevators, platform lifts, ramps, stairways and landings.

9 Point Criteria Info:
18930(a) 1