

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - John Chrysler
Date: Tuesday, May 12, 2020 3:47:56 PM

Commenter Contact Information

Name: John Chrysler
Date: 5/12/2020 12:00:00 AM
Representing: Masonry Institute of America
Mailing Address
Number and Street: 1315 Storm Parkway
City: Torrance
State: CA
Zip Code: 90501
Telephone #: 3102579000
Email: jc@masonryinstitute.org

Proposed Building Standard

Title 24 Part #: Part 2
Section #: Chapter 21, Section 2103.5
Proposing State Agency: OSHPD
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Further Study Required

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The previous Public Comment, as contained in the ISOR, objected to the fact that the provision is not enforceable since compliance for air entrainment is not defined in the code. The proposed Express Terms did not address the previous Public Comment. This provision needs to be sent for further review and the ultimate solution would be to delete from the Code since, in addition to the unenforceable provisions, it is duplicative with the requirements of TMS 602.

9 Point Criteria Info:
18930(a) 4