

COMMISSION ACTION MATRIX
2019 CALIFORNIA BUILDING CODE, TITLE 24, PART 2 (2019 Intervening Code Cycle)
AGENCY: HOUSING AND COMMUNITY DEVELOPMENT [HCD 1AC 02/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

ACCESS CODE ADVISORY COMMITTEE

CHAPTER 2 – DEFINITIONS SECTION 202

Amend Section 202 listed below

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
HCD 1AC 02/19-1-1	PUBLIC HOUSING	Further Study	Accept		Amend definition to co-adopt with DSA. CAC recommended work with DSA. Agency reviewed with DSA, post CAC.	

CHAPTER 11A – HOUSING ACCESSIBILITY

Amend Section 1112A CURB RAMPS ON ACCESSIBLE ROUTES

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
HCD 1AC 02/19-2-1	1112A.4	Approve as Submitted	Accept		Amend section to provide a correct reference to the figures change 11A-3M to <u>11A-3L</u>	
HCD 1AC 02/19-2-2	1112A.5	Approve as Submitted	Accept		Amend section to provide a correct reference to the figures change 11A-3M to <u>11A-3L</u>	

CHAPTER 11A – HOUSING ACCESSIBILITYAmend Section 1132A *DOORS*

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
HCD 1AC 02/19-3-1	1132A.7	Approve as Submitted	Accept		Amend section – model code renumbered sections in the code.	

CHAPTER 11A – HOUSING ACCESSIBILITYAmend Section 1133A *KITCHENS*

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
HCD 1AC 02/19-4-1	1133A.2	Approve as Submitted	Accept		Amend section to add correct term. Replace work space with work surface.	

CHAPTER 11A – HOUSING ACCESSIBILITYAmend Section 1134A *BATHING AND TOILET FACILITIES*

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
HCD 1AC 02/19-5-1	1134A.6	Approve as Submitted	Accept		Amend section to add design option of transfer type shower stall.	

CHAPTER 11A – HOUSING ACCESSIBILITY

Amend Section 1136A ELECTRICAL RECEPTACLE, SWITCH AND CONTROL HEIGHTS

Item Number 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
HCD 1 AC 02/19-6-1	1136A.1	Approve as Submitted	Accept		Amend section to reflect maximum 25 ½ inch reach depth for to receptacles heights and to accommodate countertop overhang. Adds language to reflect the scope of the section.	
HCD 1AC 02/19-6-2	1136A.2	Approve as Submitted	Accept		Amend section to reflect maximum 25 ½ inch reach depth for to receptacles heights and to accommodate countertop overhang. Adds language to reflect the scope of the section.	