

COMMISSION ACTION MATRIX – APPROVED BY THE CALIFORNIA BUILDING STANDARDS COMMISSION AUGUST 13, 2020
2019 CALIFORNIA RESIDENTIAL CODE, TITLE 24, PART 2.5
AGENCY: THE OFFICE OF STATE FIRE MARSHAL [SFM 02/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

BUILDING FIRE AND OTHER + STRUCTURAL DESIGN/LATERAL FORCES AD HOC CODE ADVISORY COMMITTEE

CHAPTER 2 DEFINITIONS – SECTION R202 DEFINITIONS

Adopt additional, and repeal definitions listed below

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 02/19-1-1	[RB] BATTERY SYSTEM, STATIONARY STORAGE	Approve as Submitted	Accept		Delete model code definition for Battery System, Stationary Storage.	Approved
SFM 02/19-1-2	<u>[RB] ENERGY STORAGE SYSTEM (ESS)</u>	Approve as Submitted	Accept		Add new definition for <i>Energy Storage Systems</i> .	Approved

CHAPTER 3 BUILDING PLANNING

Amend and repeal sections listed below

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 02/19-2-1	SECTION R327 STATIONARY ENERGY STORAGE BATTERY SYSTEMS	Approve as Submitted	Accept		Delete Stationary and Battery, and add <i>Energy</i> to the title of the section	Approved
SFM 02/19-2-2	R327.1 General	Approve as Submitted	Accept	45-day, J. Cain, SEIA; Approve as Amended, crit, #8	Commenter recommends that the language is made consistent with the model code	Approved

					language. Refer to SFM response in FSOR rationale.	
SFM 02/19-2-3	R327.2 Equipment listings	Approve as Submitted	Accept		Amend section and delete exception 2 and 3	Approved
SFM 02/19-2-4	R327.3 Installation	Approve as Submitted	Accept		Amend section	Approved
SFM 02/19-2-5	<u>R327.3.1 Spacing</u>	Approve as Submitted	Accept		Add new section	Approved
SFM 02/19-2-6	<u>R327.4 Locations</u>	Approve as Submitted	Accept	45-day, Nick Duvally, Fire Marshal, County of LA: Approve as Amended 15-day: N. Duvally, J. Castello, L.A. County Fire, Approve as Amended.	45- day Commenter recommends alignment with the IFC regarding residential dwelling units. Refer to SFM response in FSOR rationale. Please review full comment. 15-day comments advise further amendment.	Approved
SFM 02/19-2-7	<u>R327.5 Energy ratings</u>	Approve as Submitted	Accept		Add new section	Approved
SFM 02/19-2-8	<u>R327.4</u> <u>R327.6</u>	Approve as Submitted	Accept		Amend section number and section	Approved
SFM 02/19-2-9	<u>R327.7 Fire detection</u>	Approve as Submitted	Accept	45-day, M. Rodriguez – Sunrun, CALSSA; Approve as Amended, crit. #1	Commenter suggests incorporation of exceptions found in CBC Section 314.4 into R327.7. SFM Response in FSOR.	Approved
SFM 02/19-2-10	<u>R327.6</u> <u>R327.8</u>	Approve as Submitted	Accept		Amend section number and section.	Approved
SFM 02/19-2-11	<u>R327.5</u> <u>R327.9</u>	Approve as Submitted	Accept		Amend section number and section	Approved
SFM 02/19-2-12.1	<u>R327.10 Toxic and highly toxic gas</u>	Not reviewed by CAC	New definition. by SFM - See Annotation		SFM proposes new definition going forward as a result of CAC discussion regarding new definition for Electric vehicle use.	Approved
SFM 02/19-2-12.2	<u>R327.11 Electric vehicle use</u>	Approve as Submitted	Accept		Added new definition. During CAC discussion, a public comment identified the need for the addition of another definition post CAC. See 2-12.1 above.	Approved
SFM 02/19-2-13	<u>R337.1.1</u>	Approve as Submitted	Accept		Amend section	Approved
SFM 02/19-2-14	<u>R337.5.1</u>	Approve as Submitted	Accept		Amend section	Approved
SFM 02/19-2-15	<u>R337.5.2</u>	Approve as Submitted	Accept		Amend section	Approved
SFM 02/19-2-16	<u>R337.6.2</u>	Approve as Submitted	Accept		Amend section	Approved

SFM 02/19-2-17	<u>R337.6.2.1</u>	Approve as Submitted	Accept		Add new section	Approved
SFM 02/19-2-18	<u>R337.6.3</u>	Approve as Submitted	Accept		Amend section	Approved
SFM 02/19-2-19	<u>R337.9.1.1</u> <u>Flashing</u>	Approve as Submitted	Accept		Add new section	Approved
SFM 02/19-2-20	<u>R337.9.3</u>	Approve as Submitted	Accept		Amend section	Approved

CHAPTER 44 REFERENCED STANDARDS

Amend and repeal sections listed below

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 02/19-3-1	<u>NFPA 68-13</u> <u>Standard on</u> <u>Explosion . . .</u>	Approve as Submitted	Accept		Adopt new NFPA 69-13 standard	Approved
SFM 02/19-3-2	<u>UL 1974-17</u> <u>Evaluation of Re-</u> <u>purposing Batteries</u>	Approve as Submitted	Accept		Adopt new UL 1974-17 standard	Approved
SFM 02/19-3-3	<u>9540—44 16</u> <u>UL 9540A-17</u>	Approve as Submitted	Accept	45-day, John Taecker – Underwriters Laboratory (UL) Approve as Amended	Commenter identifies correction to the listing needed. Related to part 9 as well. SFM accepted the comment and modified the referenced standard accordingly.	Approved