

**COMMISSION ACTION MATRIX - GREEN**  
**2019 CALIFORNIA GREEN BUILDING CODE, TITLE 24, PART 11**  
**AGENCY: THE DIVISION OF THE STATE ARCHITECT [DSASS-CC 04/19]**

**LEGEND:**

**CAC Actions:** Approve as Amended, Approve as Submitted, Disapprove, Further Study

**Agency Responses:** Accept, Disagree, Withdraw

**CBSC Actions:** Approve as Amended, Approve as Submitted, Disapprove, Further Study

**Matrix Paper Color (for commission action only):** GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

**GREEN-PEME AD HOC CODE ADVISORY COMMITTEE**

**ELECTRIC VEHICLE INFRASTRUCTURE**

**SECTION 5.106.5.3 – Electric vehicle (EV) charging.**

Amend sections listed below

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSASS-CC 04/19-1-1	<b>TABLE 5.106.5.3.3 EV charging space calculation</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend table to increase the percentage of spaces required for electrical vehicle (EV) charging infrastructure. Associated with voluntary measures Item 10 below.	
DSASS-CC 04/19-1-2	<b>5.106.5.3.5 [N] Future charging spaces</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to add "Note" clarifying that future EV charging spaces shall count toward the total required parking spaces. This note does not apply to K-12 schools and community colleges.	

**LIGHT POLLUTION REDUCTION**  
**SECTION 5.106.8 Light pollution reduction.**  
Amend sections listed below

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSASS-CC 04/19-2-1	<b>5.106.8 Light pollution reduction., Exceptions: <del>[N]</del>, #1, #5</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to strike the <del>[N]</del> banner from Exceptions. Amending Exception 1 and adding new Exception 5 are to align with CALGreen BUG requirements adopted into the California Energy Code, Section 130.2(b).	
DSASS-CC 04/19-2-2	<b>5.106.8.1 Facing – Backlight. &amp; Exception: Corners</b>	<b>Approve as Submitted</b>	<b>Accept</b>		New code section proposing to relocate and amend table footnotes from Table 5.108.6 <del>[N]</del> . Section was added to properly align requirements for stringency of facing-backlight in relation to property lines. Add Exception for corners.	
DSASS-CC 04/19-2-3	<b>5.106.8.2 Facing – Glare., Notes: #1 <del>[N]</del></b>	<b>Approve as Submitted</b>	<b>Accept</b>		New code section proposing to relocate and amend table footnotes from Table 5.108.6 <del>[N]</del> . Section was added to properly align requirements for stringency of facing-glare in relation to property lines. Repeal the <del>[N]</del> banner in Notes.	
DSASS-CC 04/19-2-4	<b>TABLE 5.106.8 <del>[N]</del> Maximum Allowable Backlight . . .</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Repeal footnotes from this table and relocate them into two new code Section 5.106.8.1 with an exception for “corners,” and new Section 5.106.8.2. Table superscript numbers are re-adjusted to align with the with revised footnote numbers.	

**PRE-RINSE SPRAY VALVES**  
**SECTION 5.303 – INDOOR WATER USE**

Amend sections listed below

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSASS-CC 04/19-3-1	<u>5.303.3.4.6</u> <u>Pre-rinse</u> <u>spray valve.,</u>	Approve as Submitted	Accept		New code section to align with Appliance Efficiency regulations adopted for pre-rinse spray valves by the CEC in Title 20 for automatic shutoff requirements of the California Code of Regulations.	
DSASS-CC 04/19-3-2	<u>FOR</u> <u>REFERENCE</u> <u>ONLY : . .</u> <u>Table H-2 . . .</u> <u>&amp; Title 20</u> <u>Section</u> <u>1605.3(h)(4)</u> <u>(A)</u>	Approve as Submitted	Accept		Re-print Title 20 Table H2, and Title 20 Section 1605.3(h)(4)(A) for pre-rinse spay valves, for reference and labeling requirements on spray valves.	

**POLLUTANT CONTROL**  
**SECTION 5.504 – POLLUTANT CONTROL**

Amend sections listed below

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSASS-CC 04/19-4-1	<u>5.504.4.4</u> <u>Carpet</u> <u>systems</u>	Approve as Submitted	Accept		Amended section to repeal items 1 through 5 and add new CDPH referenced standard for VOC limits for carpet systems with new website link. <b>CAC:</b> recommended to review this amendment with other state agencies and interested parties	

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSASS-CC 04/19-4-2	5.504.4.4.1 Carpet cushion	Approve as Submitted	Accept		Amended section to repeal “Carpet and Rug Institute’s Green Label program” and new CDPH referenced standard added for VOC limits for carpet cushion with new website link. <b>CAC:</b> recommended to review this amendment with other state agencies and interested parties	