

COMMISSION ACTION MATRIX - YELLOW
2019 CALIFORNIA MECHANICAL CODE, TITLE 24, PART 4
AGENCY: THE OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT [OSHDP 05/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

GREEN-PEME AD HOC CODE ADVISORY COMMITTEE

CHAPTER 4 – VENTILATION AIR

Amend sections listed below

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHDP 05/19-4-12	TABLE 4-A	Approve as Submitted	Accept	Various stakeholders recommend Disapprove	Amend table to repeal the 100%-outdoor air column. See ET and ISOR. 45-day comments: See FSOR for agency responses.	
OSHDP 05/19-4-13	Notes for Table 4-A; a. & b., f & ab.	Approve as Submitted	Accept	Various stakeholders recommend Disapprove	Amend Table 4-A footnotes. 45-day comments: See FSOR for agency responses.	