

COMMISSION ACTION MATRIX -- APPROVED BY THE CALIFORNIA BUILDING STANDARDS COMMISSION JULY 13, 2020
 2019 CALIFORNIA BUILDING CODE, TITLE 24, PART 2, VOL. 1
 AGENCY: THE OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT [OSHPD 02/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

HEALTH FACILITIES (HF) CODE ADVISORY COMMITTEE

February 25, 2020.

CHAPTER 1 – SCOPE AND ADMINISTRATION

DIVISION I – CALIFORNIA ADMINISTRATION

Amend sections listed below

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-1-1	1.10.1 OSHPD 1 and OSHPD 1R. Application – [OSHPD 1]	Approve as Submitted	Accept		Amendment to clarify the application of [OSHPD 1R] to include " <u>SPC or freestanding</u> " nonconforming hospital buildings that have been removed from acute-care service. Associated with same section in Part 10 as well.	Approved

CHAPTER 1 – SCOPE AND ADMINISTRATION

DIVISION I – CALIFORNIA ADMINISTRATION

Amend sections listed below

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-2-1	1.10.4 OSHPD 4. Enforcing agency --	Approve as Submitted	Accept		Amending this section to reflect the enforcing agency for Correctional Treatment Centers as the <u>California Department of Corrections and Rehabilitation</u> for state prison facilities. Associated with same section in Part 10 as well. After additional study with SFM, OSHPD has Withdrawn this item.	N/A

CHAPTER 1 – SCOPE AND ADMINISTRATION
DIVISION II – CALIFORNIA ADMINISTRATION
SECTION 104 DUTIES AND POWERS OF BUILDING OFFICIAL

Amend sections listed below

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-3-1	104.11.4 Earthquake monitoring instruments, OSHPD 1 and OSHPD 4.	Approve as Submitted	Accept		Amending this section to eliminate duplicative language in the building code. Similar provisions are found in Appendix L of the building code which is also adopted by OSHPD.	Approved

CHAPTER 2 – DEFINITIONS
SECTION 202 – DEFINITIONS

Amend sections and add new definitions listed below

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-4-1	[A] CHANGE OF OCCUPANCY, 3.	Approve as Submitted	Accept		<i>[Not adopted by OSHPD]</i> Amending this definition to clarify OSHPD does not adopt Item 3 under this definition. Withdrawn Post CAC, after comments in allied Part 10 CAC.	N/A
OSHPD 02/19-4-2	<u>CHANGE OF USE.</u>	Further Study	Accept		Added definition. Criteria 8, 7A. Post CAC – definition revised. Definition Withdrawn, 3/25/2020, after comments in allied Part 10 CAC.	N/A
OSHPD 02/19-4-3	EQUIPMENT. [DSA-SS, DSA-SS/CC, OSHPD 1, 1R, 2, 4 & 5]	Approve as Submitted	Accept		OSHPD banner removed to separate these definitions from OSHPD application of specific equipment definitions.	Approved
OSHPD 02/19-4-4	<u>EQUIPMENT.</u> <u>[OSHPD 1, 1R, 2, 4 & 5].</u>	Approve as Amended	Accept		Adding these 8 specific definitions (4-4.1 through 4-4.8 below) regarding anchorage of equipment. Editorial addendum to correctly underline proposed definition, Criteria #8. Post CAC – 1R removed from banner per CAC comment, Criteria #1.	Approved

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-4-4.1	<u>(1) COUNTERTOP EQUIPMENT</u>	Approve as Amended	Accept		Specific definition for countertop/tabletop equipment. Post CAC, no change to text.	Approved
OSHPD 02/19-4-4.2	<u>(2) ESSENTIAL EQUIPMENT</u>	Approve as Amended	Accept		Essential equipment for the 8 basic services of a hospital. Addendum to add a reference pointer to CBC Section 1224.3. Criteria #8.	Approved
OSHPD 02/19-4-4.3	<u>(3) FIXED EQUIPMENT</u>	Approve as Amended	Accept		Specific definition for fixed equipment in a hospital. Addendum to correct grammar, Criteria #8.	Approved
OSHPD 02/19-4-4.4	<u>(4) INTERIM EQUIPMENT</u>	Approve as Amended	Accept		Equipment for temporary use for the duration of construction projects. Post CAC, no change to text.	Approved
OSHPD 02/19-4-4.5	<u>(5) MOBILE EQUIPMENT</u>	Approve as Amended	Accept		Equipment that is typically used in one area and stored in another. Criteria #2. Post CAC, no change to text.	Approved
OSHPD 02/19-4-4.6	<u>(6) MOVABLE EQUIPMENT</u>	Approve as Amended	Accept		Equipment that can be moved for servicing and maintenance. Addendum to correct grammar, Criteria #4.	Approved
OSHPD 02/19-4-4.7	<u>(7) OTHER EQUIPMENT</u>	Approve as Amended	Accept		Same as (6) above, except the equipment is not directly connected to building service distribution system. Post CAC – No change to text.	Approved
OSHPD 02/19-4-4.8	<u>(8) TEMPORARY EQUIPMENT</u>	Approve as Amended	Accept		Equipment used during time of service related activity as defined in Section 108. Addendum to edit format of sentence, Criteria #8	Approved
OSHPD 02/19-4-5	<u>HANDWASHING FIXTURE. [OSHPD 1, 2, 3, 4, and 5]</u>	Approve as Amended	Accept		New definition for consistency with OSHPD specific use. Amended for removal of word “accessible,” per CAC based on Criteria #2.	Approved
OSHPD 02/19-4-6	<u>IMAGING EQUIPMENT. [OSHPD 1 & 4]</u>	Further Study	Accept		New definition added to clarify specific application of equipment seismically certified associated with Section 1705A.13.3.1. OSHPD to consider moving definition to Chapter 17A, Criteria #4. Item Withdrawn-post CAC.	N/A

CHAPTER 12 – INTERIOR ENVIRONMENT
SECTION 1207 – INTERIOR SPACE DIMENSIONS
SECTION 1209 – TOILET AND BATHROOM REQUIREMENTS

Amend sections listed below: OSHPD 1R banner removed. See below.

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-5-1	1207.2 Minimum ceiling heights. Exception 5 <i>[OSHPD 1, 1R, 2, 3 & 5]</i>	Approve as Submitted	Accept		OSHPD 1R banner removed. Specified services need not comply with 1224.4.10 regarding ceiling heights.	Approved
OSHPD 02/19-5-2	1209.2 Finish Materials. <i>[OSHPD 1, 1R, 2, 3 & 5]</i>	Approve as Submitted	Accept		OSHPD 1R banner removed. Specified services need not comply with 1224.4.11 regarding finish materials.	Approved

SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS

Amend sections listed below: Clarification is added for types of health care services designated throughout Section 1224.

Item Number 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-6-1	SECTION 1224 <i>[OSHPD 1 & OSHPD 1R] HOSPITALS.</i>	Approve as Submitted	Accept		Strike OSHPD 1R from the banner on the section title. The previous application of OSHPD 1R to “hospitals” was misleading and is being corrected. Also associated with Items-7 through 19 below. CAC approved as submitted with Item 8 below.	Approved

SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS

1224.3 Definitions.

Amend sections listed below: Clarification is added to the existing definitions.

Item Number 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-7-1	CHANGE IN FUNCTION.	Approve as Submitted	Accept		The word "space" has been removed from the reference to "Function Requirements" to avoid continuing confusion among code users.	Approved
OSHPD 02/19-7-2	HANDWASHING STATION.	Further Study	Accept		Amended language to specify clearances needed around the fixtures. CAC recommends closer look at locations where clearances may conflict with accessibility. Criteria #2, #8. Post CAC, language removed regarding door swings and clear space.	Approved
OSHPD 02/19-7-3	PATIENT CARE LOCATIONS.	Further Study	Accept		Definition amended to clarify the various types of patient care locations. CAC recommends wording be revisited -- maybe vague. Criteria #6. Post CAC -- first sentence removed from the proposed amendment regarding functional space requirements.	Approved
OSHPD 02/19-7-4	PATIENT CARE LOCATIONS. BAY (patient)	Further Study	Accept		Definition amended to clarify the clearances for circulation. Criteria #6. Post CAC – no change to the wording.	Approved
OSHPD 02/19-7-5	PATIENT CARE LOCATIONS. PATIENT ROOM.	Further Study	Accept		Definition amended to reference related terminology in the code. Criteria #6. Post CAC – no change to the wording.	Approved

SECTION 1224 [OSHPD 1 & OSHPD 1R] HOSPITALS

1224.4 GENERAL CONSTRUCTION

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 8	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-8-1	TABLE 1224.4.6.5 [OSHPD 1, 1R, 2, 3, 4 & 5] LOCATION OF NURSE CALL DEVICES	Approve as Submitted	Accept		OSHPD 1R banner removed from the table for clarity and consistency in the code relative to actual health facility types and their related services and to remove the building designation as non-relevant. Associated with Item 6 above, Section 1224. CAC approved as submitted with Item 6 above.	Approved

SECTION 1224 [OSHPD 1 & OSHPD 1R] HOSPITALS

1224.4 GENERAL CONSTRUCTION

Amend sections listed below: Clarifications, general editorial changes, updated references.

Item Number 9	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-9-1	1224.4.7.3 Outpatient services.	Approve as Submitted	Accept	45-day: J. Woestman, BHMA comment recommended more detail in Chapter 10 reference. 15-day: NONE.	Phrase added to amendment regarding width requirements for corridors. Post CAC, OSHPD agreed with 45-day BHMA comment. Text was modified as recommended for the wording in the proposed phrase to "shall," and to include specific reference to Chapter 1020.2, also as recommended. OSHPD submitted item for 15-day Public comment period. No comments received during 15-day comment period.	Approved
OSHPD 02/19-9-2	1224.4.8 Doors and door openings.	Approve as Submitted	Accept	J. Woestman, BHMA comment disagrees with proposed revision to text. Recommended to have OSHPD withdraw the amendment.	Section amended to consolidate various regulations to a single location to facilitate code use. During 45-day comment period, OSHPD considered comment and Withdrew this amendment.	N/A
OSHPD 02/19-9-3	1224.4.10.1, Minimum height. Exception:	Approve as Submitted	Accept		This section is amended to add clarification relative to soffits over fixed cabinets and over work surfaces.	Approved

Item Number 9	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-9-4	1224.4.18 Grab bars.	Approve as Submitted	Accept		This section is amended to add clarification relative to the specific sections in Chapter 11B to be used for grab bars intended for non-accessible patient toilet rooms.	Approved

**SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS
1224.14 NURSING SERVICE SPACE**

Amend sections listed below: Clarifications, general editorial changes, updated references.

Item Number 10	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-10-1	1224.14.4.3 Anteroom. Exception:	---	Withdrawn		Editorial amendment to this section with the intent to simplify the code section by incorporating the former exception regarding the protective environment of the space into the language of the section itself. Withdrawn during meeting.	N/A

**SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS
1224.18 RADIOLOGICAL/DIAGNOSTIC IMAGING SERVICE
1224.18.3 Computerized tomography (CT) scanning.**

Amend sections listed below: Clarifications, general editorial changes, updated references.

Item Number 11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-11-1	1224.18.3.1 Space required, 1 & 2	Approve as Submitted	Accept		Amendment to this section updates and refines the terminology to reflect the provision for an alcove and the current technological advances in CT imaging modality.	Approved

SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS

1224.23 STORAGE SPACE

Amend sections listed below: Clarifications, general editorial changes, updated references.

Item Number 12	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-12-1	1224.23.1 General storage.	Approve as Submitted	Accept		Amendment to this section is provided for clarification of the location of the minimum amount of general storage in conforming and non-conforming hospital buildings according to SB1953.	Approved

SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS

1224.29. INTENSIVE CARE UNITS.

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 13	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-13-1	1224.29.2 Newborn intensive care units (NICU).	Approve as Submitted	Accept		This section is amended to address shared use of treatment space where multi-patient rooms are provided.	Approved
OSHPD 02/19-13-2	1224.29.2.6 Area.	Approve as Submitted	Accept		This section is amended to provide square footage area requirement where multi-patient rooms are used.	Approved
OSHPD 02/19-13-3	1224.29.2.10 Infant formula facilities.	Approve as Submitted	Accept		Language has been added to this section to clarify that this section is provided in NICUs in lieu of the nourishment area required for ICUs under Section 1224.29.1.14.4.	Approved

SECTION 1224 [OSHPD 1 & OSHPD 1R] HOSPITALS
1224.32 OBSTETRICAL FACILITIES (PERINATAL UNIT SPACE)

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 14	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-14-1	1224.32.3.7 Recovery room(s)	Approve as Submitted	Accept		Language has been amended to correct the current reference to “beds” to read “patient care stations” instead.	Approved

SECTION 1224 [OSHPD 1 & OSHPD 1R] HOSPITALS
1224.33 EMERGENCY SERVICE

Amend sections listed below and add a new section: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 15	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-15-1	1224.33.2.2 Treatment room.	Approve as Submitted	Accept		Minor modifications have been made to correct the reference to “cubicles” to read “bays.”	Approved
OSHPD 02/19-15-2	1224.33.3.7 Trauma/cardiac rooms.	Approve as Submitted	Accept		Language in this section has been amended to address the placement of handwashing fixtures within the procedure room.	Approved
OSHPD 02/19-15-3	1224.33.3.13 Administrative center . . .	Approve as Submitted	Accept		The requirement for medication storage in this section is amended to be removed and replaced with a new Section 1224.33.3.14.	Approved
OSHPD 02/19-15-4	1224.33.3.14 Medication preparation room.	Approve as Submitted	Accept		New section added with reference back to current Section 1224.4.4.4.1, under General Construction requirements.	Approved
OSHPD 02/19-15-5	1224.33.3.14 - 17 (Renumber list); 15 through 18.	Approve as Submitted	Accept		Editorial: Renumber list 14. through 17., to 15. through 18. CAC recommends follow through on cross-references.	Approved

SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS

1224.34 NUCLEAR MEDICINE

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-16-1	1224.34.1.1 Radiation protection.	Approve as Submitted	Accept		New amendment to address dosing areas and circulation paths of dosed patients, including multi-bay scanner rooms.	Approved
OSHPD 02/19-16-2	1224.34.1.2.3 Single-Photon Emission Computed Tomography (SPECT) facilities	Approve as Submitted	Accept		New amendment to address multi-bay scanner rooms.	Approved
OSHPD 02/19-16-3	1224.34.2 Support areas for nuclear medicine services.	Approve as Submitted	Accept		New amendment to clarify the sharing of nuclear medicine services and the imaging department.	Approved

SECTION 1224 [OSHPD 1 & ~~OSHPD 1R~~] HOSPITALS

1224.35 REHABILITATION THERAPY DEPARTMENT.

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 17	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-17-1	1224.35 REHABILITATION THERAPY DEPARTMENT.	Approve as Amended	Accept		New amendment regarding in-patient units, and out-patient units. Associated subsection 1224.35.1. CAC recommends removing first sentence of amendment. Criteria #4	Approved
OSHPD 02/19-17-2	1224.35.1 Rehabilitation center space. #6 & 7.	Approve as Amended	Accept		New amendment to this section to clarify requirements regarding out-patient rehabilitation service. No additional CAC action taken on this section.	Approved

SECTION 1224 [OSHPD 1 & OSHPD-1R] HOSPITALS
1224.36 RENAL DIALYSIS SERVICE (ACUTE AND CHRONIC)

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 18	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-18-1	1224.36.2.7 Medication station dispensing.	Approve as Submitted	Accept		Amendment regarding the provision of medication stations in other locations.	Approved

SECTION 1224 [OSHPD 1 & OSHPD-1R] HOSPITALS
1224.39 OUTPATIENT SERVICE SPACE

Amend sections listed below: Clarifications, general editorial changes, updated references and associated changes regarding OSHPD 1R and Section 1224 in Item 6 above.

Item Number 19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-19-1	1224.39.3.2.2, #4. Eyewash station.	Approve as Submitted	Accept		New Item 4 amendment added regarding eyewash stations in the Outpatient Service Space.	Approved

SECTION 1225 [OSHPD 2] -- SKILLED NURSING AND INTERMEDIATE-CARE FACILITIES

Amend sections listed below: Clarifications, general editorial changes and updated references.

Item Number 20	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-20-1	1225.5.1.2.6 Patient toilet room.	Approve as Submitted	Accept		Amendment regarding <i>Nursing Service Space</i> patient toilet rooms, as required by CDPH and CMS Conditions of Participation.	Approved

SECTION 1226 [OSHPD 3] -- CLINICS

Amend sections listed below: Clarifications, general editorial changes and updated references.

Item Number 21	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-21-1	1226.5 OUTPATIENT CLINICAL SERVICES OF A HOSPITAL.	Further Study	Disagree		This section is amended to refer to Title 24 Parts 1 and 10. Clarification is added for outpatient clinical services in a freestanding building [OSHPD 3] that are not specifically addressed under 1226. CAC recommends coordination regarding OSHPD 3 and with Item 4-4 anchoring requirements. Criteria #8. Post CAC -- OSHPD disagreed with CAC comment and determined OSHPD 3 buildings fall under the model code definition of Equipment. No additional action was taken based on that comment. An editorial change was made in response to CAC recommendation to remove the word "separate," as it is not needed to define "freestanding."	Approved
OSHPD 02/19-21-2	1226.5.11.6.9 Cleanup room.	Further Study	Disagree		Clean up room is removed as redundant language for a soiled utility room. CAC recommends verifying proper cross-referencing of Clean up room. Criteria 2, 3. Post CAC - OSHPD determined the reference to the cleanup room was redundant in this case. This item will remain as originally amended.	Approved
OSHPD 02/19-21-3	1226.5.11.6.10-9 Sterile and pharmaceutical supply storage.	Further Study	Disagree		Renummer section. Coordinate numbering with result of 21-2 verification of cross referencing. Criteria 8. Post CAC -- No additional action.	Approved

SECTION 1228 [OSHPD 5] -- ACUTE PSYCHIATRIC HOSPITALS

Amend sections listed below: Clarifications, general editorial changes and updated references.

Item Number 22	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 02/19-22-1	1224.14.2.5 1228.14.2.5 <i>Examination and treatment room...</i>	Approve as Submitted	Accept		Section correctly re-numbered from previous code cycle.	Approved
OSHPD 02/19-22-2	1228.14.3 <i>Airborne Infection Isolation (All) room(s).</i>	Approve as Submitted	Accept		Amendment regarding bedpan flushing attachment requirements for toilet rooms.	Approved
OSHPD 02/19-22-3	1228.30 PEDIATRIC AND ADOLESCENT PSYCHIATRIC UNIT SERVICE SPACE.	Approve as Amended	Accept		The term "Unit" has been replaced by "Service Space" in the title. CAC recommended additional correction to the rest of the amendment to be consistent with original intent to change the word usage. Criteria #8. OSHPD agreed and modified the text. OSHPD indicated Approve as Submitted in ISOR, yet the official action was Approve as Amended.	Approved
OSHPD 02/19-22-4	1228.30.3 Activity areas.	Approve as Submitted	Accept		Amendment regarding centralization of certain activity areas that may be considered for common use space.	Approved