

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Janis Kent, FAIA, CASp
Date: Thursday, April 23, 2020 7:17:00 PM

Commenter Contact Information

Name: Janis Kent, FAIA, CASp
Date: 4/23/2020 12:00:00 AM
Representing: Stepping Thru Accessibility
Mailing Address
Number and Street: 3553 Atlantic Ave #575
City: Long Beach
State: CA
Zip Code: 90807
Telephone #: 5624269363
Email: janisk@steppingthruaccessibility.com

Proposed Building Standard

Title 24 Part #: Part 11
Section #: 11B-502.4
Proposing State Agency: DSA AC
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

Clarifies and brings us into compliance with ADA Standards

9 Point Criteria Info:
18930(a) 8