

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Alejandra Warner
Date: Friday, May 15, 2020 12:36:22 PM

Commenter Contact Information

Name: Alejandra Warner
Date: 5/15/2020 12:00:00 AM
Representing: City of San Diego
Mailing Address
Number and Street: 4437 Edison St
City: San Diego
State: California
Zip Code: 92117
Telephone #: 6199804251
Email: AWarner@sandiego.gov

Proposed Building Standard

Title 24 Part #: Part 2
Section #: Chapter 2 Definitions
Proposing State Agency: DSA
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

Use the definition that does not conflict with the PROWAG, government entities already use this definition as a type of curb cut.

Blended Transition. A raised pedestrian street crossing, depressed corner, or similar connection between the pedestrian access route at the level of the sidewalk and the level of the pedestrian street crossing that has a grade of 5 percent or less.

9 Point Criteria Info:
18930(a) 7(A)