

**From:** [DGS\\_Website@DGS](mailto:DGS_Website@DGS)  
**To:** [CBSC@DGS](mailto:CBSC@DGS)  
**Subject:** PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Mehdi Shadyab  
**Date:** Monday, April 27, 2020 8:50:03 AM

---

Commenter Contact Information

Name: Mehdi Shadyab  
Date: 4/27/2020 12:00:00 AM  
Representing: City of San Diego  
Mailing Address  
Number and Street: 1222 First Avenue  
City: San Diego  
State: California  
Zip Code: 92101  
Telephone #: 6194465067  
Email: [mshadyab@sandiego.gov](mailto:mshadyab@sandiego.gov)

Proposed Building Standard

Title 24 Part #: Part 2  
Section #: Chapter 11B, Section 11B-205.1  
Proposing State Agency: CAC  
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):  
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The new Exception 9 as proposed does not seem to be an exception. It is specifying where one receptacle should be located at a corner work surface. The intent of this exception is to require one receptacle to comply with the reach range requirements, and one receptacle be exempted, at the corner of work surface. If the words "shall be" are omitted, it would be much clearer. It should read as follows:

9. In residential dwelling units with mobility features where receptacles are provided in a kitchen at a corner work surface, one receptacle located 36 inches (915 mm) from either wall at the inside corner.

9 Point Criteria Info:  
18930(a) 1