

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Mehdi Shadyab
Date: Monday, April 27, 2020 3:42:02 PM

Commenter Contact Information

Name: Mehdi Shadyab
Date: 4/27/2020 12:00:00 AM
Representing: City of San Diego
Mailing Address
Number and Street: 1222 First Avenue
City: San Diego
State: California
Zip Code: 92101
Telephone #: 6194465067
Email: mshadyab@sandiego.gov

Proposed Building Standard

Title 24 Part #: Part 2
Section #: Chapter 11B, Section 11B-705.1.1.3.1
Proposing State Agency: CBSC-CAC
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

Color 33538 of the SAE AMS-STD-595A labels this color as 'Orange Yellow' to differentiate from other shades of yellow colors. Add word 'orange' before 'yellow' in the text will make this provision clearer and consistent with the STD 595A. The proposed text should read as follows:

11B-705.1.1.3.1 Detectable warning surfaces shall be color orange yellow and approximate FS 33538 of Federal Standard 595C 33538 of SAE AMS-STD-595A.

9 Point Criteria Info:
18930(a) 1