

**From:** [DGS Website@DGS](mailto:DGS_Website@DGS)  
**To:** [CBSC@DGS](mailto:CBSC@DGS)  
**Subject:** PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Armin Wolski  
**Date:** Thursday, May 14, 2020 3:53:24 PM

---

Commenter Contact Information

Name: Armin Wolski  
Date: 5/14/2020 12:00:00 AM  
Representing: Self  
Mailing Address  
Number and Street: 1429  
City: El Cerrito  
State: CA  
Zip Code: 94530  
Telephone #: 5102334768  
Email: armin.wolski@hotmail.com

Proposed Building Standard

Title 24 Part #: Part 2  
Section #: 3007.1  
Proposing State Agency: CA  
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):  
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The 45 day language proposed after the Code Advisory Committee hearing does not match the CAC hearing's intent. The following language better follows the intent of the comments made when it was voted for further study: 3007.1 General. Where required by Section 403.6.1, every floor above and including the lowest level of fire department vehicle access of the building shall be served by fire service access elevators complying with Sections 3007.1 through 3007.9. Except as modified in this section, fire service access elevators shall be installed in accordance with this chapter and California Code of Regulations, Title 8, Division 1, Chapter 4, Subchapter 6, Elevator Safety Orders.

Exception: Below grade floors, primarily used as parking garage, shall not be required to be served by fire service access elevators.

9 Point Criteria Info:  
18930(a) 5