

**COMMISSION ACTION MATRIX**  
**2019 CALIFORNIA ELECTRICAL CODE, TITLE 24, PART 3 (2017 NATIONAL ELECTRICAL CODE)**  
**AGENCY: THE OFFICE OF THE STATE FIRE MARSHAL [SFM 03/19]**

**LEGEND:**

**CAC Actions:** Approve as Amended, Approve as Submitted, Disapprove, Further Study

**Agency Responses:** Accept, Disagree, Withdraw

**CBSC Actions:** Approve as Amended, Approve as Submitted, Disapprove, Further Study

**Matrix Paper Color (for commission action only):** GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

**GREEN/PEME AD HOC CODE ADVISORY COMMITTEE**

**CHAPTER 3, WIRING METHODS AND MATERIALS**

Amend Article 334-Nonmetallic-Sheathed Cable: Types NM, NMC, and NMS

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 03/19-1	334.10				Propose regulations that reflect the tentative interim amendment, issued by NFPA, limiting NM, NMC, and NMS cable to 4 stories or fewer in types III, IV and V Construction.	

**ARTICLES 90, 425, 691, 710, 712**

Adopt Articles that were missed during the 2018 Triennial Rulemaking Cycle.

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 03/19-2-1	Article 90				Adopt Article to correct oversight.	
SFM 03/19-2-2	Article 425				Adopt Article to correct oversight	
SFM 03/19-2-3	Article 691				Adopt Article to correct oversight	
SFM 03/19-2-4	Article 710				Adopt Article to correct oversight	
SFM 03/19-2-5	Article 712				Adopt Article to correct oversight	

