

COMMISSION ACTION MATRIX - GREEN
2019 CALIFORNIA ELECTRICAL CODE, TITLE 24, PART 3 (2017 NATIONAL ELECTRICAL CODE)
AGENCY: THE OFFICE OF THE STATE FIRE MARSHAL [SFM 03/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

GREEN-PEME AD HOC CODE ADVISORY COMMITTEE

CHAPTER 3, wiring methods and materials

Amend Article 334-Nonmetallic-Sheathed Cable: Types NM, NMC, and NMS

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 03/19-1	334.10	Approve as Amended	Accept		Propose regulations that reflect the tentative interim amendment, issued by NFPA, limiting NM, NMC, and NMS cable to 4 stories or fewer in types III, IV and V Construction. CAC recommends consider public comment re cable & have BFO/SDLF review.	

Articles 90, 425, 691, 710, 712

Adopt Articles that were missed during the 2018 Triennial Rulemaking Cycle.

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
SFM 03/19-2-1	Article 90	Approve as Submitted	Accept		Adopt Article to correct oversight.	
SFM 03/19-2-2	Article 425	Approve as Submitted	Accept		Adopt Article to correct oversight	
SFM 03/19-2-3	Article 691	Approve as Submitted	Accept		Adopt Article to correct oversight	
SFM 03/19-2-4	Article 710	Approve as Submitted	Accept		Adopt Article to correct oversight	
SFM 03/19-2-5	Article 712	Approve as Submitted	Accept		Adopt Article to correct oversight	