

COMMISSION ACTION MATRIX - APPROVED BY THE CALIFORNIA BUILDING STANDARDS COMMISSION JULY 13, 2020
2019 CALIFORNIA GREEN BUILDING CODE, TITLE 24, PART 11
AGENCY: THE DIVISION OF THE STATE ARCHITECT [DSASS-CC 04/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

GREEN-PEME AD HOC CODE ADVISORY COMMITTEE

ELECTRIC VEHICLE INFRASTRUCTURE

SECTION 5.106.5.3 – Electric vehicle (EV) charging.

Amend sections listed below

| Item Number 1 | Code Section | CAC Action | Agency Response | Public Comments | Annotations | CBSC Action |
|--------------------|--|-----------------------------|-----------------|-----------------|--|-----------------|
| DSASS-CC 04/19-1-1 | TABLE 5.106.5.3.3 EV charging space calculation | Approve as Submitted | Accept | | Amend table to increase the percentage of spaces required for electrical vehicle (EV) charging infrastructure. Associated with voluntary measures Item 10 below. | Approved |
| DSASS-CC 04/19-1-2 | 5.106.5.3.5 [N] Future charging spaces | Approve as Submitted | Accept | | Amend section to add "Note" clarifying that future EV charging spaces shall count toward the total required parking spaces. This note does not apply to K-12 schools and community colleges. | Approved |

LIGHT POLLUTION REDUCTION
SECTION 5.106.8 Light pollution reduction.
Amend sections listed below

| Item Number 2 | Code Section | CAC Action | Agency Response | Public Comments | Annotations | CBSC Action |
|--------------------|---|-----------------------------|-----------------|-----------------|--|-----------------|
| DSASS-CC 04/19-2-1 | 5.106.8 Light pollution reduction., Exceptions: [N], #1, #5 | Approve as Submitted | Accept | | Amend section to strike the [N] banner from Exceptions. Amending Exception 1 and adding new Exception 5 are to align with CALGreen BUG requirements adopted into the California Energy Code, Section 130.2(b). | Approved |
| DSASS-CC 04/19-2-2 | 5.106.8.1 Facing – Backlight. & Exception: Corners | Approve as Submitted | Accept | | New code section proposing to relocate and amend table footnotes from Table 5.108.6 [N] . Section was added to properly align requirements for stringency of facing-backlight in relation to property lines. Add Exception for corners. | Approved |
| DSASS-CC 04/19-2-3 | 5.106.8.2 Facing – Glare., Notes: #1 [N] | Approve as Submitted | Accept | | New code section proposing to relocate and amend table footnotes from Table 5.108.6 [N] . Section was added to properly align requirements for stringency of facing-glare in relation to property lines. Repeal the [N] banner in Notes. | Approved |
| DSASS-CC 04/19-2-4 | TABLE 5.106.8 [N] Maximum Allowable Backlight . . . | Approve as Submitted | Accept | | Repeal footnotes from this table and relocate them into two new code Section 5.106.8.1 with an exception for “corners,” and new Section 5.106.8.2. Table superscript numbers are re-adjusted to align with the with revised footnote numbers. | Approved |

PRE-RINSE SPRAY VALVES
SECTION 5.303 – INDOOR WATER USE

Amend sections listed below

| Item Number 3 | Code Section | CAC Action | Agency Response | Public Comments | Annotations | CBSC Action |
|--------------------|---|----------------------------|-----------------|-----------------|---|-------------|
| DSASS-CC 04/19-3-1 | <u>5.303.3.4.6</u> <u>Pre-rinse</u> <u>spray valve.,</u> | Approve as Submitted | Accept | | New code section to align with Appliance Efficiency regulations adopted for pre-rinse spray valves by the CEC in Title 20 for automatic shutoff requirements of the California Code of Regulations. | Approved |
| DSASS-CC 04/19-3-2 | <u>FOR</u> <u>REFERENCE</u> <u>ONLY : . .</u> <u>Table H-2 . . .</u> <u>& Title 20</u> <u>Section</u> <u>1605.3(h)(4)</u> <u>(A)</u> | Approve as Submitted | Accept | | Re-print Title 20 Table H2, and Title 20 Section 1605.3(h)(4)(A) for pre-rinse spay valves, for reference and labeling requirements on spray valves. | Approved |

POLLUTANT CONTROL
SECTION 5.504 – POLLUTANT CONTROL

Amend sections listed below

| Item Number 4 | Code Section | CAC Action | Agency Response | Public Comments | Annotations | CBSC Action |
|--------------------|---|----------------------------|-----------------|-----------------|--|-------------|
| DSASS-CC 04/19-4-1 | <u>5.504.4.4</u> <u>Carpet</u> <u>systems</u> | Approve as Submitted | Accept | | Amended section to repeal items 1 through 5 and add new CDPH referenced standard for VOC limits for carpet systems with new website link. CAC: recommended to review this amendment with other state agencies and interested parties | Approved |

| | | | | | | |
|--------------------|---|-------------------------------------|---------------|--|--|-----------------|
| DSASS-CC 04/19-4-2 | 5.504.4.4.1 Carpet cushion | Approve as Submitted | Accept | | Amended section to repeal “Carpet and Rug Institute’s Green Label program” and new CDPH referenced standard added for VOC limits for carpet cushion with new website link. CAC: recommended to review this amendment with other state agencies and interested parties | Approved |
| DSASS-CC 04/19-4-3 | 5.504.4.4.6 Resilient flooring systems | Approve as Submitted | Accept | Josh Jacobs-Underwriters Laboratory (UL), recommends Approve as Amended. | Amended section to repeal items 1 through 4 and add new CDPH referenced standard for VOC limits for resilient flooring systems with new website link. CAC: recommended to review this amendment with other state agencies and interested parties 45-day: See FSOR for agency response. | Approved |