

COMMISSION ACTION MATRIX - APPROVED BY THE CALIFORNIA BUILDING STANDARDS COMMISSION JULY 13, 2020
2019 CALIFORNIA MECHANICAL CODE, TITLE 24, PART 4
AGENCY: THE OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT [OSHPD 05/19]

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

GREEN-PEME AD HOC CODE ADVISORY COMMITTEE

CHAPTER 1 – ADMINISTRATION

DIVISION I – CALIFORNIA ADMINISTRATION

Amend sections listed below

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-1-1	1.10.1 OSHPD 1 and OSHPD 1R., Application.	Approve as Submitted	Accept		Amend code section to add the term “SPC or freestanding” to align with Title24, Part 2.	Approved
OSHPD 05/19-1-2	1.10.4 OSHPD 4., Enforcement agency.	Approve as Submitted	Accept		Amend code section to clarify proper authority having jurisdiction for OSHPD 4 facilities. After additional study (post 45day) with SFM, OSHPD has withdrawn this item.	Approved

CHAPTER 2 – DEFINITIONS

SECTION 203.0 – A –

Amend sections listed below

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-2-1	Authority Having Jurisdiction. [OSHPD 1, 1R, 2, 3, & 4 & 5]	Approve as Submitted	Accept		Add banners 1R and 5. Repeal banner 4.	Approved

CHAPTER 3 – GENERAL REGULATIONS

Amend sections listed below

Item Number3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-3-1	<u>301.7 OSHPD 1R</u> <u>[OSHPD 1R].</u>	Approve as Submitted	Accept		Add new code section regarding General requirements.	Approved
OSHPD 05/19-3-2	303.2 Closet or Alcove Installations., [OSHPD 1, 1R, 2, 3, 4 & 5]; Exception: [OSHPD 1, 1R, 2, 3, 4 & 5]	Approve as Submitted	Accept		Code section is not adopted by OSHPD and repealing banners, text and exception.	Approved
OSHPD 05/19-3-3	<u>306.2 Building Automation Systems.</u> <u>[OSHPD 1]</u>	Approve as Submitted	Accept		Add new code section for Building Automation Systems.	Approved

OSHPD 05/19-3-4	<u>318.2 Services/System and Utilities.</u>	Approve as Submitted	Accept		Amend code section to add a new reference to CBC sections.	Approved
OSHPD 05/19-3-5	<u>320.3.1</u>	Approve as Submitted	Accept		Editorial correction for the term "humidities."	Approved
OSHPD 05/19-3-6	<u>320.4 Telephone and Technology Equipment Centers Data Equipment Rooms. [OSHPD 1 & 4]</u>	Approve as Submitted	Accept		Amend the code section title.	Approved
OSHPD 05/19-3-7	<u>320.4.4</u>	Approve as Submitted	Accept		Add new code section for Technology Equipment Centers.	Approved
OSHPD 05/19-3-8	<u>321.1</u>	Approve as Submitted	Accept		Amend codes section to add fans in certain areas that are to be on essential power.	Approved
OSHPD 05/19-3-9	<u>321.2</u>	Approve as Submitted	Accept		Amend language to add fans to code section.	Approved
OSHPD 05/19-3-10	<u>323.0 Mechanical Equipment Schedules. [OSHPD 1, 1R, 2, 4 & 5]</u>	Approve as Submitted	Accept		Add new code section for requirements in mechanical equipment schedules on construction documents.	Approved

CHAPTER 4 – VENTILATION AIR

Amend sections listed below

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-4-1	402.0 Ventilation Air. Not Permitted for OSHPD 1, 2, 3 & 4	Approve as Submitted	Accept		Amend code Section 402 to repeal the “Not permitted” banner to correct a clerical error in the banner from a previous cycle.	Approved
OSHPD 05/19-4-2	402.1 Occupiable Spaces.	Approve as Submitted	Accept		Add a banner for OSHPD 1, 1R, 2, 3, 4 & 5 facilities with occupiable spaces listed in Table 4-A	Approved
OSHPD 05/19-4-3	402.1.3 Ventilation in Health Care Facilities.	Approve as Submitted	Accept		Amend code section to repeal code language. OSHPD does not adopt this standard	Approved
OSHPD 05/19-4-4	<u>402.1.3(1)</u>	Approve as Submitted	Accept		Add new code subsection to clarify Ventilation rates for areas not specified in Table 4.	Approved
OSHPD 05/19-4-5	402.2 Natural Ventilation.	Approve as Submitted	Accept		Add clarification with a banner stipulating that this code section does not apply to certain OSHPD facilities.	Approved
OSHPD 05/19-4-6	402.3 Mechanical Ventilation.	Approve as Submitted	Accept		Add clarification with a banner stipulating that this code section does not apply to certain OSHPD facilities.	Approved
OSHPD 05/19-4-7	403.0 Ventilation Rates.	Approve as Submitted	Accept		Add clarification with a banner stipulating that this code section does not apply to certain OSHPD facilities listed in Table 4A.	Approved
OSHPD 05/19-4-8	<u>407.4.1.7 Recirculating Room Units.</u>	Approve as Submitted	Accept		Add this new code subsection for Ventilation System Details.	Approved
OSHPD 05/19-4-9	408.2.2, 408.2.3, 408.2.4	Approve as Submitted	Accept		Amend these code sections to add MERV requirements.	Approved
OSHPD 05/19-4-10	408.3.3	Approve as Submitted	Accept		Amend this code section to add MERV requirements.	Approved
OSHPD 05/19-4-11	411.0 through 417.0	Approve as Submitted	Accept		Repeal 1R banner.	Approved
OSHPD 05/19-4-12	TABLE 4-A	Approve as Submitted	Accept	Various stakeholders recommend Disapprove	Amend table to repeal the 100%-outdoor air column. See ET and ISOR. 45-day comments: See FSOR for agency responses.	Approved

OSHPD 05/19-4-13	<i>Notes for Table 4-A; a. & b., f & ab.</i>	Approve as Submitted	Accept	Various stakeholders recommend Disapprove	Amend Table 4-A footnotes. 45-day comments: See FSOR for agency responses.	Approved
------------------	--	-----------------------------	---------------	---	--	-----------------

CHAPTER 5 – EXHAUST SYSTEMS

PART II – COMMERCIAL HOODS AND KITCHEN VENTILATION.

Amend sections listed below

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-5-1	<u>507.7 Pharmaceutical Compounding Exhaust Discharge. [OSHPD 1, 2, 3, 4 & 5]</u>	Approve as Submitted	Accept		Add new code section for Pharmaceutical Compounding Exhaust Discharge.	Approved

CHAPTER 6 – DUCT SYSTEMS

604.0 Insulation of ducts.

Amend sections listed below

Item Number 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-6-1	604.2 [OSHPD 1, 1R, 2, 3 (surgical clinics), 4 & 5]	Approve as Submitted	Accept		Repeal the word “terminal,” for surgical clinics.	Approved

CHAPTER 10 – BOILERS AND PRESSURE VESSELS

1001.2 Boiler rooms and enclosures.

Amend sections listed below

Item Number 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-7-1	<u>1001.2.1</u> <u>[OSHPD 1, 1R, 2, 3, 4, & 5]</u>	Approve as Submitted	Accept		Add new code section to specify requirements to correlate with NFPA 99 for boiler rooms.	Approved

CHAPTER 11 -- REFRIGERATION

1104.0 Requirements for refrigerant and refrigeration system use.

Amend sections listed below

Item Number 8	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-8-1	1104.3 Institutional Occupancies., <u>[OSHPD 1 & 4]</u> <u>Exception:</u>	Approve as Submitted	Accept		Add new exception for technology equipment centers, OSHPD 1 & 4.	Approved