

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Adrienne Alcantara
Date: Friday, October 29, 2021 4:39:00 PM

Commenter Contact Information

Name: Adrienne Alcantara

Date: 10/29/2021 12:00:00 AM

Representing: Kaiser Permanente

Mailing Address

Number and Street: 1800 Harrison-19th floor

City: Oakland

State: CA

Zip Code: 94612

Telephone #: 7144620819

Email: adrienne.alcantara@kp.org

Proposed Building Standard

Title 24 Part #: Part 2

Section #: Chapter 12, 1224.14.2.10 Nourishment area.

Proposing State Agency: OSHPD

This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Disapprove

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

To be consistent with other unit support rooms, revise to- A nourishment room shall be provided and shall comply with 1224.4.4.5.

9 Point Criteria Info:

18930(a) 6