

**From:** [DGS Website@DGS](mailto:DGS_Website@DGS)  
**To:** [CBSC@DGS](mailto:CBSC@DGS)  
**Subject:** PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Carrie Sheridan  
**Date:** Friday, October 29, 2021 4:35:56 PM

---

Commenter Contact Information

Name: Carrie Sheridan

Date: 10/29/2021 12:00:00 AM

Representing: Kaiser Permanente

Mailing Address

Number and Street: 1800 Harrison-19th floor

City: Oakland

State: CA

Zip Code: 94612

Telephone #: 7144620819

Email: [adrienne.alcantara@kp.org](mailto:adrienne.alcantara@kp.org)

Proposed Building Standard

Title 24 Part #: Part 2

Section #: Chapter 12, 1224.14.2.6 Clean utility/workroom.

Proposing State Agency: OSHPD

This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):

Approve

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

9 Point Criteria Info:

18930(a) 4