

COMMISSION ACTION MATRIX

2022 CALIFORNIA BUILDING CODE (CBC), TITLE 24, PART 2 VOLUME 1, 2021 INTERNATIONAL BUILDING CODE (IBC)
 AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT (OSHPD 04/21)

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

HEALTH FACILITIES CODE ADVISORY COMMITTEE – AUGUST 11, 2021

CHAPTER 1, SCOPE AND ADMINISTRATION

OSHPD proposes to adopt 2021 IBC Chapter 1 and carry forward existing 2019 CBC California amendments for OSHPD 1, 1R, 2, 3, 4, and 5 with the following modifications listed below:

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-1-1	1.10.2 OSHPD 2, 2A and 2B.	Approve	Accept		Amend section to update the application of OSHPD 2 to include designations for OSHPD 2A and 2B.	
OSHPD 04/21-1-2	110.3.12	Approve	Accept		Repeal section regarding types of connection protection inspections.	

CHAPTER 2, DEFINITIONS

OSHPD proposes to adopt 2021 IBC Chapter 2 and carry forward existing 2019 CBC California amendments for OSHPD 1, 1R, 2, 3, 4 and 5 with the following modifications listed below:

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-2-1	MASS TIMBER (Repealed)	Approve	Accept		Repeal California defined term.	
OSHPD 04/21-2-2	WALL, LOAD BEARING	Approve	Accept		Amend defined term to update with model defined term regarding mass timber.	

CHAPTER 3 OCCUPANCY CLASSIFICATION AND USE

OSHDP proposes to adopt 2021 IBC Chapter 3 and carry forward existing 2019 CBC California amendments for OSHPD 1, 1R, 2, 3, 4, and 5.

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-3-1	CHAPTER 3	Approve	Accept		Adopt Chapter 3 without additional amendments.	

CHAPTER 4 SPECIAL DETAILED REQUIREMENTS BASED ON OCCUPANCY AND USE

OSHDP proposes to adopt 2021 IBC Chapter 4 for OSHPD 1, 1R, 2, 4, and 5, and carry forward specific existing 2019 CBC California amendments for OSHPD 3.

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-4-1	CHAPTER 4	Approve	Accept		Adopt Chapter 4 without additional amendments.	

CHAPTER 5 GENERAL BUILDING HEIGHTS AND AREAS**CHAPTER 6 TYPES OF CONSTRUCTION****CHAPTER 7 FIRE AND SMOKE PROTECTION FEATURES**

OSHDP proposes to adopt 2021 IBC Chapters 5, 6 and 7 OSHPD 1, 1R, 2, 3, 4, and 5, and carry forward existing 2019 CBC California amendments.

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-5-1	CHAPTER 5 CHAPTER 6 CHAPTER 7	Approve	Accept		Adopt Chapters 5, 6 and 7 without additional amendments.	

CHAPTER 7A [SFM] MATERIALS AND CONSTRUCTION METHODS FOR EXTERIOR WILDFIRE EXPOSURE

OSHDP does not adopt 2022 CBC California *Chapter 7A [SFM]*.

Item Number 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-6-1	CHAPTER 7A [SFM]	Approve	Accept		OSHDP does not adopt <i>Chapter 7A [SFM]</i> .	

CHAPTER 8 INTERIOR FINISHES

CHAPTER 9 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

CHAPTER 10 MEANS OF EGRESS 5 GENERAL BUILDING HEIGHTS AND AREAS

OSHPD proposes to adopt 2021 IBC Chapters 8, 9 and 10 OSHPD 1, 1R, 2, 3, 4, and 5, and carry forward existing 2019 CBC California amendments.

Item Number 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-7-1	CHAPTER 8 CHAPTER 9 CHAPTER 10	Approve	Accept		Adopt Chapters 8, 9 and 10 without additional amendments.	

CHAPTER 11A CHAPTER 11A HOUSING ACCESSIBILITY

CHAPTER 11B ACCESSIBILITY TO PUBLIC BUILDINGS, PUBLIC ACCOMMODATIONS, COMMERCIAL BUILDINGS AND PUBLIC HOUSING

OSHPD does not adopt 2022 CBC California *Chapters 11A and 11B.*

Item Number 8	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-8-1	CHAPTER 11A CHAPTER 11B	Approve	Accept		OSHPD does not adopt <i>Chapters 11A and 11B.</i>	

CHAPTER 12 INTERIOR ENVIRONMENT

Item Number 9 through Item Number 38

OSHPD proposes to adopt 2021 IBC Chapter 12 for OSHPD 1, 1R, 2, 3, 4, and 5, and carry forward existing 2019 CBC California amendments with the following modifications listed below:

Item Number 9	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-9-1	1224.1 Scope. [OSHPD 1]	Approve	Accept		Editorial amendment to the text to remove the word "either."	

Item Number 10	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-10-1	1224.3 Definitions. HANDWASHING STATION.	Approve	Accept		Editorial amendment to the text regarding hands-free operation of doors.	
OSHPD 04/21-10-2	INVASIVE PROCEDURE. (New)	Approve	Accept		OSHPD proposes a new defined term.	

Item Number 10	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-10-3	LOCATION TERMINOLOGY, READILY ACCESSIBLE.	Approve	Accept		Amend this defined term of the term "Readily Accessible" to add stipulation regarding 200 foot proximity to area served.	
OSHPD 04/21-10-4	PROCEDURE ROOM. (New)	Approve	Accept		OSHPD proposes a new defined term.	
OSHPD 04/21-10-5	RESTRICTED AREA.	Approve	Accept		Amend this defined term to add stipulation regarding operative or other invasive procedures.	
OSHPD 04/21-10-6	SEMI-RESTRICTED AREA. (New)	Approve	Accept		OSHPD proposes a new defined term.	
OSHPD 04/21-10-7	[BS] START OF CONSTRUCTION.	Approve	Accept		Amend this defined term to add banner stipulating OSHPD does NOT adopt the model defined term. Post CAC: minor grammar correction to word "area" to be plural, "areas."	
OSHPD 04/21-10-8	UNRESTRICTED AREA. (New)	Approve	Accept		OSHPD proposes a new defined term.	

Item Number 11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-11-1	1224.4.4.1	Approve as Amended	Accept		Editorial amendment to the title text to include procedure room. Code Advisory Committee (CAC): AA under criteria #8 - Editorial correction to add comma to section heading before word "and." The only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-2	1224.4.4.1.2 Treatment room.	Approve as Amended	Accept		Editorial amendment to the text to remove the word "either." CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-3	1224.4.4.1.4 Procedure room. (New)	Approve as Amended	Accept		OSHPD proposes new section and subsections. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	

Item Number 11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-11-4	1224.4.4.1.4.1 (New)	Approve as Amended	Accept		New subsection. General. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-5	1224.4.4.1.4.2 (New)	Approve as Amended	Accept		New subsection. Space requirements. CAC: AA under criteria #8 - suggested to amend (2)(b) to stipulate 6 feet "minimum" dimension. Editorial correction to correct metric conversion.	
OSHPD 04/21-11-6	1224.4.4.1.4.3 (New)	Approve as Amended	Accept		New subsection. Documentation area. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-7	1224.4.4.1.4.4 (New)	Approve as Amended	Accept		New subsection. Patient privacy. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-8	1224.4.4.1.4.5 (New)	Approve as Amended	Accept		New subsection. Handwashing station. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-9	1224.4.4.1.5 <i>Seclusion room.</i> (Renumbered)	Approve as Amended	Accept		Renumber <i>1224.4.4.1.4</i> to <i>1224.4.4.1.5</i> and subsequent subsections. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	
OSHPD 04/21-11-10	1224.4.4.4.1	Approve as Amended	Accept		Amend this section regarding accessibility to nursing stations. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5.	

Item Number 12	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-12-1	TABLE 1224.4.6.1, <i>Line 6</i>	Approve	Accept		Editorial amendment to identify that line 6 is specifically for an intensive care unit to eliminate the confusion with line 3.	

Item Number 13	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-13-1	TABLE 1224.4.6.5	Approve	Accept		Amendment to table to add footnote 1.	

Item Number 14	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-14-1	1224.4.11 Interior finishes.	Approve as Amended	Accept		Amendment to add reference to a subsection. CAC: AA under criteria #6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 14-3.	
OSHPD 04/21-14-2	1224.4.11.4.1 Ceiling finishes.	Approve as Amended	Accept		Amendment to add reference to <i>Table 1224.4.11.4a</i> . CAC: AA under criteria #6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 14-3.	
OSHPD 04/21-14-3	TABLE 1224.4.11.4a (New)	Approve as Amended	Accept		OSHPD proposes a new table for room classifications. Approve as Amended, Criteria #6. Post CAC: Punctuation and grammar revisions adding the word "or" regarding the Use column "Invasive procedures." For Operating room and Class 3 imaging room.	

Item Number 15	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-15-1	1224.5.4 SPC/NPC compliance.	Approve	Accept		Amendment to update references to California Existing Building Code and to Section 307A.	

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-16-1	1224.14.2 Support areas.	Approve	Accept		Amendments to this section and subsections regarding access and space requirements.	
OSHPD 04/21-16-2	1224.14.2.2	Approve	Accept		Editorial amendment.	
OSHPD 04/21-16-3	1224.14.2.6	Approve	Accept		Editorial amendment.	

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-16-4	1224.14.2.7	Approve	Accept		Editorial amendment.	
OSHPD 04/21-16-5	1224.14.2.10	Approve	Accept		Editorial amendment.	
OSHPD 04/21-16-6	1224.14.2.12	Approve	Accept		Editorial amendment.	
OSHPD 04/21-16-7	1224.14.2.15 (Renumbered)	Approve	Accept		Renumber 1224.14.2.14.1 to 1224.14.2.15. and amend per requirements for space allocated for attendant.	
OSHPD 04/21-16-8	1224.14.2.16 through 1224.14.2.19 (Renumbered)	Approve	Accept		Renumber sections sequentially.	

Item Number 17	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-17-1	1224.15.1 General.	Approve	Accept		Editorial amendment regarding sterile cores within surgical service spaces.	
OSHPD 04/21-17-2	1224.15.2.2 Procedure room(s). (New)	Approve	Accept		New amendment to add reference to <i>Section 1224.4.4.1.4.</i>	
OSHPD 04/21-17-3	1224.15.2.2.1 (Renumbered)	Approve	Accept		Renumber and re-format 1224.15.2.2 to 1224.15.2.2.1.	

Item Number 18	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-18-1	1224.16.3.1 Space requirements.	Approve	Accept		Editorial amendment regarding access and circulation requirements and adding reference to Patient Care Locations in Section 1224.3. Post CAC: Remove comma and capitalize word "Patient Bay."	

Item Number 19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-19-1	1224.18	Approve	Accept		Amendment regarding requirements for environmental controls.	

Item Number 19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-19-2	1224.18.1 Minimum requirements. Items 1, 2 and 6	Approve	Accept		Amendments modifying sub-items and minimum requirements at various areas and stations within different care units.	
OSHPD 04/21-19-3	1224.18.1.1, Items 1 through 5. (New)	Approve	Accept		New amendment to add Items 1 through 5.	
OSHPD 04/21-19-4	1224.18.1.2 (New)	Approve	Accept		New amendment regarding modality devices.	
OSHPD 04/21-19-5	1224.18.4 Magnetic resonance imaging (MRI). Items 3 and 4.	Approve	Accept		Amendments modifying Items 3 and 4 in this section.	
OSHPD 04/21-19-6	1224.18.5.2	Approve	Accept		Editorial amendment.	
OSHPD 04/21-19-7	1224.18.5.3	Approve	Accept		New amendment regarding toilet access.	
OSHPD 04/21-19-8	1224.18.5.4 Processing Room. (New)	Approve	Accept		New amendment regarding requirements for decontamination areas.	
OSHPD 04/21-19-9	1224.18.5.4.1 (New)	Approve	Accept		New amendment regarding requirements for decontamination areas.	

Item Number 20	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-20-1	1224.19.7.1	Approve	Accept		Editorial amendment.	
OSHPD 04/21-20-2	1224.20.3 Outside Service.	Approve	Accept		Editorial amendment regarding requirements for temporary mobile kitchens.	

Item Number 21	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-21-1	1224.22.1 Minimum requirements.	Approve	Accept		Editorial amendment regarding storage and sterilizing areas.	

Item Number 22	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-22-1	1224.25.1 Minimum facilities.	Approve	Accept		Editorial amendment regarding employee dressing rooms and lockers.	

Item Number 23	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-23-1	1224.28.2.1 Procedure room.	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 23-3.	
OSHPD 04/21-23-2	1224.28.2.3 Equipment space.	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 23-3.	
OSHPD 04/21-23-3	1224.28.4.8 Imaging equipment room.	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 -Editorial amendment to delete the word “Electronic” at beginning of definition. No amendments suggested for the rest of Item 23.	
OSHPD 04/21-23-4	1224.28.4.12 Staff changing areas.	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 23-3.	
OSHPD 04/21-23-5	1224.28.5.2 Control room. Item 3	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 23-3.	
OSHPD 04/21-23-6	1224.28.5.5.2 iMRI. Item 3	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 23-3.	

Item Number 23	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-23-7	1224.28.5.5.3 Vascular imaging.	Approve as Amended	Accept		Editorial amendments revising and updating equipment requirements. CAC: AA under criteria #4, 6 - no amendments suggested for this subitem, the only suggested amendment is in subitem 23-3	

Item Number 24	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-24-1	1224.29.1.12	Approve	Accept		Editorial amendments regarding refrigeration storage requirements.	
OSHPD 04/21-24-2	1224.29.1.13, Exception	Approve	Accept		Editorial amendment regarding protected environment unit.	

Item Number 25	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-25-1	1224.29.2.6 Area.	Approve	Accept		Editorial amendment regarding minimum headwall width.	

Item Number 26	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-26-1	1224.30.1 Patient rooms.	Approve	Accept		Editorial amendment regarding direct visual observation.	
OSHPD 04/21-26-2	1224.30.2 Examination room and treatment rooms.	Approve as Amended	Accept		Editorial amendment regarding pediatric unit. Approve as Amended, Criteria #6. Post CAC: editorial clarification to stipulate whether the Exam room and Treatment rooms are separated.	
OSHPD 04/21-26-3	1224.30.3.1 Play area.	Approve as Amended	Accept		Editorial amendment regarding direct visual observation. Approve as Amended, Criteria #6. Post CAC: editorial clarification to change Section heading to "Play Room."	

Item Number 27	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-27-1	1224.31.1.1 General.	Approve	Accept		Editorial amendment regarding acute medical care. Post CAC: editorial clarification to change word “provide” to add “s.”	
OSHPD 04/21-27-2	1224.31.1.10	Approve	Accept		Editorial amendment regarding acute medical care. Post CAC: add comma in OSHPD banner.	
OSHPD 04/21-27-3	1224.31.1.17 Administrative center(s) or nurse station(s). (New)	Approve	Accept		New amendment regarding distance from administrative centers or nurse stations to patient bedrooms.	

Item Number 28	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-28-1	1224.32.3.2.1 Postpartum bed ratio. Exceptions	Approve	Accept		Editorial amendment regarding requirements per section 1224.32.3.2.	

Item Number 29	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-29-1	1224.33.2.2 Treatment room. Item 5	Approve	Accept		Editorial amendment regarding access/circulation requirements.	
OSHPD 04/21-29-2	1224.33.2.7 Observation area. Item 2	Approve	Accept		Editorial amendment regarding clearances around beds and gurneys.	
OSHPD 04/21-29-3	1224.33.3.14	Approve	Accept		Editorial amendment regarding self-contained medication dispensing units.	
OSHPD 04/21-29-4	1224.33.4.3	Approve	Accept		Editorial amendment regarding visual privacy.	
OSHPD 04/21-29-5	1224.33.5.1 Observation units. Item 2	Approve	Accept		Editorial amendment regarding visual privacy.	

Item Number 30	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-30-1	1224.34.1.2.2 Positron Emission Tomography (PET). Item 7	Approve	Accept		Editorial amendment regarding imaging equipment room requirements.	

Item Number 30	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-30-2	1224.34.1.2.3, Items 1, 2, and 3	Further Study	Accept		Editorial amendment regarding shielding and imaging equipment room requirements. Further Study, Criteria #8. Post CAC: Editorial revision to remove duplicated Term "Control room" from text to be consistent with other amendments proposed in this section.	
OSHPD 04/21-30-3	1224.34.6.3 Pre-procedure/recovery accommodations. Item 3	Approve	Accept		Editorial amendment regarding access/circulation requirements.	

Item Number 31	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-31-1	1224.39.3.2.1	Approve	Accept		Editorial amendment regarding dedicated cleaning areas and decontaminating instruments.	
OSHPD 04/21-31-2	1224.39.3.4 Post-anesthesia recovery area.	Approve	Accept		Editorial amendment to update section reference to Section 1224.16.	
OSHPD 04/21-31-3	1224.39.3.6 Service areas.	Approve	Accept		New amendment referencing requirements per Section 1226.5.11.6	
OSHPD 04/21-31-4	1224.39.6.4.1 Space requirements: Item 2	Approve	Accept		Editorial amendment regarding access/circulation requirements in multi-station rooms or areas.	

Item Number 32	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-32-1	1225.4.1.6.3 Bathroom facilities.	Approve	Accept		Editorial amendment regarding access to private toilet accommodations.	

Item Number 33	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-33-1	1226.4 General construction.	Approve	Accept		Editorial amendment to add a reference to Section 1224.4.	

Item Number 33	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-33-2	1226.4.2.6 Noise reduction. (New)	Approve	Accept		New amendment to add a reference to criteria shown in <i>Table 1224.4.19</i> .	
Item Number 34	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-34-1	1226.4.13.2 Medication station.	Approve	Accept		Editorial formatting.	
Item Number 35	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-35-1	1226.5.11.6.8 Housekeeping room.	Approve	Accept		Editorial update to code reference section <i>1224.39.2.3.2</i> .	
Item Number 36	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-36-1	1226.6.1.4 Oral surgery.	Approve	Accept		Editorial amendment to requirement for treatment using anesthesia.	
Item Number 37	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-37-1	1227.12.10.1 Bathroom facilities.	Approve	Accept		Editorial amendment regarding ratio of bathtubs to showers.	
OSHPD 04/21-37-2	1227.23.2 Mental health treatment.	Approve	Accept		Editorial amendment regarding safety rooms.	
OSHPD 04/21-37-3	1227.23.3 Safety rooms. (Repealed)	Approve	Accept		OSHPD proposes to repeal amendment regarding safety room construction.	
Item Number 38	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-38-1	1228.4.4.2 Reserved. (Title amended)	Approve	Accept		OSHPD proposes to repeal this section and modify the title of this section to be <i>Reserved</i> .	

Item Number 38	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-38-2	1228.4.8 Doors and door openings. Item 6	Approve	Accept		Editorial amendment regarding soft doors for patient room toilets.	
OSHPD 04/21-38-3	1228.13.2	Approve	Accept		Editorial amendment.	
OSHPD 04/21-38-4	1228.13.3	Approve	Accept		Editorial amendment.	
OSHPD 04/21-38-5	1228.13.4	Approve	Accept		Editorial amendment.	
OSHPD 04/21-38-6	1228.14.1.2 Space requirements.	Approve	Accept		Editorial amendment to revise clear floor area square footage.	
OSHPD 04/21-38-7	1228.14.2.12 Equipment and supply storage.	Approve	Accept		Editorial amendment to revise equipment storage floor area square footage. Post CAC: Correction to 15 square feet to metric conversion (1.39 m2).	
OSHPD 04/21-38-8	1228.14.2.13 Gurneys or wheelchairs. (Repealed)	Approve	Accept		OSHPD proposes to repeal amendment regarding storage of wheelchairs and gurneys.	
OSHPD 04/21-38-9	1228.20.1 Dining area.	Approve	Accept		Editorial amendment regarding staff dining.	
OSHPD 04/21-38-10	1228.23 STORAGE.	Approve	Accept		Editorial amendment to reformat sub-sections.	
OSHPD 04/21-38-11	1228.23.1, 1228.23.2, 1228.23.2.1 through 1228.23.2.5, (New)	Approve	Accept		New amendments regarding general and specialized storage.	
OSHPD 04/21-38-12	1228.23.3 Patient storage facilities. (Renumbered)	Approve	Accept		Editorial amendment to renumber and reformat sub-sections.	
OSHPD 04/21-38-13	1228.30.5 Education. (New)	Approve	Accept		New amendment regarding educational program requirements for school aged children.	

[END of CHAPTER 12 Commission Action Items]

CHAPTER 14 EXTERIOR WALLS

OSHDP proposes to adopt 2021 IBC Chapter 14 for OSHPD 1, 1R 2, 3, 4 and 5 and carry forward existing 2019 CBC amendments without additional modification.

Item Number 39	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-39-1	CHAPTER 14	Approve	Accept		Adopt Chapter 14 without additional modifications.	

CHAPTER 15 ROOF ASSEMBLIES AND ROOFTOP STRUCTURES

OSHDP proposes to adopt 2021 IBC Chapter 15 for OSHPD 1, 1R, 2, 4 and 5 and carry forward existing 2019 CBC amendments with the following modifications listed below:

Item Number 40	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-40-1	1511.9 Photovoltaic (PV) panel systems. (Re-titled)	Approve	Accept		OSHDP proposes to re-title section and adopt language formerly in Section 1510.7.2. Post CAC: Correct typo on UL 1703.	
OSHPD 04/21-40-2	1511.9.1 Installation. (Formally 1510.7.2.1)	Approve	Accept		OSHDP proposes to carry forward and renumber section and adopt amendment language formerly in Section 1510.7.2.1.	