

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Scott Martin
Date: Monday, December 6, 2021 4:38:14 PM

Commenter Contact Information

Name: Scott Martin
Date: 12/6/2021 12:00:00 AM
Representing: 4Leaf, Inc.
Mailing Address
Number and Street: 2126 Rheem Drive
City: Pleasanton
State: CA
Zip Code: 94588
Telephone #: 9254625959
Email: smartin@4leafinc.com

Proposed Building Standard

Title 24 Part #: Part 2.5
Section #: Item 12, R702.7 Vapor Retarders Proposing State Agency: HCD This comment is intended for review during: 15-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

For the proposed standard, emailed today the text is:

R702.7 Vapor retarders. (2019 CRC) Class I or II vapor retarders are required on the interior side of frame walls in Climate Zones (begin double strikeout)14 and 16. See the California Energy Code, Figure 100.1-A —California Climate Zones. (end double strikeout)

ending the sentence "in Climate Zones." is confusing. The double strikeout should be moved back three words, to read --

R702.7 Vapor retarders. (2019 CRC) Class I or II vapor retarders are required on the interior side of frame walls. (begin double strikeout)in Climate Zones 14 and 16. See the California Energy Code, Figure 100.1-A —California Climate Zones. (end double strikeout)

9 Point Criteria Info:

18930(a) 1