

**From:** [DGS Website@DGS](mailto:DGS_Website@DGS)  
**To:** [CBSC@DGS](mailto:CBSC@DGS)  
**Subject:** PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Scott Martin  
**Date:** Monday, December 6, 2021 4:45:18 PM

---

Commenter Contact Information

Name: Scott Martin  
Date: 12/6/2021 12:00:00 AM  
Representing: 4Leaf, Inc.  
Mailing Address  
Number and Street: 2126 Rheem Drive  
City: Pleasanton  
State: CA  
Zip Code: 94588  
Telephone #: 9254625959  
Email: [smartin@4leafinc.com](mailto:smartin@4leafinc.com)

Proposed Building Standard

Title 24 Part #: Part 2.5  
Section #: Item 12, R702.7.1 Class III vapor retarders.  
Proposing State Agency: HCD  
This comment is intended for review during: 15-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):  
Disapprove

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The remaining phrase (after removing the double strikeout text) has no content. "Class III vapor retarders shall be permitted where any one of" is not a sentence, and doesn't in any way specify a use for Class III vapor retarders.

If the CA specific language from the 2019 code is to be removed, the entire section (R702.7.1) should be removed, unless some model code language is restored to ensure that the sentence has some meaning.

9 Point Criteria Info:  
18930(a) 6