

COMMISSION ACTION MATRIX - YELLOW

2022 CALIFORNIA PLUMBING CODE, TITLE 24, PART 5, 2021 UNIFORM PLUMBING CODE
 AGENCY: DEPARTMENT OF WATER RESOURCES (DWR 01/21)

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

PLUMBING, ELECTRICAL, MECHANICAL, AND ENERGY (PEME) CODE ADVISORY COMMITTEE

CHAPTER 15 – ALTERNATE WATER SOURCES FOR NONPOTABLE APPLICATIONS

DWR proposes to adopt parts of Chapter 15 of the 2021 UPC with new amendments and carry forward existing amendments as specified into the 2022 CPC

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DWR 01/21-4-2	1501.6	Approve	Accept	Jennifer West-WateReuse, Paul Cook-Irvine Ranch Water District Recommend: Disapprove	Delete DWR-only section and migrate amendments into Sec. 1501.6	

CHAPTER 15 – ALTERNATE WATER SOURCES FOR NONPOTABLE APPLICATIONS

DWR proposes to carry forward existing amendments in Section 1505 with new amendments as follows:

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DWR 01/21-5-1	1505.1 & Exception	Further Study	Accept	45-day public comment period - Jennifer West-WateReuse, Paul Cook-Irvine Ranch Water District Recommend: Disapprove 15-day public comment period – no comments received.	Amend section and add new Exception. DWR presented new code changes at the CAC meeting. CAC recommended: Further Study Under 9-Point Criteria #6. DWR incorporated reference to state regulations to main paragraph. 15-day public comment period. DWR proposed two sentences to specify that the section does not apply to plumbing systems using recycled water that do not enter the interior of the building.	

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DWR 01/21-5-2	1505.1.1	Approve	Accept	Jennifer West-WateReuse, Paul Cook-Irvine Ranch Water District Recommend: Disapprove	Restore UPC language applicable to aboveground and subsurface irrigation uses	
DWR 01/21-5-3	1505.4 <i>Exception 4</i>	Further Study	Accept	Jennifer West-WateReuse, Paul Cook-Irvine Ranch Water District Recommend: Amend exception	Add new <i>Exception 4</i> . CAC recommended: Further Study under 9-Point Criteria #3. DWR added more specificity to inform the code user of requirements for changeover devices.	