

**COMMISSION ACTION MATRIX-YELLOW**

**2022 CALIFORNIA MECHANICAL CODE, TITLE 24, PART 4, 2021 UNIFORM MECHANICAL CODE  
 AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT (OSHDP 01/21)**

**LEGEND:**

**CAC Actions:** Approve, Disapprove, Approve as Amended, Further Study Required

**Agency Responses:** Accept, Disagree, Withdraw

**CBSC Actions:** Approve, Disapprove, Approve as Amended, Further Study Required

**Matrix Paper Color (for commission action only):** GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

**PEME CODE ADVISORY COMMITTEE**

**CHAPTER 4 - VENTILATION AIR SUPPLY**

Adopt specific sections of Chapter 4 of the 2021 UMC and carry forward existing amendments of the 2019 CMC for OSHPD 1, 1R, 2, 3, 4 and 5 with modifications listed below

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHDP 01-21-4-2	<b>407.5.1.3</b>	<b>Approve</b>	<b>Accept</b>	<p><b>Approve:</b> Christopher Hanzel and Austin M. Barolin representing Mazzetti</p> <p><b>Approve as Amended:</b> Brian D. Hans, representing Mazzetti, Criteria #1</p>	<p>Bring forward existing amendment and modify to specify that a VAV device is required in spaces with pressure requirements.</p> <p>See FSOR for agency response.</p>	