

**From:** [DGS Website@DGS](mailto:DGS.Website@DGS)  
**To:** [CBSC@DGS](mailto:CBSC@DGS)  
**Subject:** PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Jeff Foster  
**Date:** Monday, January 3, 2022 3:49:46 PM

---

Commenter Contact Information

Name: Jeff Foster  
Date: 1/3/2022 12:00:00 AM  
Representing: JWF Consulting, LLC  
Mailing Address  
Number and Street: 10476 Twin Oaks Drive  
City: COBB, CA  
State: United States  
Zip Code: 95426  
Telephone #: 8056109087  
Email: jwf1660@gmail.com

Proposed Building Standard

Title 24 Part #: Part 2  
Section #: 11B-206.4.1  
Proposing State Agency: DSA-AC  
This comment is intended for review during: Commission Meeting

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):  
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The edited text of section 11B-206.4.1 becomes redundant to 11B-206.4; the revised language provides no additional criteria for access to building or facility entrances. I recommend removing 11B-206.4.1 entirely.

9 Point Criteria Info:  
18930(a) 1