

**COMMISSION ACTION MATRIX – YELLOW**

**2022 CALIFORNIA BUILDING CODE, TITLE 24, PART 2 VOLUME 2, 2021 INTERNATIONAL BUILDING CODE  
 AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT (OSHPD 06/21)**

**LEGEND:**

**CAC Actions:** Approve, Disapprove, Approve as Amended, Further Study Required

**Agency Responses:** Accept, Disagree, Withdraw

**CBSC Actions:** Approve, Disapprove, Approve as Amended, Further Study Required

**Matrix Paper Color (for commission action only):** GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

**STRUCTURAL DESIGN/LATERAL FORCES (SDLF) CODE ADVISORY COMMITTEE – JULY 28 & 29, 2021**

**CHAPTER 21 MASONRY**

Adopt 2021 International Building Code (IBC) Chapter 21 for OSHPD 1R, 2, 4 and 5, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 15	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-15-8	<b>2105.2 Compressive Strength</b>	<b>Approve</b>	<b>Accept</b>	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Approve as Amended, Criteria #5	Amend this section to update and revise references to TMS 602 Article 1.4 B.3. Comment from Masonry Institute of America and Concrete Masonry Assoc of California and Nevada (MIA, CMA-CA-NEV). Maintain 2,000 psi minimum design threshold when prism testing is required.	
OSHPD 06/21-15-10	<b>2105.4 Masonry core testing.</b>	<b>Approve</b>	<b>Accept</b>	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Disapprove, Criteria #5	Amend Exception 1 in this section to revise design values. Comment Maintain 2,000 psi minimum design threshold when core testing is required. Item regarding the exception is withdrawn post 45-Day at 15-Day. Amendment to include OSHPD 2B in subsection banner remains.	

**CHAPTER 21A MASONRY**

Adopt 2021 International Building Code (IBC) Chapter 21A for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-16-9	<b>2105A.2 Compressive Strength . . .</b>	<b>Approve</b>	<b>Accept</b>	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Approve as Amended, Criteria #5  15-Day comment: G. Acero & C. Briceno SEAOSC Seismology Committee Approve as Amended, Criteria #1	Amend this section to update and revise references to TMS 602 Article 1.4 B.3.  Comment from Masonry Institute of America and Concrete Masonry Assoc of California and Nevada (MIA, CMA-CA-NEV). Maintain 2,000 psi minimum design threshold when prism testing is required.  SEAOSC comment regarding applicability of Seismic Design Categories D, E or F.	