

From: [Eric McSwain](#)
To: [CBSC@DGS](#)
Cc: [Clair, Ida@DGS](#)
Subject: RE: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Eric McSwain
Date: Thursday, May 25, 2023 5:04:43 PM
Attachments: [image001.png](#)

CAUTION: This email originated from a NON-State email address. Do not click links or open attachments unless you are certain of the sender's authenticity.

To whom it may concern,
I would like to submit the following comments regarding proposed changes to CBC Section 11B-605.4.

Proposed Building Standard
Title 24 Part #: Part 2
Section #: (ET Item 15) 11B-605
Proposing State Agency: DSA-AC
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve as Amended

9 Point Criteria Info:
18930(A) 6

I have a couple concerns regarding 11B-605.4. The proposed 15-Day language is as follows:



1. Regarding "Urinals provided in urinal compartments and with hand operated flush controls shall have the controls located on the open side of the urinal.", "and with" results in an awkward/less than ideal statement.
2. More importantly, not every urinal compartment is required to be (wheelchair) accessible, but the flush control location language does not reflect this.

Please consider changing the last part of 11B-605.4 to say:

Where hand operated urinal flush controls are provided in urinal compartments required to comply with 11B-605.5, they shall be located on the open side of the urinal.

Thank you,
Eric

Eric McSwain, RA, CASp
ACCESS COMPLIANCE CONSULTANTS, INC.
811 El Capitan Way, Suite 230, SLO, CA 93401
c: (805) 550-5997 p: (805) 541-2745