

From: [DGS Website@DGS](mailto:DGS_Website@DGS)
To: CBSC@DGS; bryce.tanner@arup.com
Subject: PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Bryce Tanner
Date: Monday, May 15, 2023 7:30:44 PM

Commenter Contact Information

Name: Bryce Tanner
Date: 5/15/2023 12:00:00 AM
Representing: Arup
Mailing Address
Number and Street: 635 San Gabriel Ave
City: Albany
State: CA
Zip Code: 94706
Telephone #: 4158239626
Email: bryce.tanner@arup.com

Proposed Building Standard

Title 24 Part #: Part 11
Section #: 5, 5.409.3.1
Proposing State Agency: BSC-CG
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The exception equation does not appear correct. I believe the intent is to represent a summation of products, e.g. the summation of the product ($GWP_n * v_n$) for each mix n. Instead what's written is that GWP_n is summed for all n and then multiplied by v_n . Recommend to place the summation symbol outside the parenthesis.

9 Point Criteria Info:
18930(a) 6