

**From:** [DGS Website@DGS](mailto:DGS_Website@DGS)  
**To:** [CBSC@DGS](mailto:CBSC@DGS); [bryce.tanner@arup.com](mailto:bryce.tanner@arup.com)  
**Subject:** PUBLIC COMMENT on PROPOSED BUILDING STANDARDS - Bryce Tanner  
**Date:** Monday, May 15, 2023 7:34:05 PM

---

Commenter Contact Information

Name: Bryce Tanner  
Date: 5/15/2023 12:00:00 AM  
Representing: Arup  
Mailing Address  
Number and Street: 635 San Gabriel Ave  
City: Albany  
State: CA  
Zip Code: 94706  
Telephone #: 4158239626  
Email: [bryce.tanner@arup.com](mailto:bryce.tanner@arup.com)

Proposed Building Standard

Title 24 Part #: Part 11  
Section #: 5, 5.409.3.2  
Proposing State Agency: BSC-CG  
This comment is intended for review during: 45-Day Comment Period

Your recommendation based on the criteria of Health and Safety Code Section 18930(a):  
Approve as Amended

In support of your recommendation above, provide the rationale based on the criteria of Health and Safety Code Section 18930(a). If you recommend anything other than approve, cite the criteria in your comment. If you oppose a proposed building standard, offer a solution or alternative for the state agency to consider.

The table refers only to ready-mixed concrete, which would not include precast concrete, shotcrete or CMU. Suggest that all concrete forms should be included, at least by the 2025 edition.

9 Point Criteria Info:  
18930(a) 6