

COMMISSION ACTION MATRIX – GREEN
BUILDING, FIRE AND OTHER – STRUCTURAL DESIGN/LATERAL FORCES AD-HOC (BFO/SDLF) CODE ADVISORY COMMITTEE

2025 CALIFORNIA BUILDING CODE, TITLE 24, PART 2

AGENCY: DIVISION OF THE STATE ARCHITECT – STRUCTURAL SAFETY, DSA-SS 02/25

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

If using assistive technology, please adjust your settings to recognize underline, strikeout, italic and ellipsis.

- Model Code language appears upright
- Existing California amendments appear in *italic*
- Amended model code or new California amendments appear *underlined & italic*
- Repealed model code language appears ~~upright and in strikeout~~
- Repealed California amendments appear in ~~*italic and strikeout*~~
- Ellipses (...) indicate existing text remains unchanged

ITEM 1

CHAPTER 1 ADMINISTRATION

Amend sections listed below.

DSA-SS 02/25 ITEM 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
1-1	106.1.2 Snow load posting. [DSA-SS, DSA-SS/CC]	Approve	Accept	No public comments received.	Amend to clarify the snow load posting requirements.	

ITEM 2

CHAPTER 16 STRUCTURAL DESIGN

Amend sections listed below.

DSA-SS 02/25 ITEM 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
2-1	1617.12.12 ASCE 7, Section 13.1.4.	Approve	Accept	No public comments received.	Amend exemption #2 to clarify requirements for distribution system and exemptions #2 and #3 to clarify requirements for attachment details.	

ITEM 3
CHAPTER 16A STRUCTURAL DESIGN

Amend sections listed below.

DSA-SS 02/25 ITEM 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
3-1	1603A.1.5 Earthquake design data.	Approve	Accept	No public comments received.	Amend adding requirements to the information related to seismic loads required by this section to be shown on construction documents. Coordinated with OSHPD.	
3-2	1603A.1.6 Geotechnical information.	Approve	Accept	No public comments received.	Amend adding requirements to the information related to seismic loads required by this section to be shown on construction documents. Coordinated with OSHPD.	
3-3	1617A.1.18 ASCE 7, Section 13.1.4.	Approve	Accept	No public comments received.	Amend exemption #2 to clarify requirements for distribution system and exemptions #2 and #3 to clarify requirements for attachment details.	

ITEM 4
CHAPTER 17A SPECIAL INSPECTIONS AND TESTS

Amend sections listed below.

DSA-SS 02/25 ITEM 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
4-1	1705A.5.5 Structural glued laminated and cross-laminated timber.	Approve	Accept	No public comments received.	Amend exception to remove language about sourcing requirements. Coordinated with OSHPD.	

ITEM 5
CHAPTER 21 MASONRY

Amend sections listed below.

DSA-SS 02/25 ITEM 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
5-1	2115.3.2.2 TMS 602, Article 3.4B Reinforcement.	Approve	Accept	No public comments received.	Repeal a portion of the language modifying TMS 602, Article 3.4B Reinforcement.	
5-2	2115.3.2.5 TMS 602, Article 3.5 F.1 Grout Key.	Approve	Accept	No public comments received.	Repeal a portion of the language modifying TMS 602, Article 3.5 F.1 Grout Key.	
5-3	2115.5.3 TMS 402, Sections 7.4.4.1 and 7.4.5.1.	Approve	Accept	No public comments received.	Repeal a portion of the language modifying TMS 402, Section 7.4.4.1 Minimum reinforcement requirements for masonry walls.	

ITEM 6
CHAPTER 21A MASONRY

Amend sections listed below.

DSA-SS 02/25 ITEM 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
6-1	<i>2104A.1.3.5 [DSA-SS] TMS 602, Article 3.5 C Grout pour height.</i>	Approve	Accept	No public comments received.	Repeal a portion of the language modifying TMS 602, Article 3.5 C Grout pour height.	

ITEM 7
CHAPTER 22 STEEL

Repeal sections listed below.

DSA-SS 02/25 ITEM 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
7-1	<i>2215.2.2 Section D2.</i>	Approve	Accept	No public comments received.	Repeal Section 2215.2.2 which modifies AISC 341 Section D2.6c(b)(2).	

ITEM 8
CHAPTER 22A STEEL

Repeal sections listed below.

DSA-SS 02/25 ITEM 8	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
8-1	<i>2202A.5.2 Section D2.</i>	Approve	Accept	No public comments received.	Repeal Section 2202A.5.2 which modifies AISC 341 Section D2.6c(b)(2).	

ITEM 9
CHAPTER 35 REFERENCED STANDARDS

Amend referenced standards listed below.

DSA-SS 02/25 ITEM 9	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
9-1	<i>ACI 318—19 (22): [DSA-SS, DSA-SS/CC] Building Code Requirements for Structural Concrete</i>	Approve	Accept	No public comments received.	Amend to adopt reapproved version of the ACI 318-19 standard. Coordinated with OSHPD.	

DSA-SS 02/25 ITEM 9	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
9-2	ASCE 41—17: [DSA-SS, DSA-SS/CC] Seismic Evaluation and Retrofit of Existing Buildings	Approve	Accept	No public comments received.	Repeal the ASCE/SEI 41—17 standard.	