

COMMISSION ACTION MATRIX – GREEN

GREEN BUILDING – PLUMBING, ELECTRICAL, MECHANICAL & ENERGY AD-HOC (GREEN/PEME) CODE ADVISORY COMMITTEE

2025 CALIFORNIA ELECTRICAL CODE, TITLE 24, PART 3

AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT, OSHPD 04/25

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

If using assistive technology, please adjust your settings to recognize underline, strikeout, italic and ellipsis.

- Model Code language appears upright
- Existing California amendments appear in *italic*
- Amended model code or new California amendments appear *underlined & italic*
- Repealed model code language appears ~~upright and in strikeout~~
- Repealed California amendments appear in ~~*italic and strikeout*~~
- Ellipses (...) indicate existing text remains unchanged

ITEM 1

CHAPTER 5 SPECIAL OCCUPANCIES, ARTICLE 517 HEALTH CARE FACILITIES, SECTION 517.31 REQUIREMENTS FOR THE ESSENTIAL ELECTRICAL SYSTEM

Amend sections listed below.

OSHPD 04/25 ITEM 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
1-1	517.31(B)(3) Bypass Isolation	Approve	Accept	No public comments received	Add new exception for fire pumps to not require bypass isolation automatic transfer switches.	

ITEM 2

CHAPTER 5, ARTICLE 517, SECTION 517.34 CRITICAL BRANCH

Amend sections listed below.

OSHPD 04/25 ITEM 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
2-1	517.34(A) Task Illumination, Fixed Equipment, and Select Receptacles	Approve	Accept	No public comments received	Amend (b) by deleting “where direct wired” and replacing with “where an internal battery is not provided”.	

ITEM 3**CHAPTER 5, ARTICLE 517, SECTION 517.35 EQUIPMENT BRANCH CONNECTION TO ALTERNATE POWER SOURCE**

Amend sections listed below.

OSHPD 04/25 ITEM 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
3-1	517.35(B) Equipment for Delayed Automatic or Manual Connection	Approve	Accept	No public comments received	Amend (5) by deleting "Automatically operated door." and replacing with "[OSHPD 1, 2, 3, 4 & 5] Reserved"	

ITEM 4**CHAPTER 5, ARTICLE 517, SECTION 517.44 CONNECTION TO EQUIPMENT BRANCH**

Amend sections listed below.

OSHPD 04/25 ITEM 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
4-1	517.44(A) Delayed Automatic Connections to Equipment Branch. (6) <i>Exception # 1</i>	Approve	Accept	No public comments received	Amend (6) Exception # 1 to remove OSHPD 1 from the banner.	
4-2	517.44(A) Delayed Automatic Connections to Equipment Branch. (6) <i>Exception # 2</i>	Approve	Accept	No public comments received	Amend (6) Exception # 2 to include OSHPD 5 in the banner.	
4-3	517.44(A) Delayed Automatic Connections to Equipment Branch. (7), (8) and (10)	Approve	Accept	No public comments received	Amend (7), (8) and (10) to remove OSHPD 1 from the banner.	
4-4	517.44(A) Delayed Automatic Connections to Equipment Branch. (9)	Approve	Accept	No public comments received	Amend (9) to remove OSHPD 1 from the banner and delete "where direct wired" and replace with "where an internal battery is not provided."	
4-5	517.44(A) Delayed Automatic Connections to Equipment Branch. <u>(11)</u>	Approve	Accept	No public comments received	Add new item (11) for OSHPD 2, 4 & 5 allowing alarm systems for negative and positive pressure isolation rooms to be connected to the Delayed Automatic Connections Equipment Branch.	
4-6	517.44(A) Delayed Automatic Connections to Equipment Branch. <u>(12)</u>	Approve	Accept	No public comments received	Add new item (12) for OSHPD 2, 4 & 5 allowing medication dispensing units to be connected to the Delayed Automatic Connections Equipment Branch.	
4-7	517.44(A) Delayed Automatic Connections to Equipment Branch. <u>(13)</u>	Approve	Accept	No public comments received	Add new item (13) for OSHPD 2, 4 & 5 allowing medication refrigerators and freezers to be connected to the Delayed Automatic Connections Equipment Branch.	

ITEM 5
CHAPTER 5, ARTICLE 517, SECTION 517.124
 Amend sections listed below.

OSHPD 04/25 ITEM 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
5-1	517.124 [OSHPD 1, <u>2</u>, 4 & 5] Technology and Telecommunications Rooms	Approve	Accept	No public comments received	Amend banner to include OSHPD 2 and add additional California Building Code section reference.	