

COMMISSION ACTION MATRIX – SALMON

GREEN BUILDING – PLUMBING, ELECTRICAL, MECHANICAL & ENERGY AD-HOC (GREEN/PEME) CODE ADVISORY COMMITTEE

2025 CALIFORNIA ELECTRICAL CODE, TITLE 24, PART 3

AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT, OSHPD 04/25

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

If using assistive technology, please adjust your settings to recognize underline, strikeout, italic and ellipsis.

- Model Code language appears upright
- Existing California amendments appear in *italic*
- Amended model code or new California amendments appear *underlined & italic*
- Repealed model code language appears ~~upright and in strikeout~~
- Repealed California amendments appear in ~~*italic and strikeout*~~
- Ellipses (...) indicate existing text remains unchanged

ITEM 6

CHAPTER 6 SPECIAL EQUIPMENT, ARTICLE 695 FIRE PUMPS

Amend sections listed below.

OSHPD 04/25 ITEM 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
6-1	695.3 Power Source(s) for Electric Motor-Driven Fire Pumps	Approve	Accept	No public comments received	Amend banner to delete OSHPD “1R” and to include “surgical clinics only” for OSHPD 3. Include “Essential Electrical System” before the acronym EES. Delete “generator” and replace with “power source”. Post 45-Day: Withdrawn by OSHPD	
6-2	695.3(G) Power Source Selection	Approve	Accept	No public comments received	Repeal the requirement to comply with 517.31(B)(3) for fire pump automatic transfer switches (ATS). Post 45-Day: Withdrawn by OSHPD	