

Kevin:

I apologize for my delay in getting comments to you.

My primary comment remains Section 1502.3. I do not believe that DDW or many recycled water retailers would like to have the ability to interconnect potable water with recycled water without an air gapped connection between the two. I would recommend modifying this section as follows:

1502.3 Connections to Potable and Reclaimed (Recycled) Recycled reclaimed (recycled) recycled Water Systems. Gray water systems shall have no *unprotected* connection to a potable water supply, on-site treated nonpotable water supply, or reclaimed (recycled) water systems. Potable, on-site treated nonpotable, water, or rainwater is permitted to be used as makeup water for a non-pressurized storage tank provided the connection is protected by an airgap, ~~reduced pressure principle backflow preventer, or other physical device which prevents backflow in accordance with this code.~~

Thank you,
Curtis Lam
HydroScience