

**CALIFORNIA BUILDING STANDARDS COMMISSION
2016 INTERVENING CYCLE
GREEN BUILDING FOCUS GROUP
WORKSHOP #2
November 18, 2016 - Agenda Item 4g**

**DRAFT EXPRESS TERMS for the 2016
CALIFORNIA GREEN BUILDING STANDARDS CODE,
(CALGreen), PART 11,
CALIFORNIA BUILDING STANDARDS CODE,
TITLE 24, CALIFORNIA CODE OF REGULATIONS**

Proposed code language for the 2016 Intervening Code Adoption Cycle

<p>LEGEND FOR EXPRESS TERMS</p> <ol style="list-style-type: none">1. New California amendments: All such language appears <u>underlined</u>.2. Repealed text: All such language appears in strikeout. <i>[Information for the reader is bracketed and in red italics]</i>

**Cx REFERENCED STANDARDS
CHAPTER 6
REFERENCED ORGANIZATIONS AND STANDARDS**

Statement of specific purpose, problem, rationale and benefits:

- CBSC is proposing to reprint the Appendix Reference Standards from the 2010 *CALGreen* Code July 1, 2012 Supplement with additional edits to address the Commissioning requirements for non-energy related systems as shown on 5.410.1 Commissioning. This proposed code change will give guidance to the local jurisdictions for enforcing commissioning requirements for those non-energy systems which are not regulated by other state agencies.

Commissioning Referenced Standards for Non-Energy Systems

**CHAPTER 6
Cx REFERENCED STANDARDS**

The following *CALGreen* Referenced Standards are included herein as a convenience for the users of the California Green Building Standards Code, but they are not considered to be part of the code unless they are officially adopted by a local jurisdiction.

Contents

	<u>Page</u>
Part 1: Standards for Compliance with Building Commissioning.....	X
Part 2: Commissioning Sample Forms and Templates.....	X

Part 1

STANDARDS for COMPLIANCE with BUILDING COMMISSIONING

Reference: Section 5.410.2 Commissioning.

Introduction:

The purpose of this code is to improve public health, safety and general welfare by enhancing the design and construction of buildings through the use of concepts that reduce negative and increase positive environmental impacts. Commissioning is a vital element in this effort.

Definitions used in the CALGreen CX Reference standard:

Acronyms

<u>BOD</u>	<u>Basis of Design</u>
<u>Cx</u>	<u>Commissioning</u>
<u>FPT</u>	<u>Functional Performance Test</u>
<u>HVAC</u>	<u>Heating Ventilating and Air-Conditioning</u>
<u>O&M</u>	<u>Operations and Maintenance</u>
<u>OPR</u>	<u>Owner's Project Requirements</u>

Glossary

Acceptance Criteria - The conditions that must be met for systems or equipment to meet defined expected outcomes.

Commissioning (Cx) - Building commissioning as required in this code involves a quality assurance process that begins during design and continues to occupancy. Commissioning verifies that the new building operates as the owner intended and that building staff are prepared to operate and maintain its systems and equipment. Exceptions are allowed for dry storage warehouses of any size and conditioned spaces under 10,000 square accessory to them; and for tenant improvements under 10,000 within a larger space.

Owner - The individual or entity holding title to the property on which the building is constructed.

Commissioning Coordinator - The person who coordinates the commissioning process. This can be either a third-party commissioning provider or an experienced member of the design team or owner in-house staff member.

Commissioning Team - The key members of each party involved with the project designated to provide insight and carry out tasks necessary for a successful commissioning project. Team members may include the commissioning coordinator, owner or owner's representative, building staff, design professionals, contractors or manufacturer's representatives, and testing specialists.

Independent Third-Party Commissioning Professional - A commissioning consultant contracted directly by the owner who is not responsible to, or affiliated with any other member of the design and construction team.

Operation and Maintenance (O&M) Manuals - Documents that provide information necessary for operating and maintaining installed equipment and systems.

Owner Representative - An individual or entity assigned by the owner to act and sign on the owner's behalf.

Process Equipment - Energy-using equipment and components that are not used for HVAC, Electrical, Plumbing and Irrigation operations.

Such devices would include but are not limited to heat transfer, water purifying, air cleaning, air vacuum and air compressing.

Sequence of Operation – A written description of the intended performance and operation of each control element and feature of the equipment and systems.

Selecting Trained Personnel for (Commissioning)

This code requires that “Commissioning shall be performed in accordance with this section by trained personnel with experience on projects of comparable size and complexity.” The trained personnel manage and facilitate the commissioning process. The trained personnel develop and implement the commissioning tasks and documentation identified in sections 5.410.2.1 through 5.410.2.7. Trained personnel may include appropriate members of owner staff, contractor and design team as well as independent commissioning professionals.

It is essential that there is a single person designated to lead and manage the commissioning activities. In practice, this individual has been referenced by various identifiers such as commissioning authority, agent, provider, coordinator, lead, etc. In this guide the term “commissioning coordinator” is used.

The designated commissioning coordinator may be an independent third-party commissioning professional, a project design team member (e.g. engineer or architect), an owner’s engineer or facility staff, contractor or specialty sub-contractor. Methods of evaluating the designated commissioning coordinator and trained personnel include review of the following:

1. Technical knowledge
2. Relevant experience
3. Potential conflict of interest concerns
4. Professional certifications and training
5. Communication and organizational skills
6. Reference and sample work products

Selection of “trained”, qualified personnel is required by this Code. In order to meet this requirement, the commissioning provider should be evaluated via the methods discussed above. In addition, various organizations have training and certification programs that may be a source for identification of qualified commissioning providers.

For information about enforcement and compliance of each commissioning element see sections 5.410.2.1 through 5.410.2.7.

For compliance forms and templates see Part 2 following the standard

Reference: Owner’s Project Requirements

CALGreen Section: 5.410.2.1 Owner’s or Owner representative’s Project Requirements (OPR).

1.1 Intent:

The Owner’s Project Requirements (OPR) documents the functional requirements of a project and expectations of the building use and operation as it relates to systems being commissioned. The document describes the physical and functional building characteristics desired by the owner and establishes performance and acceptance criteria. The OPR is most effective when developed during pre-design and used to develop the Basis of Design (BOD) during the design process. The level of detail and complexity of the OPR will vary according to building use, type and systems.

1.2 Compliance Method:

Compliance is demonstrated by the owner or owner’s representative developing and/or

approving the Owner's Project Requirements (OPR) document and can be defined as follows:

1. Environmental and Sustainability Goals – Establish environmental project goals and objectives exceeding the code for the project's sustainability which may include:
 - a) CALGreen voluntary measures or Tiers sought, or other specific green building rating system or program credits and/or level of certification sought
 - b) Specific environmental or sustainability goals such as water efficiency, water reuse, CO2 monitoring, xeriscaping, etc.
2. Building sustainable Goals –Establish goals and targets affecting energy efficiency which may include:
 - a) Measures affecting building sustainability desired by owner
 - Building orientation and siting
 - Daylighting
 - Facade, envelope and fenestration
 - Roof
 - Natural ventilation
 - Onsite renewable power generation and net-zero energy use
 - Landscaping and shading
3. Indoor Environmental Quality Requirements - For each program space describe indoor environmental requirements including intended use and anticipated schedule
 - a) Temperature and humidity
 - b) Acoustics
 - c) Air quality, ventilation and filtration
 - d) Desired adjustability of system controls
 - e) Accommodations for after-hours use
 - f) Other owner requirements including natural ventilation, operable windows, daylight, views, etc.
4. Project Program, Including facility functions and hours of operation, and need for after hours operation – Describe primary purpose, program and use of proposed project
 - a) Building size, number of stories, construction type, occupancy type and number
 - b) Building program areas including intended use and anticipated occupancy schedules
 - c) Future expandability and flexibility of spaces
 - d) Quality and/or durability of materials and building lifespan desired
 - e) Budget or operational constraints
 - f) Applicable codes
5. Equipment and Systems Expectations – Describe the following for each system commissioned:
 - a) Level of quality, reliability, equipment type, automation, flexibility, maintenance and complexity desired
 - b) Specific efficiency targets, desired technologies, or preferred manufacturers for building systems, acoustics and vibration
 - c) Degree of system integration, automation and functionality for controls; i.e.xxx
6. Building Occupant and O&M Personnel Expectations – Describe the following:
 - a) How building will be operated and by whom
 - b) Level of training and orientation required to understand, operate and use the building systems for building operation and maintenance staff, as well as occupants
 - c) Building operation and maintenance staff location and capabilities

1.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance at Plan Intake by:

- a) Receipt of a copy of the OPR document, or
- b) Receipt of a form signed by the owner or owner representative attesting that the OPR has been completed and approved by the owner.

Reference: 2 Basis of Design (BOD)

CALGreen Section: 5.410.2.2 Basis of Design (BOD).

2.1 Intent:

The Basis of Design (BOD) describes the building systems to be commissioned and outlines design assumptions not indicated in the design documents. The design team develops the BOD to describe how the building systems design meets the Owner's Project Requirements (OPR), and why the systems were selected. The BOD is most effective when developed early in the project design and updated as necessary throughout the design process.

2.2 Compliance Method:

Compliance requires the completion of the BOD document and should include the following where applicable:

1. Renewable Energy Systems
 - a) Provide narrative description of system – type, performance, control type, energy savings, payback period
 - b) Describe reason for system selection – why chosen system is better than alternatives, issues such as performance, efficiency, reliability, flexibility, simplicity, expandability, cost, payback period, utility company incentives, owner preference.
 - c) Sequence of Operation – operating schedules, setpoints, storage capacity
 - d) Describe how system meets the OPR
2. Landscape Irrigation Systems
 - a) Provide narrative description of system – type, performance, water usage
 - b) Describe reason for system selection – why chosen system is better than alternatives, issues such as performance, efficiency, reliability, flexibility, expandability, cost, owner preference, simplicity
 - c) Sequence of Operation – operating schedules, setpoints
 - d) Describe how system meets the OPR
3. Water Reuse Systems
 - a) Provide narrative description of system – type, performance, capacity, reuse purpose
 - b) Describe reason for system selection – why chosen system is better than alternatives, issues such as performance, efficiency, reliability, flexibility, expandability, cost, owner preference, simplicity
 - c) Sequence of Operation – operating schedules, setpoints
 - d) Describe how system meets the OPR

2.3 Enforcement:

At their discretion, the building official confirms demonstrated compliance at Plan Intake by:

- a) Receipt of a copy of the BOD document, or
- b) Receipt of a form signed by the architect, engineer or designer of record, attesting that the BOD has been completed and meets the requirements of the OPR.

Reference: 3 Commissioning measures shown in the construction documents

CALGreen Section: 5.410.2 Commissioning.

This section provides details for element 3: Commissioning measures shown in the construction documents.

3.1 Intent:

Include commissioning measures or requirements in the construction documents (plans and specifications). Commissioning measures or requirements should be clear, detailed and complete to clarify the commissioning process.

3.2 Compliance Method:

Compliance is achieved by including commissioning requirements in the project specifications. The commissioning specifications should include the following:

1. Primary (and optionally all) commissioning requirements are included in the general specification division (typically Division 1) and clear cross references of all commissioning requirements to and from the general division are included to ensure all subcontractors are held to them
2. A list of the systems and assemblies covered by the commissioning requirements.
3. Roles and responsibilities of all parties including:
 - General contractor and subcontractors, vendors, construction manager
 - Commissioning provider lead
 - Owner, facility staff
 - Architect and design engineers
 - Including the non-contractor parties in the construction specifications is for information only to provide the contractor with context for their work
 - Include who writes checklists and tests, who reviews and approves test forms, who directs tests, who executes tests, who documents test results and who approves completed tests. These roles may vary by system or assembly.
4. Meeting requirements
5. Commissioning schedule management procedures
6. Issue and non-compliance management procedures
7. Requirements for execution and documentation of installation, checkout and start up, including controls point-to-point checks and calibrations
8. Specific testing requirements by system, including:
 - Monitoring and trending
 - Opposite season or deferred testing requirements, functions and modes to be tested
 - Conditions of test
 - Acceptance criteria, and any allowed sampling
 - Include details of the format and rigor of the test forms required to document test execution
 - Including example forms is recommended
9. Submittal review requirements and approval process.
10. Content, authority and approval process of the commissioning plan.
11. Commissioning documentation and reporting requirements.
12. Facility staff training requirements and verification procedures.
13. O&M manual review and approval procedures.
14. System's manual development and approval requirements and procedures.
15. Definitions section.

3.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance at Plan Intake by:

- a) Receipt of a copy of the commissioning specifications, or
- b) Receipt of a form signed by the owner or owner representative or designer of record attesting that the owner-approved commissioning specifications are included in the construction documents.

Reference: 4 Commissioning plan.

CALGreen Section: 5.410.2.3 Commissioning plan.

4.1 Intent:

The Commissioning Plan (Cx Plan) establishes the commissioning process guideline for the project and commissioning team's level of effort by identifying the required Cx activities to

November 18, 2016

ensure that the Owner's Project Requirements (OPR) and the Basis of Design (BOD) are met. The Cx Plan also includes a commissioning schedule from design to occupancy.

4.2 Compliance Method:

Compliance is demonstrated by preparation of a project specific Cx Plan that includes the elements listed in the code section above. The following gives guidance for developing the components of the Commissioning Plan:

1. General project information - Provide project identifying information including but not limited to the following:
 - Project Name, Owner, Location,
 - Building type, Building area,
 - Project Schedule
 - Contact information of individual/company providing the commissioning services
2. Commissioning Goals – Document the commissioning goals, including, but not limited to:
 - Meeting CALGreen code requirements for commissioning
 - Meeting OPR and BOD requirements
 - Carrying out requirements for commissioning activities as specified in plans and specifications
3. Systems to be commissioned – See BOD
 - a. An explanation of the original design intent - Document the performance objectives and design intent for each system listed to be commissioned in a written narrative
 - Refer to the OPR and BOD documents
 - b. Equipment and systems to be tested, including the extent of tests
 - Provide a list of equipment and systems to be tested
 - Describe the range and extent of tests to be performed for each system component, and interface between systems
 - c. Functions to be tested - Provide example functional test procedures to identify the level of testing detail required
 - See (Section 5.410.2.4) FPT guidance for more information
 - d. Conditions under which the test shall be performed - Identify the conditions under which the major operational system functions are to be tested, including:
 - Normal operations and part-load operations
 - Seasonal testing requirements
 - Restart of equipment and systems after power loss
 - System alarm confirmations
 - e. Measurable criteria for acceptable performance - Include measurable criteria for acceptable performance of each system to be tested
4. Commissioning Team Information - Provide a contact list for all Commissioning team members, including but not limited to:
 - Owner, owner's representative
 - Architect, Engineers
 - Designated commissioning representative
 - General contractor, sub-contractors, and construction manager
5. Commissioning process activities, schedules and responsibilities
 - Establish prescribed commissioning process steps and activities to be accomplished by the Cx team throughout the design to occupancy
 - For each phase of the work, define the roles and responsibilities for each member of the Cx team
 - List the required Cx deliverables, reports, forms and verifications expected at each stage of the commissioning effort
 - Include the confirmation process for the O&M manual, systems manual and the facility operator and maintenance staff training

4.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance at Plan Intake by:

- a) Receipt of a copy of the Commissioning Plan, or
- b) Receipt of a form signed by the owner or owner representative attesting that the Cx Plan has been completed.

Reference: 5 Functional performance testing

CALGreen Section: 5.410.2.4 Functional performance testing.

5.1 Intent:

Develop and implement the functional performance tests to document, as set forth in the Commissioning Plan, that all components, equipment, systems and system-to-system interfaces were installed as specified, and operate according to the Owner's Project Requirements, Basis of Design, and plans and specifications.

The following systems to be functionally tested are listed in the Basis of Design (5.410.2.2 of the Code):

1. Renewable Energy Systems
2. Landscape Irrigation Systems
3. Water Reuse Systems

5.2 Compliance Method:

Compliance is demonstrated by developing and implementing test procedures for each piece of commissioned equipment and interfaces between equipment and systems according to the building-specific Commissioning Plan. Tests should include verification of proper operation of all equipment features, each part of the sequence of operation, overrides, lockouts, safeties, alarms, occupied and unoccupied modes, loss of normal power, exercising a shutdown, startup, low load through full load (as much as is possible) and back, staging and standby functions, scheduling, energy efficiency strategies and loop tuning.

Elements of acceptable test procedures include:

1. Date and Party -- Identification of the date of the test and the party conducting the test.
2. Signature Block -- Signature of the designated commissioning lead and the equipment installing contractor attesting that the recorded test results are accurate.
3. Prerequisites -- Any conditions or related equipment checkout or testing that needs to be completed before conducting this test.
4. Precautions -- Identification of the risks involved to the test team members and the equipment and how to mitigate them.
5. Instrumentation -- Listing of the instrumentation and tools necessary to complete the test.
6. Reference -- In each procedure item, identify the source for what is being confirmed (e.g., sequence of operation ID, operating feature, specification requirement, etc.).
7. Test Instructions -- Step-by-step instructions of how to complete the test, including functions to test and the conditions under which the tests should be performed.
8. Acceptance Criteria -- Measurable pass / fail criteria for each step of the test, as applicable.
9. Results -- Expected system response and space to document the actual response, readings, results and adjustments.
10. Return to Normal -- Instructions that all systems and equipment are to be returned to their as-found state at the conclusion of the tests.
11. Deficiencies -- A list of deficiencies and how they were mitigated.

5.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance during Onsite Enforcement by:

- a) Receipt of a copy of completed and signed Functional Performance Tests and

corrected deficiencies, or

- b) Receipt of a form signed by the owner, owner representative or commissioning coordinator attesting that the Functional Performance Tests have been completed and any deficiencies corrected.

Reference: 6.1 Documentation and training

CALGreen Section: 5.410.2.5 Documentation and training.

Section: 5.410.2.5.1 Systems manual.

6.1.1 Intent:

The Systems Manual documents information focusing on the operation of the building systems. This document provides information needed to understand, operate, and maintain the equipment and systems and informs those not involved in the design and construction of the building systems. This document is in addition to the record construction drawings, documents, and the Operation & Maintenance (O&M) Manuals supplied by the contractor. The Systems Manual is assembled during the construction phase and available during the contractors' training of the facility staff.

A6.1.6.1.2 Compliance Method:

Compliance is demonstrated by providing the Systems Manual. The information in the Systems Manual includes the following information:

1. Site information, including facility description, history and current requirements
 - a) Site Information
 - i. Location of property - Address
 - ii. Site acreage
 - iii. Local utility information
 - Water service provider
 - Natural/LPG gas service provider
 - Electrical service provider
 - Telecommunications service provider
 - Other service providers
 - b) Facility Description
 - i. Use/Function
 - ii. Square footage
 - iii. Occupancy Type
 - iv. Construction Type
 - v. Basis of design
 - vi. Location of major systems & equipment
 - c) Project History
 - i. Project requirements
 - Owner's Project Requirements (OPR)
 - Basis of Design (BOD)
 - ii. Project undocumented events
 - iii. Record Drawings & Documents
 - iv. Final control drawings and schematics
 - v. Final control sequences
 - vi. Construction documents - Location or delivery information
 - Mechanical & electrical drawings
 - Specifications
 - Submittals
 - Project change orders and information
 - d) Current requirements

- i. Building operating schedules
 - ii. Space temperature, humidity, & pressure, CO2 setpoints
 - iii. Summer and winter setback schedules
 - iv. Chilled & hot water temperatures
 - v. As-built control setpoints and parameters
 2. Site contact information
 - a) Owner information
 - b) Emergency contacts
 - c) Design Team: Architect, Mechanical, Engineer, Electrical Engineer, etc.
 - d) Prime Contractor contact information
 - e) Subcontractor information
 - f) Equipment supplier contact information
 3. Basic operation & maintenance, including general site operating procedures, basic trouble shooting, recommended maintenance requirements site events log
 - a) Basic operation
 - i. Written narratives of basic equipment operation
 - ii. Interfaces, interlocks and interaction with other equipment and systems
 - iii. Initial maintenance provide by contactor
 - b) General site operating procedures
 - i. Instructions for changes in major system operating schedules
 - ii. Instructions for changes in major system holiday & weekend schedules
 - c) Basic troubleshooting
 - i. Cite any recommended troubleshooting procedures specific to the major systems and equipment installed in the building.
 - ii. Manual operation procedures
 - iii. Standby/Backup operation procedures
 - iv. Bypass operation procedures
 - v. Major system power fail resets and restarts
 - vi. Trend log listing
 - d) Recommended maintenance events log
 - e) Operation & Maintenance Manuals - Location or delivery information
 4. Major systems
 - a) Renewable energy systems
 - i. Photovoltaic panels & inverters
 - ii. Wind powered electrical generators & inverters
 - b) Landscape irrigation systems
 - i. Water distribution diagrams
 - ii. Control system
 - c) Water reuse systems
 - i. Reclaimed water system for indoor use
 - ii. Reclaimed water for irrigation use
 5. Site equipment inventory and maintenance notes
 - a) Spare parts inventory
 - b) Frequently required parts and supplies
 - c) Special equipment required to operate or maintain systems
 - d) Special tools required to operate or maintain systems
 6. A copy of all special inspection verifications required by the enforcing agency of this code
 7. Other resources and documentation

6.1.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance during Onsite Enforcement by:

- a. Receipt of a copy of the Systems Manual, or
- b. Receipt of a form signed by the owner or owner representative attesting that the System's Manual has been completed.

Reference: 6.2 Documentation and training

CALGreen Section: 5.410.2.5 Documentation and training.

Section: 5.410.2.5.2 Systems operations training.

6.2.1 Intent:

The systems operation training verifies that a training program is developed to provide training to the appropriate maintenance staff for each equipment type and/or system and that this training program is documented in the commissioning report. The systems operations training program is specified in the project specifications for the major systems listed. The System Manual, Operation and Maintenance (O&M) documentation, and record drawings are prepared and available to the maintenance staff prior to implementation of any training or the development of a written training program. The training program is to be administered when the appropriate maintenance staff is made available to receive training.

A6.1.6.2.2 Compliance Method:

The written training program includes: (a) learning goals and objectives for each session, (b) training agenda, topics, and length of instruction for each session, (c) instructor information and qualifications, (d) location of training sessions (onsite, off-site, manufacturer's or vendor's facility), (e) attendance forms, (f) training materials, and (g) description on how the training will be archived for future use.

1. Systems/equipment overview
 - a) Review OPR and BOD related to the major systems and equipment
 - b) Describe system type and configuration
 - c) Explain operation all major systems and equipment and how it interfaces with other systems and equipment
 - d) Describe operation of critical devices, controls and accessories
 - e) Review location of the major systems and equipment
 - f) Describe operation of control system for each system, location of critical control elements, and procedures to properly operate control system
 - g) Review recommendations for implementation to reduce energy and water use
2. Review and demonstration of servicing/preventive maintenance
 - a) Explain location or delivery contact of the Operation & Maintenance manuals
 - b) Review of all manufacturer's recommended maintenance activities to maintain warranty
 - c) Review and demonstrate frequent maintenance activities and suggested schedule.
 - d) Review and demonstrate typical servicing procedures and techniques (electrical current, pressure, and flow readings, etc; calibration procedures, point trending, power fail restart procedures, etc.)
 - e) Locate, observe and identify major equipment, systems, accessories and controls
 - f) Review emergency shut-offs and procedures
3. Review of the information in the Systems Manual
 - a) Describe use of System Manual
 - b) Review elements of System Manual
 - c) Explain how to update and add revisions to System Manual
4. Review record drawings on the systems/equipment
 - a) Explain location or delivery contact of the record drawings
 - b) Review record drawings, revisions, and changes to original design drawings.
 - c) Review equipment schedules and compare with actual installed systems

6.2.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance during Onsite Enforcement by:

1. In the event appropriate maintenance staff is made available to receive training for each equipment type and/or system installed in the building.
 - a. Receipt of a copy of the written training program and completed attendance forms, or
 - b. Receipt of a form signed by the owner or owner representative attesting that the training program and delivery of training has been completed
2. In the event appropriate maintenance staff are unavailable to receive training for each equipment type and/or system installed in the building.
 - a. Receipt of a copy of the training program provided to the owner or owner's representative, or
 - b. Receipt of a form signed by the owner or owner representative attesting that the written training program has been provided.

Reference: 7 Commissioning report
CALGreen Section: 5.410.2.6 Commissioning report.

7.1 Intent:

The Commissioning Report documents the commissioning process and test results. The report includes confirmation from the commissioning agent verifying that commissioned systems meet the conditions of the Owner's Project Requirements (OPR), Basis of Design (BOD), and Contract Documents.

7.2 Compliance Method:

The Components of the Commissioning Report include the following and are defined as follows:

1. Executive summary of process and results of commissioning program – including observations, conclusions and any outstanding items.
2. History of any system deficiencies and how resolved
 - a) Include outstanding deficiencies and plans for resolution
 - b) Include plans for seasonal testing scheduled for a later date
3. System performance test results and evaluations
4. Summary of training process completed and scheduled
5. Attach commissioning process documents
 - a) Commissioning Plan
 - b) Owners Project Requirements (OPR)
 - c) Basis of Design (BOD)
 - d) Executed installation checklists
 - e) Executed Functional Performance Test (FPT) forms
 - f) Recommendations for end-of-warranty review activities

7.3 Enforcement:

At their discretion, the inspector confirms demonstrated compliance during Onsite Enforcement by:

- a) Receipt of a copy of the Commissioning Report, or
- b) Receipt of a form signed by the owner or owner representative attesting that the Cx Report has been completed.

Part 2 SAMPLE FORMS and TEMPLATES for COMMISSIONING

Note: Following are examples of templates and/or forms that may be used or adopted for verification of compliance with commissioning. Code users may provide their own documents as permitted by the enforcing agency. For each subsection of commissioning, samples are provided; in a few cases with narrative templates, and in most cases with compliance forms. Simplified forms or more detailed forms, but not both, may be selected to submit for each project.

OWNER'S PROJECT REQUIREMENTS (OPR) COMPLIANCE TEMPLATE	
---	--

[The Owner's Project Requirements (OPR) is a step of commissioning required for compliance with the CALGREEN Code, Section 5.410.2.1, for newly constructed buildings greater than 10,000 sq. ft. This template is a guide to collecting the information recommended for the OPR. The information should be developed by the project team in collaboration with the Owner.]

Owner and User Requirements

- a) [Typically already covered in Project Scope as described in the building program. Includes primary purpose, program and use of project. May also describe future expansion needs, flexibility, quality of materials, construction and operation costs.]

Environmental and Sustainability Goals

- a) Project shall meet performance requirements required by the owner.
- b) Other Owner requirements: [e.g. Owner priorities among CALGREEN Code or other areas]

Building Sustainable Goals

- a) Measures affecting energy efficiency desired by owner (e.g. Building orientation, shading, daylighting, natural ventilation, renewable power, etc)

Indoor Environmental Quality Requirements

- a) Indoor lighting requirements: [List any specific non-standard requirements. E.g. pendant-mounted lighting, illumination requirements, special applications.]
- b) Occupant lighting control requirements: [List any non-standard requirements. E.g. multi-mode controls for assembly spaces]
- c) Thermal comfort requirements: [List any non-standard temperature or humidity requirements]
- d) Ventilation and filtration requirements: [List any non-standard requirements]
- e) Occupancy HVAC control requirements: [List any non-standard requirements. E.g. integration with existing control systems]
- f) Acoustic environment requirements: [List any non-standard requirements. E.g. local noise sources requiring mitigation, spaces such as classrooms that require low background noise and short reverberation times]

g) Other Owner requirements: [E.g. natural ventilation, operable windows, daylight, views]

Equipment and Systems Expectations

a) Other system requirements:

Building Occupant and O&M Personnel Expectations

Training required for building occupants: [e.g. demonstration, instruction documents]

Training required for operating and maintenance staff: [e.g. demonstration, classroom training, instruction documents]

Other Owner requirements:

DRAFT

OWNER'S PROJECT REQUIREMENTS (OPR) COMPLIANCE FORM	
---	--

The following form may be required to be printed on the permit set of construction drawings or submitted separately.

CALGreen Commissioning Requirement 5.410.2.1- Owner's or Owner representative's Project Requirements (OPR).

5.410.2.1 Owner's or Owner representative's Project Requirements (OPR). *[N] The expectations and requirements of the building appropriate to its phase shall be documented before the design phase of the project begins. The documentation shall include the following: (See Cx plan elements checklist below)*

The OPR includes the checked elements listed below that should be approved by the Owner or Owner's Representative.

	OPR Elements	Included
1.	Environmental and Sustainability Goals.	<input type="checkbox"/>
2.	Building Sustainable Goals.	<input type="checkbox"/>
3.	Indoor Environmental Quality Requirements.	<input type="checkbox"/>
4.	Project program, including facility functions and hours of operation, and need for after-hours operation.	<input type="checkbox"/>
5.	Equipment and Systems Expectations.	<input type="checkbox"/>
6.	Building Occupant and O&M Personnel Expectations.	<input type="checkbox"/>

Owner / Owner Representative Signature

Date

**OWNER'S PROJECT REQUIREMENTS (OPR)
COMPLIANCE CHECKLIST**

INCORPORATE THIS FORM IN THE PLANS

Project Address: _____

Permit Number: _____

ITEM #	OPR ITEMS	PAGE NUMBER IN OPR DOCUMENT
PROJECT PROGRAM		
1	General building information (size, stories, construction type, occupancy type and number)	
2	Intended uses and schedules	
3	Future expandability and flexibility of spaces	
4	Quality and/or durability of materials and desired building lifespan	
5	Budget or operation constraints	
ENVIRONMENTAL AND SUSTAINABILITY GOALS		
6	Level of compliance with the California Green Building Standards Code: Mandatory, Tier 1, or Tier 2	
7	Specific environmental or sustainability goals (e.g. water efficiency, water reuse, CO ₂ monitoring, xeriscaping, etc.)	
BUILDING SUSTAINABLE GOALS		
8	Measures affecting energy efficiency desired by owner (e.g. Building orientation, shading, daylighting, natural ventilation, renewable power, etc.)	
INDOOR ENVIRONMENTAL QUALITY REQUIREMENTS		
9	Lighting	
10	Temperature and Humidity	
11	Acoustics	
12	Air quality, ventilation, and filtration	
13	Desired adjustability of system controls	
14	Accommodations for after-hours use	
15	Other owner requirements (e.g. natural ventilation, daylight, views, etc.)	
EQUIPMENT AND SYSTEMS EXPECTATIONS		
16	Level of quality, reliability, equipment type, flexibility, maintenance, and complexity desired	
17	Specific efficiency targets, desired technologies, or preferred manufacturers for building systems, acoustics and vibration	
18	Degree of system integration, automation, and functionality for	

	controls (i.e. load shedding, demand response, energy management)	
	BUILDING OCCUPANT AND O&M PERSONNEL EXPECTATIONS	
19	Description of how the building will be operated and by whom	
20	Level of training and orientation required to understand, operate and use the building systems for building operation and maintenance staff, as well as occupants	
21	Building operation and maintenance staff location and capabilities	
	COMMISSIONING AGENT INFORMATION	
22	Name of Commissioning Agency:	
23	Address of Agency:	
24	Contact person(s) Name(s):	

Owner/Owner Representative Acknowledgement

Owner's Project Requirements (OPR). The expectations and requirements of the building appropriate to its phase shall be documented before the design phase of the project begins. The OPR includes the elements listed above and have been approved by the Owner or Owner's Representative.

Name: _____ Owner Owner's Representative

Company Name (if applicable): _____

Signature: _____ Date: _____

BASIS OF DESIGN (BOD) COMPLIANCE TEMPLATE	
--	--

Documentation of the Basis of Design (BOD) is a step required for compliance with CALGreen Code, section 5.410.2.1, for newly constructed buildings greater than 10,000 sq. ft. This template is a guide for use by the design team.

1. Renewable Energy Systems

1.1. Narrative Description of System

- A. [System type(s), location, inverter type, control type, performance, efficiency, energy savings, payback period]
- B. [Describe how system meets any special requirements listed in the Owner's Project Requirements document.]

1.2. Reasons for System Selection

[Reasons that the selected renewable energy systems are a better choice than alternatives, e.g. performance, efficiency, reliability, flexibility, simplicity, expandability, cost, payback period, utility company incentives, owner preference, space constraints, cost, owner preferences, ease of maintenance, etc.]

1.3. Renewable Energy System Generation Calculations

[Describe sizing calculation method, assumptions, and results]

2. Landscape Irrigation Systems

2.1. Narrative Description of System

- A. [System type(s), location, control type, performance, efficiency, water savings]
- B. [Describe how system meets any special requirements listed in the Owner's Project Requirements document.]

2.2. Reasons for System Selection

[Reasons that the selected landscape irrigation systems are a better choice than alternatives. E.g. performance, efficiency, reliability, flexibility, simplicity, expandability, cost, payback period, utility company incentives, owner preference, cost, owner preferences, ease of maintenance, etc.]

2.3. Landscape Irrigation System Calculations

[Describe sizing calculation method, assumptions, and results]

3. Water Reuse Systems

3.1. Narrative Description of System

- A. [System type(s), location, space requirements, equipment requirements, control type, performance, efficiency, potable water savings, payback period]
- B. [Describe how system meets any special requirements listed in the Owner's Project Requirements document.]

3.2. Reasons for System Selection

[Reasons that the selected water reuse systems are a better choice than alternatives. E.g. performance, efficiency, reliability, flexibility, simplicity, expandability, cost, payback period, utility company incentives, owner preference, space constraints, cost, owner preferences, ease of maintenance, etc.]

3.3. Water Reuse System Calculations

[Describe sizing calculation method, assumptions, and results]

**BASIS OF DESIGN (BOD)
COMPLIANCE CHECKLIST**

INCORPORATE THIS FORM IN THE PLANS

Project Address: _____

Permit Number: _____

ITEM #	BOD ITEMS	PAGE NUMBER IN BOD DOCUMENT
RENEWABLE ENERGY SYSTEMS (IF ANY)		
1	Narrative description of system (i.e. system type(s), location, inverter type, control type, performance, efficiency, energy savings, payback period, other)	
2	Description of how the system meets requirements listed in OPR	
3	Reasons for system selection, as opposed to alternatives (e.g. performance, efficiency, reliability, flexibility, simplicity, expandability, cost, payback period, etc.)	
4	Renewable energy system generation calculations: sizing calculation method, assumptions, and results	
LANDSCAPE IRRIGATION SYSTEMS		
5	Narrative description of system (i.e. system type(s), location, control type, performance, efficiency, water savings, other)	
6	Description of how the system meets requirements in OPR	
7	Reasons for system selection, as opposed to alternatives (e.g. performance, efficiency, reliability, flexibility, cost, utility company incentives, etc.)	
8	Landscape irrigation system calculations: sizing calculation method, assumptions, and results	
WATER REUSE SYSTEM (IF ANY)		
11	Narrative description of system (i.e. system type(s), location, space requirements, equipment requirements, control type, performance, efficiency, potable water savings, payback period, other)	
12	Description of how the system meets requirements in OPR	
13	Reasons for system selection, as opposed to alternatives (e.g. performance, efficiency, reliability, flexibility, simplicity, cost, payback period, etc.)	
14	Water reuse system calculations: sizing calculation method, assumptions, and results	

Architect/Engineer/Designer Acknowledgement

I hereby acknowledge the Basis of Design (BOD) document has been completed and meets the Owner's Project Requirements (OPR)

	Name	License Number	Signature	Date
Architect of Record				
Landscape Architect				

Renewable Energy System Designer				
Other (specify):				

Commissioning Agent Acknowledgment

I have reviewed the Basis of Design (BOD) and verified that it meets the Owner's Project Requirements (OPR):

Name: _____

Company Name (if applicable): _____

Agent's Signature: _____ Date: _____

DRAFT

Cx MEASURES IN CONSTRUCTION DOCUMENTS COMPLIANCE FORM	
--	--

The following form may be required to be printed on the permit set of construction drawings or submitted separately.

CALGreen Commissioning Requirement 5.410.2 Commissioning Measures in the Construction Documents

5.410.2. Commissioning measures shall be shown in the construction documents.

The commissioning measures shown in the construction documents include the checked elements listed below and have been approved by the Owner, Owner's Representative or Designer of record.

	Commissioning Measure Elements ¹	Included
1.	Measures shown in the specifications and cross referenced	<input type="checkbox"/>
2.	List of commissioned equipment and systems	<input type="checkbox"/>
3.	Cx roles and responsibilities of all parties	<input type="checkbox"/>
4.	Meeting requirements	<input type="checkbox"/>
5.	Commissioning schedule management procedures	<input type="checkbox"/>
6.	Procedures for addressing outstanding issues or non-compliance	<input type="checkbox"/>
7.	Requirements for execution and documentation of installation and equipment start up	<input type="checkbox"/>
8.	Specific testing requirements for each system type ¹	<input type="checkbox"/>
9.	Submittal review and approval requirements	<input type="checkbox"/>
10.	Contents and approval process of the commissioning plan	<input type="checkbox"/>
11.	Cx documentation and reporting requirements	<input type="checkbox"/>
12.	Facility staff training requirements and verification procedures	<input type="checkbox"/>
13.	O&M manual review and approval procedures	<input type="checkbox"/>
14.	Systems manual development and approval procedures	<input type="checkbox"/>
15.	Definitions	<input type="checkbox"/>

1. These are not the detailed step-by-step test procedures, but are lists of features, elements, modes and conditions of tests for specific equipment.

Owner / Owner Representative
or Designer of Record Signature

Date

Cx MEASURES IN CONSTRUCTION DOCUMENTS**INCORPORATE THIS FORM IN THE PLANS**

Project Address: _____

Permit Number: _____

ITEM #	Commissioning Measures Items
1	Measures shown in the specifications and cross referenced
2	List of commissioned equipment and systems
3	Cx roles and responsibilities of all parties
4	Meeting requirements
5	Commissioning schedule management procedures
6	Procedures for addressing outstanding issues or non-compliance
7	Requirements for execution and documentation of installation and equipment start up
8	Specific testing requirements for each system type
9	Submittal review and approval requirements
10	Contents and approval process of the commissioning plan
11	Cx documentation and reporting requirements
12	Facility staff training requirements and verification procedures
13	O & M manual review and approval procedures
14	Systems manual development and approval procedures
15	Definitions

Commissioning Agent Acknowledgment

I have reviewed the construction documents listed above and verified their compliance with the owner's project requirements, basis of design, and commissioning plan.

Name: _____

Company Name (if applicable): _____

Agent's signature: _____ Date: _____

COMMISSIONING PLAN COMPLIANCE FORM	
---	--

The following form may be required to be printed on the permit set of construction drawings or submitted separately.

CALGreen Commissioning Requirement 5.410.2.3 Commissioning Plan

5.410.2.3 Commissioning plan. [N] *Prior to permit issuance a commissioning plan shall be completed to document how the project will be commissioned. The commissioning plan shall include the following:*

(See Cx plan elements checklist below)

The commissioning plan should be started during the design phase of the building project, include the checked elements listed below and approved by the Owner or Owner Representative.

	Commissioning Plan Elements ¹	Included
1.	General project information	<input type="checkbox"/>
2.	Commissioning goals	<input type="checkbox"/>
4.	An explanation of original design intent	<input type="checkbox"/>
5.	Equipment and systems to be commissioned and tested, including extent of tests	<input type="checkbox"/>
6.	Functions to be tested and conditions of tests ¹	<input type="checkbox"/>
7.	Measurable performance criteria	<input type="checkbox"/>
8.	Cx team information	<input type="checkbox"/>
9.	Cx activities, schedules and responsibilities	<input type="checkbox"/>

1. These are not the detailed step-by-step test procedures, but are lists of features, elements, modes and conditions of tests for specific equipment.

Owner / Owner Representative Signature

Date

COMMISSIONING PLAN COMPLIANCE CHECKLIST	
--	--

INCORPORATE THIS FORM IN THE PLANS

Project Address: _____

Permit Number: _____

ITEM #	COMMISSIONING PLAN ITEMS ¹	PAGE NUMBER IN COMMISSIONING PLAN DOCUMENT
	GENERAL PROJECT INFORMATION	
1	Project name, owner, location	
2	Building type, building area	
3	Overall project commissioning schedule	
4	Contact information for individual/company providing commissioning services	
	COMMISSIONING GOALS	
5	Meet California Green Building Standards Code requirements for commissioning	
6	Meeting OPR and BOD requirements	
7	Carrying out requirements for commissioning activities as specified in plans and specifications	
	SYSTEMS TO BE COMMISSIONED	
8	Explanation of the original design intent (refer to OPR and BOD documents)	
9	Equipment and systems to be tested*, functions to be tested, conditions under which the test shall be performed, and measurable criteria for acceptable performance	
	COMMISSIONING TEAM INFORMATION	
10	List of all team members and contact information (i.e. owner, owner's representative, architect, engineers, designated commissioning representative, and (if available): general contractor, sub-contractors, and construction manager)	
	COMMISSIONING PROCESS ACTIVITIES, SCHEDULES, AND RESPONSIBILITIES	
11	Prescribed commissioning process steps and activities to be accomplished by the Cx team throughout the design to occupancy	
12	Roles and responsibilities for each member of the Cx team for each phase of the work	
13	Required Cx deliverables, reports, forms, and verifications expected at each stage of the commissioning effort	
14	Confirmation process for the O&M manual, systems manual and the facility operator and maintenance staff training	

1. The following systems shall be tested: renewable energy systems, landscape irrigation systems and water reuse systems

Owner/Owner Representative Acknowledgment

The commissioning plan includes the items listed above and have been approved by the Owner or Owner Representative:

Name: _____ Owner Owner's Representative

Company Name (if applicable): _____

Signature: _____ Date: _____

DRAFT

FUNCTIONAL PERFORMANCE TESTING COMPLIANCE FORM	
---	--

CALGreen Commissioning Requirement 5.410.2.4-Functional Performance Testing

5.410.2.4 Functional performance testing. [N] *Functional performance tests shall demonstrate the correct installation and operation of each component, system, and system-to-system interface in accordance with the approved plans and specifications. Functional performance testing reports shall contain information addressing each of the building components tested, the testing methods utilized, and include any readings and adjustments made.*

Test forms have been developed for each piece of commissioned equipment and system and include the checked elements listed below. These tests have been executed with deficiencies corrected.

	Functional Test Elements	Included
1.	Date and parties participating	<input type="checkbox"/>
2.	Signature block attesting test is complete and accurate	<input type="checkbox"/>
3.	Prerequisites	<input type="checkbox"/>
4.	Precautions	<input type="checkbox"/>
5.	Instrumentation required	<input type="checkbox"/>
6.	Reference to the source of what is being confirmed (sequences, packaged features, etc.)	<input type="checkbox"/>
7.	Detailed step-by-step test instructions	<input type="checkbox"/>
8.	Acceptance criteria	<input type="checkbox"/>
9.	Results	<input type="checkbox"/>
10.	Confirmation of returning to normal	<input type="checkbox"/>
11.	Deficiency list	<input type="checkbox"/>

Cx Coordinator Signature

Date

FUNCTIONAL PERFORMANCE TESTING COMPLIANCE FORM	
---	--

THIS FORM IS TO COMPLETED FOR THE TIME OF INSPECTION

Project Address: _____

Permit Number: _____

List the functional test reports below for all systems to be tested (see Form 5.4-8.1, item #9)

REPORT # (e.g. FPT-003)	SYSTEM/EQUIPMENT TEST REPORT (See minimum report requirements on page 2 of this form)	PAGE/TAB # IN COMMISSIONING REPORT

Minimum Requirements for Test Report

1. Date and Party – Identification of the date of the test and the party conducting the test.
2. Signature Block – Signature of the designated commissioning lead and the equipment installing contractor attesting that the recorded test results are accurate.
3. Prerequisites – any conditions or related equipment checkout or testing that needs to be completed before conducting this test.
4. Precautions – Identification of the risks involved to the test team members and the equipment and how to mitigate them.
5. Instrumentation – Listing of the instrumentation and tools necessary to complete the test.
6. Reference – In each procedure item, identify the source for what is being confirmed (e.g. sequence of operation ID, operating feature, specification requirement, etc.)
7. Test Instructions – Step-by-step instructions of how to complete the test, including functions to test and the conditions under which the tests should be performed.
8. Acceptance Criteria – Measurable pass/fail criteria for each step of the test, as applicable.
9. Results – Expected system response and space to document the actual response, readings, results, and adjustments.
10. Return to Normal – Instructions that all systems and equipment are to be returned to their as-found state at the conclusion of the tests.
11. Deficiencies – A list of deficiencies and how they were mitigated.

Commissioning Agent Acknowledgment

I have reviewed the test reports listed above and verified that they are complete; these tests have been executed with deficiencies corrected.

Name: _____

Company Name (if applicable): _____

Agent's signature: _____ Date: _____

CALGreen Commissioning Requirement 5.410.2.5.1-Documentation and Training-Systems Manual

5.410.2.5.1 Systems Manual. [N] Documentation of the operational aspects of the building shall be completed within the Systems Manual and delivered to the building owner or representative. The Systems Manual shall include the following: checked elements listed below. (See elements checklist below)

	System Manual Elements	Included
1.	Site information including facility description, history and current requirements	<input type="checkbox"/>
2.	Site contact information	<input type="checkbox"/>
3.	Basic operations and maintenance and troubleshooting	<input type="checkbox"/>
4.	Systems covered include major systems listed under the BOD.	<input type="checkbox"/>
5.	Site equipment inventory and maintenance notes	<input type="checkbox"/>
6.	Special inspection verifications	<input type="checkbox"/>
7.	Other resources and documentation	<input type="checkbox"/>

Owner or Owner Representative Signature

Date

SYSTEM OPERATIONS TRAINING COMPLIANCE FORM	
---	--

CALGreen Commissioning Requirement 5.410.2.5.2-System Operations Training

5.410.2.5.2 Systems Operations Training.[N] *A program for training of the appropriate maintenance staff for each equipment type and/or system shall be developed and documented in the commissioning report and shall include the following. (See elements checklist below)*

The written training program includes the checked elements listed below.

	Training Program Elements	Included
1.	System/equipment overview (what it is, what it does and with what other systems and/or equipment it interfaces)	<input type="checkbox"/>
2.	Review and demonstration of servicing & preventive maintenance	<input type="checkbox"/>
3.	Review of the information in the Systems Manual	<input type="checkbox"/>
4.	Review of the record drawings on the system/equipment	<input type="checkbox"/>

The Owner or Owner Representative attest that when the appropriate maintenance staff are made available prior to certificate of occupancy that the written training program was executed with these staff. Or, that if appropriate maintenance staff are not available, that the written training program was submitted and approved by the Owner or Owner Representative.

Owner or Owner Representative Signature

Date

SYSTEM OPERATIONS TRAINING COMPLIANCE FORM	
---	--

THIS FORM IS TO BE COMPLETED PRIOR TO INSPECTION

Project Address: _____

Permit Number: _____

Part One: System Manual

ITEM #	SYSTEM MANUAL ELEMENTS	PAGE NUMBER IN MANUAL
	SITE INFORMATION	
1	General (i.e. address, acreage, local utility information, other)	
2	Facility description (i.e. use/function, square footage, occupancy type, construction type, basis of design, location of major systems & equipment)	
3	Project history (i.e. project requirements (BOD/OPR), project undocumented events, record drawings & documents, final control drawings & schematics, final control sequences, construction documents)	
4	Current requirements (i.e. building operating schedules, space temperature, humidity, pressure, CO ₂ setpoints, summer and winter setback schedules, chilled and hot water temperatures, As-built control setpoints & parameters)	
	SITE CONTACT INFORMATION	
5	Owner Information	
6	Emergency contacts	
7	Design Team (i.e. architect, mechanical engineer, electrical engineer, other)	
8	Prime Contractor contact information	
9	Subcontractor information	
10	Equipment supplier contact information	
	BASIC OPERATIONS & MAINTENANCE	
11	Basic operation (i.e. narratives of basic equipment operation, interfaces, interlocks & interaction with other equipment & systems, initial maintenance provided by the contractor)	
12	General site operating schedules (i.e. instructions for changes in major system operating schedules, instructions for changes in major system holiday & weekend schedules)	
13	Basic troubleshooting (i.e. cite recommended troubleshooting procedures specific to major systems & equipment, manual operation procedures, standby/backup/bypass operation procedures, major system power fail resets and restarts, trend log listing)	
14	Recommended maintenance events log (i.e. HVAC air filter replacement schedule & log, building control system sensor calibration schedule & log)	
15	Operation & maintenance manuals (location or delivery information)	
	MAJOR SYSTEMS	
19	Water Heating Systems	
20	Landscape irrigation systems (i.e. water distribution diagrams, and	

	control system)	
21	Water reuse systems (i.e. reclaimed water system for indoor use, reclaimed water for irrigation use)	
SITE EQUIPMENT INVENTORY & MAINTENANCE NOTES		
22	Spare parts inventory	
23	Frequently required parts and supplies	
24	Special equipment required to operate or maintain systems	
25	Special tools required to operate or maintain systems	
SPECIAL INSPECTIONS		
26	Copies of all special inspection verifications required by the enforcing agency of this code	
OTHER		
27	Other resources and documentation	

Part Two: Training

ITEM #	TRAINING PROGRAM ELEMENTS	PAGE NUMBER IN TRAINING DOCUMENT
1	System/equipment overview (i.e. what it is, what it does, and with what other systems and/or equipment it interfaces)	
2	Review and demonstration of servicing & preventative maintenance	
3	Review of the information in the Systems Manual	
4	Review of the record drawings on the system/equipment	

Owner/Owner Representative Acknowledgment

- Documentation of the operation aspects of the building shall be completed within the systems manual and delivered to the building owner or representative and facilities operator. The Systems Manual includes the elements listed in part one of this form; or
- When the appropriate maintenance staff is made available prior to the certificate of occupancy, the written training program will be executed to these staff. The written training program includes the elements listed in part two of this form.

Name: _____
Representative

Owner

Owner's

Company Name (if applicable): _____

Signature: _____ Date: _____

<h2 style="margin: 0;">Commissioning Report Compliance Form</h2>	
--	--

CALGreen Commissioning Requirement 5.410.2.6 Commissioning Report

5.410.2.6 Commissioning Report. [N] *A report of commissioning process activities undertaken through the design and construction phases of the building project shall be completed and provided to the owner or representative.*

The commissioning report should include the checked elements listed below and should be approved by the Owner or Owner’s Representative.

	Commissioning Report Elements	Included
1.	Executive summary with conclusions and outstanding issues	<input type="checkbox"/>
2.	History of system deficiencies and resolution	<input type="checkbox"/>
3.	Summary of system functional test results	<input type="checkbox"/>
4.	Summary of training completion	<input type="checkbox"/>
5.	Attachments of Commissioning plan, OPR, BOD, executed (filled in) installation checklists, executed functional tests, recommendations for end-of-warranty review	<input type="checkbox"/>

Owner / Owner’s Representative Signature

Date

COMMISSIONING REPORT COMPLIANCE FORM

THIS FORM IS TO BE COMPLETED PRIOR TO INSPECTION

Project Address: _____

Permit Number: _____

ITEM #	COMMISSIONING REPORT ELEMENTS	PAGE NUMBER IN COMMISSIONING REPORT DOCUMENT
	EXECUTIVE SUMMARY	
1	Executive summary of process and results of commissioning program (include observations, conclusions, and any outstanding items)	
	HISTORY OF ANY SYSTEM DEFICIENCIES AND HOW RESOLVED	
6	Outstanding deficiencies and plans for resolution	
7	Plans for seasonal testing scheduled for a later date	
	RESULTS	
8	System performance test results and evaluations	
	SUMMARY OF TRAINING	
9	Summary of training process completed and scheduled	
	ATTACH COMMISSIONING PROCESS DOCUMENTS	
10	Commissioning Plan	
11	Owner's Project Requirements (OPR)	
12	Basis of Design (BOD)	
13	Executed installation checklists	
14	Executed Functional Performance Test (FPT) forms	
15	Recommendations for end-of-warranty review activities	

Owner & Commissioning Agent Acknowledgment

The commissioning report includes the items listed above and is approved by the owner/owner's representative and commissioning agent below.

1. Owner/Owner's Representative

The commissioning report includes the items listed above and have been approved by the Owner or Owner's Representative.

Name: _____ Owner Owner's Representative

Company Name (if applicable): _____

Signature: _____ Date: _____

2. Commissioning Agent

Name: _____

Company Name (if applicable): _____

Signature: _____ Date: _____