

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than May 23, 2025, 5:00 p.m.)

PMDB RFBI No.: 01

Requestor RFBI No.: 01

Request Date: 5/23/25

From (Bidder): XL Construction

To: **Sabina Wiley, Project Director II**
Project Management and Development Branch
Real Estate Services Division
Phone: 279-799-3936

Email: sabina.wiley@dgs.ca.gov

Contact: Austin Stewart

Phone: (650) 208-0802

Fax: _____

Email: astewart@xlconstruction.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000014471

Project Name: LOT 50 ACCESSIBILITY UPGRADES & EVCS

Location: SACRAMENTO, CA

Drawing Reference: _____ Project Manual Reference: _____

Question:

The drawings indicate that coring and drilling into the existing structure will be required for installation of the wheel stops and curbs. To proceed safely, we would like to clarify the following:

1. Slab Type Confirmation:
Please confirm whether the existing structural slabs are post-tensioned.
2. Scanning Requirements:
Please advise on the required scanning procedures for the parking structure.

AOR Response:

1. The Ground Level slab is non-structural with steel reinforcement. Levels 1-6, including all ramps, are post-tensioned concrete.
2. Any areas with planned drilling or core work into the concrete slabs need to be scanned to avoid existing reinforcement. We do not have specific requirements for how this is accomplished.

Bidder's Authorized Signature: Austin Stewart

☐ Check here if additional pages attached

Page 1 of 1