

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than December 19, 2025, 5:00 p.m.)

PMDB RFBI No.: 04

Requestor RFBI No.: 02

Request Date: 12/19/2025

From (Bidder): McCarthy

To: Jenny Li, Project Director
Project Management and Development Branch
Real Estate Services Division
Phone: 916-206-3264

Email: jenny.li@dgs.ca.gov

Contact: Adam Osantowski

Phone: 916-532-5140

Fax: _____

Email: AOsantowski@McCarthy.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000009324

Project Name: OES Security Upgrades

Location: Mather, Sacramento County, CA

Drawing Reference: _____ Project Manual Reference: _____

Question:

Please confirm whether directional boring is an acceptable means of installation for the new 1" and 2" PVC conduits (power and telecom) serving each of the new guard shack and security arm locations

DGS Response:

Directional boring is not an acceptable means of installation for the new 1" and 2" PVC conduits (power and telecom) serving each of the new guard shack and security arm locations due to the risks associated with hitting existing underground utilities, including but not limited to gas line, electrical services, and other critical communication infrastructure. Note that OES Headquarters campus is an Essential Services Facility, where continuous operation is critical.

- Jenny Li, Project Director, DGS, 12/22/2025

Bidder's Authorized Signature: Adam Osantowski

[] Check here if additional pages attached

Page 1 of 1