

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than December 17, 2024, 5:00 p.m.)

To: Sagar Gupta, Project Director
Project Management and Development Branch
Real Estate Services Division
Phone: 916-591-2691

Email: sagar.gupta@dgs.ca.gov

PMDB RFBI No.: 16
Requestor RFBI No.: 13
Request Date: Dec. 17, 2024
From (Bidder): Preston Pipelines Infrastructure LLC

Contact: Chad Hutchinson
Phone: 209.649.5982
Fax: 916.386.7531
Email: chutchinson@prestonpipelines.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000008666
Project Name: DSH-Coalinga Hydronic Loop Replacement
Location: Coalinga, CA

Drawing Reference: Mech. Sheets Project Manual Reference: 23 20 13 - Above Ground Piping

Question: Can the 3.5" hot water piping be upsized to 4" piping?

It will be difficult to procure 3.5" pipe and fittings. That is a very odd size.

Bureau Veritas Response:
01/13/2025

All heating hot water piping indicated to be 3.5" diameter piping shall instead be 4" diameter piping.

Richard Henrikson
Mechanical Project Engineer

Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of _____