

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than ~~December 17, 2024~~, 5:00 p.m.)

December 27, 2024 per Add. #1

To: Sagar Gupta, Project Director
Project Management and Development Branch
Real Estate Services Division
Phone: 916-591-2691

Email: sagar.gupta@dgs.ca.gov

PMDB RFBI No.: 19
Requestor RFBI No.: 16
Request Date: Dec. 26, 2024
From (Bidder): Preston Pipelines
Infrastructure LLC

Contact: Chad Hutchinson
Phone: 209.649.5982
Fax: 916.386.7531
Email: chutchinson@prestonpipelines.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000008666
Project Name: DSH-Coalinga Hydronic Loop Replacement
Location: Coalinga, CA

Drawing Reference: Mech. Sheet M-1.03 Project Manual Reference: n/a

Question: Please confirm that the contractor will be required to flush and clean the new, as well as the existing, hydronic piping within the buildings. Or will the Facilities Management group clean the existing piping during the commissioning sequence?

Additionally, please identify if the Facilities Management will work with the Contractor purge air from the existing piping within the Hospital during the commissioning activities.

From Sheet M-1.03


Clean the new HHW piping in the building. Pipe cleaning requirements are covered in the Division 23 specifications sections.

Response:

Contractor will be required to flush and clean the new piping entirely per specs. Facility will assist in flushing existing pipe during the commissioning.

Facility will work with contractor to purge air from the existing pipe during the commissioning.

Bidder's Authorized Signature:



[] Check here if additional pages attached

Page 1 of 1