

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than ~~December 17, 2024, 5:00 p.m.~~)

December 27, 2024 per Add. #1

PMDB RFBI No.: 24

Requestor RFBI No.: 21

Request Date: Dec. 26, 2024

From (Bidder): Preston Pipelines Infrastructure LLC

To: **Sagar Gupta, Project Director**
Project Management and Development Branch
Real Estate Services Division
Phone: 916-591-2691

Email: sagar.gupta@dgs.ca.gov

Contact: Chad Hutchinson

Phone: 209.649.5982

Fax: 916.386.7531

Email: chutchinson@prestonpipelines.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000008666
Project Name: DSH-Coalinga Hydronic Loop Replacement
Location: Coalinga, CA

Drawing Reference: Sheet S-3.00 Project Manual Reference: _____


Question: Please confirm that all the roof pipe supports need to align with the steel roof beams as shown below.

If so, please confirm that the Owner will locate the position of the existing beams on the roof.

Bureau Veritas Response:
1/13/2025

The roof pipe supports needs to align with steel roof beam. For location of the existing beams coordinate with the owner.

Aygin Teimoori
structural Project Engineer



4 DETAIL

Scale: 1" = 1'-0" Ref:

Bidder's Authorized Signature:

[] Check here if additional pages attached

Page 1 of 1