

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than ~~December 17, 2024, 5:00 p.m.~~)

December 27, 2024 per Add. #1

PMDB RFBI No.: 26

Requestor RFBI No.: 23

Request Date: Dec. 26, 2024

From (Bidder): Preston Pipelines Infrastructure LLC

To: **Sagar Gupta, Project Director**
Project Management and Development Branch
Real Estate Services Division
Phone: 916-591-2691

Email: sagar.gupta@dgs.ca.gov

Contact: Chad Hutchinson

Phone: 209.649.5982

Fax: 916.386.7531

Email: chutchinson@prestonpipelines.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000008666

Project Name: DSH-Coalinga Hydronic Loop Replacement


Location: Coalinga, CA

Drawing Reference: Sheet M-4.38C Project Manual Reference: _____

Question: Please reference the plan sheet comments shown below.

Based on the project walk, it appears that there are potential electrical conduit conflicts for the hot water connections within Building 38.

Please advise how the Contractor should address this situation in the bid and/or if the Owner will issue a revised drawing.



Bureau Veritas Response:
01/14/2025

The pipes should penetrate the canopy where they will miss the electrical conduits and then route back to the exterior side of the wall to drop down along the wall.

Richard Henrikson
Mechanical Project Engineer

Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of 1