

REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than December 17, 2024, 5:00 p.m.)

PMDB RFBI No.: 4

Requestor RFBI No.: 1

Request Date: 12/19/24

From (Bidder): Tak Broadband

To: **Sagar Gupta, Project Director**
Project Management and Development Branch
Real Estate Services Division
Phone: 916-591-2691

Email: sagar.gupta@dgs.ca.gov

Contact: Steve Medley

Phone: 916-869-5213

Fax: _____

Email: smedley@takcommunicationsca.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000008666

Project Name: DSH-Coalinga Hydronic Loop Replacement

Location: Coalinga, CA

Drawing Reference: C-1.1 AND C-1.11 Project Manual Reference: _____

Question: On both of these pages it calls for the pipe to be bored under fence and no mans land (see note 7)

C-1.1 is a 3.5" pipe and C-1.11 is a 8" pipe but it doesn't give you a casing size. The detail is on page C-4.1

Response: Casing should be at least 6" larger than the host pipe.

By: Bureau Veritas, Orland Obtera (949.210.5781), 1-10-2025

Bidder's Authorized Signature: _____

[] Check here if additional pages attached

Page 1 of _____