

# REQUEST FOR BIDDING INTERPRETATION (RFBI)

(Email no later than December 17, 2024, 5:00 p.m.)

To: Sagar Gupta, Project Director  
Project Management and Development Branch  
Real Estate Services Division  
Phone: 916-591-2691

Email: [sagar.gupta@dgs.ca.gov](mailto:sagar.gupta@dgs.ca.gov)

PMDB RFBI No.: 9  
Requestor RFBI No.: 6  
Request Date: Dec. 17, 2024  
From (Bidder): Preston Pipelines Infrastructure LLC

Contact: Chad Hutchinson  
Phone: 209.649.5982  
Fax: 916.386.7531  
Email: chutchinson@prestonpipelines.com

All RFBI's received prior to deadline identified above, and responses from the State will be published on <http://www.caleprocure.ca.gov>. Click on "Start Search." In the event name field, enter the project number and click search. While viewing the Event Details, click on "View Event Package" to view RFBI responses.

Project No.: 000000000008666  
Project Name: DSH-Coalinga Hydronic Loop Replacement  
Location: Coalinga, CA

Drawing Reference: n/a Project Manual Reference: n/a

Question: During the pre-bid job walk, it appeared that a number of motion sensors, near to the perimeter fencing, may potentially be near the proposed piping alignment.

Based on the review of the plans, it appears that new hydronic loop does not conflict with the electrical conduits associated with this system.

Please confirm that the Contractor will not be required to make any temporary accommodations to keep to avoid conflicts with the motion sensors system.

Response:

Contractor will be responsible to avoid any conflicts with the motion sensor system if it crosses path into the contractor's work area. Contractor will be responsible to relocate the sensors if it crosses path into the contractor's work area. If sensors and any of its components are damaged during the construction, it will be contractor's responsibility to fix completely to its original condition.

Bidder's Authorized Signature: \_\_\_\_\_

[ ] Check here if additional pages attached

Page 1 of \_\_\_\_\_