

Notice of Determination**Appendix D****To:**

Office of Planning and Research
 U.S. Mail: Street Address:
 P.O. Box 3044 1400 Tenth St., Rm 113
 Sacramento, CA 95812-3044 Sacramento, CA 95814

County Clerk
 County of: San Bernardino
 Address: 222 West Hospitality Lane
San Bernardino, California 92415

From:

Public Agency: CA Dept. of General Services
 Address: 707 3rd Street 3-401
West Sacramento, California 95605
 Contact: Jennifer Parson
 Phone: (916) 376-1604

Lead Agency (if different from above):
California Department of State Hospitals
 Address: 1215 O Street
Sacramento, California 95814
 Contact: Robert Horsley
 Phone: (916) 562-2209

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2022030787

Project Title: Patton State Hospital Waterline Replacement Project

Project Applicant: California Department of State Hospitals

Project Location (include county): 3102 Highland Ave., City of San Bernardino, San Bernardino County

Project Description:

Patton State Hospital proposes to replace an existing 14-inch diameter, 115-foot-long waterline due to leakage. The new 16-inch diameter waterline would extend approximately 165 feet and be installed from two existing reduced pressure double detector check and pressure reducing valve assemblies. The abandoned waterline would be filled with grout. Construction of the Proposed Project is estimated to begin in Spring of 2023 and last approximately 13 months.


This is to advise that the California Department of State Hospitals has approved the above
 Lead Agency or Responsible Agency)

described project on 9/12/2022 and has made the following determinations regarding the above
 (date)
 described project.

1. The project [will will not] have a significant effect on the environment.
2. An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
 A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [were were not] made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [was was not] adopted for this project.
5. A statement of Overriding Considerations [was was not] adopted for this project.
6. Findings [were were not] made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

<http://bit.ly/DGSCEQA>

Signature (Public Agency):  Title: Chief Operating Officer (A)

Date: 9/12/2022 Date Received for filing at OPR: _____