

**COMMISSION ACTION MATRIX**  
**2019 CALIFORNIA BUILDING CODE, TITLE 24, PART 2, 11B (2018 INTERNATIONAL BUILDING CODE)**  
**AGENCY: DIVISION OF STATE ARCHITECT (DSAAC 01/19)**

**LEGEND:**

**CAC Actions:** Approve as Amended, Approve as Submitted, Disapprove, Further Study

**Agency Responses:** Accept, Disagree, Withdraw

**CBSC Actions:** Approve as Amended, Approve as Submitted, Disapprove, Further Study

**Matrix Paper Color (for commission action only):** GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

**ACCESS CODE ADVISORY COMMITTEE**

**CHAPTER 1 – SCOPE AND ADMINISTRATION DIVISION I CALIFORNIA ADMINISTRATION.**

Amend Section 1.9 –Division of the State Architect.

Item Number 1.01	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-1-01	1.9.1.3	Approve as Submitted	Accept		Delete term “private housing available for public use” and reference to Government Code 4450.	

**CHAPTER 2 – DEFINITIONS.**

Amend Section 202.

Item Number 2.01	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-01	<b>BLEND TRANSITION</b>	Approve as Submitted	Accept		Amend definition replace term “pedestrian access route” with <u>circulation path</u> and include additional amendments for clarity.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.02	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-02	<b><u>BOTTLE FILLING STATION</u></b>	Approve as Submitted	Accept		Add new definition for proposed amendments in Sections 11B-211.4 and 11B-602.10.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.03	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-03	<b>CIRCULATION PATH</b>	Approve as Submitted	Accept		Amend definition to clarify that a circulation path describes all prepared surfaces for pedestrian travel, accessible and non-accessible.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.04	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-04	<b>CURB RAMP</b>	Approve as Submitted	Accept		Amend definition to replace term " <del>pedestrian way</del> " with the term "prepared surface." This is consistent with DSA's intent curb ramp is applied to constructed rather than natural elements.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.05	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-05	<b><i>DETECTABLE WARNING</i></b>	Approve as Submitted	Accept		Amend definition to better describe the intended purpose of detectable warnings.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.06	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-06	<b><i><u>DRIVE AISLE</u></i></b>	Approve as Submitted	Accept		Add new definition for proposed language in Section 11B-250.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.07	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-07	<b><i><u>DRIVEWAY</u></i></b>	Approve as Submitted	Accept		Add new definition for proposed language in Section 11B-250.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.08	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-08	<b>PEDESTRIAN WAY</b>	Approve as Submitted	Accept		Repeal definition. Circulation path provides greater specificity and consistent with terminology used in the 2010 ADA Standards.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.09	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-09	<b>PUBLIC HOUSING</b>	Further Study	Accept		Amend definition to repeal redundant language “publicly owned and/or operated.” Eliminate item 7 that is ambiguous and vague. Provide a new note for code user to refer to “Guide to Public Housing.” Clarify definition based on questions received from code users.	

CHAPTER 2 – DEFINITIONS.  
Amend Section 202.

Item Number 2.10	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-2-10	<b>PUBLIC USE</b>	Approve as Submitted	Accept		Amend definition to repeal the last sentence in definition “public use is the provision of housing programs.” It is unnecessary and confusing.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Existing buildings and facilities.

Item Number 11B.01	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-01	<b>11B-202.4 Exception 10</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend language to clarify language regarding term “primary function” (which is not defined).	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B General exceptions.

Item Number 11B.02	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-02	<b>11B-203.8</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Operable parts.

Item Number 11B.03	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-03	<b>11B-205.1</b>	<b>Further Study</b>	<b>Accept</b>		Amend section to alleviate conflict with Electrical code for placements of electrical outlets.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Accessible routes.

Item Number 11B.04	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-04	<b>11B-206.2.3</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Accessible routes.

Item Number 11B.05	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-05	<b>11B-206.7.6</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Parking spaces.

Item Number 11B.06	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-06	<b>11B-208.1</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to allow installation of electric vehicle charger when accessible parking space is assigned to resident.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section *11B Parking spaces*.

Item Number 11B.07	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-07	<b>11B-208.2.3</b>	<b>Approve as Amended</b>	<b>Accept</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section *11B Parking spaces*.

Item Number 11B.08	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-08	<b>11B-208.3.2</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Sections *11B Drinking fountains*.

Item Number 11B.09	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-09	<b>11B-211</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend title to include bottle filling stations.	
DSAAC 01/19-11B-09-1	<b>11B211.4</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to provide scoping and technical provisions for bottle filling stations for access compliance.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B *Transient lodging guest rooms, housing at a place of education and social service center establishments.*

Item Number 11B.10	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-10	<b>11B-224.8</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Repeal references to sections 11-224.1 through 11B-224.6 that create confusion. The proposed change, add 11B-233.3 aligns 11B with 2010 ADA Standards.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B *Dining surfaces and work surfaces.*

Item Number 11B.11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-11	<b>11B-226.4</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section in order to use the same title for baby diaper changing stations consistent with Gov' Code 50535 & HSC 118506..	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B *Depositories, vending machines, change machines, mailboxes, fuel dispensers, and electric vehicle charging stations.*

Item Number 11B.12	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-12	<b>11B-228.2</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B. Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	



CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Depositories, vending machines, change machines, mail boxes, fuel dispensers, and electric vehicle charging stations.

Item Number 11B.13	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-13	<b>11B-228.3.2</b>	<b>Further Study</b>	<b>Accept</b>		Amend section to clarify language to indicate that each combination of charging level and connector type provided constitutes a facility.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Sections 11B Residential facilities.

Item Number 11B.14	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-14	<b>11B-233.3</b>	<b>Approve as Amended</b>	<b>Disagree</b>		Amend section to add reference note to alert code users of the requirements in the Civil Code for senior housing.	
DSAAC 01/19-11B-14-1	<b>11B-233.3.1.2</b>	<b>Approve as Amended</b>	<b>Disagree</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B. Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	
DSAAC 01/19-11B-14-2	<b>11B-233.3.1.2.4</b>	<b>Approve as Amended</b>	<b>Disagree</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B. Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	
DSAAC 01/19-11B-14-3	<b>11B-233.3.1.2.5</b>	<b>Approve as Amended</b>	<b>Disagree</b>		Amend section to delete reference to 11A. DSA revised and reformatted 11B. Sections 11B-809.6 through 11B-809.12 for public housing change proposals.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.  
Amend Sections 11B Residential facilities.

Item Number 11B.15	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-15	<b>11B-233.3.1.2.6</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section for consistency with the format of Chapter 11B which is a response to comments from code users regarding public housing projects.	
DSAAC 01/19-11B-15-1	<b>11B-233.3.1.2.6.1</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section with the intent to include the provisions related to public housing.	
DSAAC 01/19-11B-15-2	<b>11B-233.3.1.2.6.2</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section with the intent to include the provisions related to public housing.	
DSAAC 01/19-11B-15-3	<b>11B-233.3.1.2.6.3</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section with the intent to include the provisions related to public housing.	
DSAAC 01/19-11B-15-4	<b>11B-233.3.1.2.6.4</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section with the intent to include the provisions related to public housing.	
DSAAC 01/19-11B-15-5	<b>11B-233.3.1.2.6.5</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section with the intent to include the provisions related to public housing.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.  
Amend Section 11B Residential facilities.

Item Number 11B.16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-16	<b>11B-233.3.2.1</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section, new language taken from United States Code of Federal Regulations for facilities with residential dwelling units offered for sale. Repeal exception which was unnecessary requirement.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Residential facilities.

Item Number 11B.17	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-17	<b>11B-233.3.4.2</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to delete “public housing facility” from text.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Detectable warnings and detectable directional texture.

Item Number 11B.18	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-18	<b>11B-247.1.2.5</b>	<b>Disapprove</b>	<b>Disagree</b>		Amend section to minimize confusion about the required placement of detectable warnings.	

CHAPTER 11B – DIVISION 2: SCOPING REQUIREMENTS.

Amend Section 11B Circulation paths.

Item Number 11B.19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-19	<b>11B-250.1</b>	<b>Disapprove</b>	<b>Disagree</b>		Amend section to require circulation paths be physically separated from vehicular traffic in all locations, with several exceptions provided.	

CHAPTER 11B – DIVISION 3 BUILDING BLOCKS.  
Amend Section 11B Turning space.

Item Number 11B.20	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-20	<b>11B-304.2</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to clarify that detectable warnings are not permitted at floor or ground surfaces in turning spaces.	

CHAPTER 11B – DIVISION 3 BUILDING BLOCKS.  
Amend Section 11B Clear floor or ground space.

Item Number 11B.21	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-21	<b>11B-305.2</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to clarify that detectable warnings are not permitted at clear floor or ground space..	

CHAPTER 11B – DIVISION 4: ACCESSIBLE ROUTES.  
Amend Section 11B Doors, Doorways, and gates.

Item Number 11B.22	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-22	<b>11B-404.2.4.4</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to clarify that detectable warnings are not permitted at door maneuvering clearances.	

CHAPTER 11B – DIVISION 4: ACCESSIBLE ROUTES.  
Amend Section 11B Doors, doorways, and gates.

Item Number 11B.23	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-23	<b>11B-404.2.9</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to correct drafting error made in 2012 rulemaking cycle.	

CHAPTER 11B – DIVISION 4: ACCESSIBLE ROUTES.  
Amend Section 11B Ramps.

Item Number 11B.24	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-24	<b>11B-405.7.1</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to clarify detectable warnings are not permitted at ramp landings. Exception rescinded and restated in parent section.	

CHAPTER 11B – DIVISION 4: ACCESSIBLE ROUTES.  
Amend Section 11B Curb ramps, blended transitions and islands.

Item Number 11B.25	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-25	<b>11B-406.3</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to change proposal to allow parallel curb ramps to be provided with one or two opposed sloping segments.	

CHAPTER 11B – DIVISION 4: **ACCESSIBLE ROUTES.**

Amend Section *11B Curb ramps, blended transitions and islands.*

Item Number 11B.26	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-26	<b>11B-406.5.10</b>	Further Study	Disagree		Amend language to clarify addressing diagonal perpendicular and parallel curb ramps.	

CHAPTER 11B – DIVISION 5: GENERAL SITE AND BUILDING ELEMENTS.

Amend Section *11B Parking spaces.*

Item Number 11B.27	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-27	<b>11B-502.3</b>	Approve as Submitted	Accept		Amend section to state the access aisle may be shared between accessible parking space and electric vehicle charging station.	

CHAPTER 11B – DIVISION 5: GENERAL SITE AND BUILDING ELEMENTS.

Amend Section *11B Parking spaces.*

Item Number 11B.28	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-28	<b>11B-502.4</b>	Approve as Submitted	Accept		Amend section to clarify that detectable warnings are not permitted at accessible parking access aisles. Exception rescinded and added to parent section.	

**CHAPTER 11B – DIVISION 5: GENERAL SITE AND BUILDING ELEMENTS.**

Amend Section 11B passenger drop-off and loading zones.

Item Number 11B.29	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-29	<b>11B-503.4</b>	Approve as Submitted	Accept		Amend section to clarify that detectable warnings are not permitted at accessible passenger drop off and loading zone access aisles. Exception rescinded and added to parent section.	

**CHAPTER 11B – DIVISION 5: GENERAL SITE AND BUILDING ELEMENTS.**

Amend Section 11B Stairways.

Item Number 11B.30	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-30	<b>11B-504.4</b>	Approve as Submitted	Accept		Amend section to clarify that detectable warnings are not permitted at stair treads. Exception rescinded and added to parent section.	

**CHAPTER 11B – DIVISION 6: PLUMBING ELEMENTS AND FACILITIES.**

Amend Section 11B – Drinking fountains.

Item Number 11B.31	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-31	<b>11B-602</b>	Approve as Submitted	Accept		Amend title to include bottle filling stations.	
DSAAC 01/19-11B-31-1	<b>11B-602.10</b>	Approve	Accept		Amend section to provide technical provisions for bottle filling stations for access compliance.	

Item Number 11B.31	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
		as Submitted				

**CHAPTER 11B – DIVISION 6: PLUMBING ELEMENTS AND FACILITIES.**

*Amend Section 11B – Toilet and bathing rooms.*

Item Number 11B.32	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-32	<b>11B-603.5</b>	Approve as Submitted	Accept		Amend section in order to use the same title for baby diaper changing stations consistent with Gov' Code 50535 & HSC 118506..	

**CHAPTER 11B – DIVISION 6: PLUMBING ELEMENTS AND FACILITIES.**

*Amend Section 11B Water closets and toilet compartments.*

Item Number 11B.33	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-33	<b>11B-604.3.2</b>	Further Study	Accept		Amend section to provide clarity and compliant installations of grab bars and lavatories.	
DSAAC 01/19-11B-33-1	<b>Figure 11B-604.3.2</b>	Further Study	Accept		Amend inaccurate figure and associated code language for clarity and compliant installations of grab bars and lavatories.	



**CHAPTER 11B – DIVISION 6: PLUMBING ELEMENTS AND FACILITIES.**

Amend Section 11B Below-Water closets and toilet compartments.

Item Number 11B.34	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-34	<b>11B-604.8.1.2</b>	Approve as Submitted	Accept		Amend section to revise required location for side opening toilet compartment doors.	
DSAAC 01/19-11B-34-1	<b>Figure 11B-604.8.1.1.2</b>	Approve as Submitted	Accept		Amend figure to match associated code language from above.	

**CHAPTER 11B – DIVISION 6: PLUMBING ELEMENTS AND FACILITIES.**

Amend Section 11B Shower compartments.

Item Number 11B.35	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-35	<b>11B-608.5.2</b>	Approve as Submitted	Accept		Amend section to align with 2010 ADA Standards and use consistent terminology. And remove unnecessary language.	
DSAAC 01/19-11B-35-1	<b>Figure 11B-608.5.2</b>	Approve as Submitted	Accept		Amend figure to match associated code language.	
DSAAC 01/19-11B-35-2	<b>11B-608.5.3</b>	Approve as Submitted	Accept		Amend section to aid in compliant installations. And remove unnecessary language.	
DSAAC 01/19-11B-35-3	<b>Figure 11B-608.5.3</b>	Approve as Submitted	Accept		Amend figure to match associated code language.	

**CHAPTER 11B – DIVISION 7: COMMUNICATION ELEMENTS AND FEATURES.**

Amend Section 11B Detectable warnings and detectable directional texture.

Item Number 11B.36	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-36	<b>11B-705.1.1.3</b>	Further Study	Accept		Amend section to require all newly installed detectable warning surfaces to be federal yellow.	
DSAAC 01/19-11B-36-1	<b>11B-705.1.1.3.1</b>	Further Study	Accept		Amend section to update the reference citation for the required color.	

**CHAPTER 11B – DIVISION 7: COMMUNICATION ELEMENTS AND FEATURES.**

Amend Section 11B Detectable warnings and detectable directional texture.

Item Number 11B.37	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-37	<b>11B-705.1.2.2</b>	Disapprove	Disagree		Amend section to reformat 11B-705.1.2.2 to present detectable warnings requirements separately for perpendicular and parallel curb ramps.	
DSAAC 01/19-11B-37-1	<b>11B-705.1.2.2.1</b>	Disapprove	Disagree		Amend section - perpendicular curb ramps.	
DSAAC 01/19-11B-37-2	<b>11B-705.1.2.2.2</b>	Disapprove	Disagree		New section - parallel curb ramps.	
DSAAC 01/19-11B-37-3	<b>11B-705.1.2.2.2.1</b>	Disapprove	Disagree		New section for one entrance/exit point with 2 new exceptions.	
DSAAC 01/19-11B-37-4	<b>11B-705.1.2.2.2.2</b>	Disapprove	Disagree		New section - two entrance/exit points with 2 new exceptions.	

**CHAPTER 11B – DIVISION 7: COMMUNICATION ELEMENTS AND FEATURES.**

Amend Section 11B Detectable warnings and detectable directional texture.

Item Number 11B.38	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-38	<b>11B-705.1.2.5</b>	<b>Disapprove</b>	<b>Disagree</b>		Amend language to require detectable warnings at blended transitions.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES, AND ELEMENTS.**

Amend Section 11B Wheelchair spaces, companion seats, and designated aisle seats and semi-ambulant seats.

Item Number 11B.39	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-39	<b>11B-802.1.1</b>	<b>Approve as Submitted</b>	<b>Accept</b>		Amend section to clarify that detectable warnings are not permitted at floor or ground surfaces for wheelchair spaces. Exception rescinded and restated in parent section.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES, AND ELEMENTS.**

Amend Section 11B Kitchens, kitchenettes, and wet bars.

Item Number 11B.40	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-40	<b>11B-804.2.3</b>	<b>Further Study</b>	<b>Disagree</b>		Amend section to provide requirements from United States Code of Federal Regulations for turning spaces at kitchens in undergraduate student housing.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES, AND ELEMENTS.**

Amend Section 11B Kitchens, kitchenettes, and wet bars.

Item Number 11B.41	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-41	<b>11B-804.3</b>	Further Study	Disagree		Amend section to provide requirements from United States Code of Federal Regulations for kitchen work surfaces in undergraduate student housing.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES AND ELEMENTS.**

Amend Section 11B Residential dwelling units.

Item Number 11B.42	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-42	<b><u>11B-809.6</u></b>	Further Study	Accept		DSA proposing code change in response to comments from code users, for one set of regulations be used for public housing projects. Language written 11B-809.6 through 11B-809.12 is written and formatted to align with the 2010 ADA Standards For Accessible Design.	
DSAAC 01/19-11B-42-1	<b><u>11B-809.7</u></b>	Further Study	Accept		Add new Section: Accessible routes.	
DSAAC 01/19-11B-42-2	<b><u>11B-809.7.1</u></b>	Further Study	Accept		Add new Section: Width.	
DSAAC 01/19-11B-42-3	<b><u>11B-809.7.2</u></b>	Further Study	Accept		Add new Section: Changes in level.	
DSAAC 01/19-11B-42-4	<b><u>11B-809.8</u></b>	Further Study	Accept		Add new Section: Doors.	
DSAAC 01/19-11B-42-5	<b><u>Figure 11B-809.8 Ex.1(c)</u></b>	Further Study	Accept		Add new Figure: Platform at secondary exterior door.	

Item Number 11B.42	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-42-6	<u>Figure 11B-809.8 Ex. 1(d)</u>	Further Study	Accept		Add new Figure: Ramp at exterior door.	
DSAAC 01/19-11B-42-7	<u>11B-809.8.1</u>	Further Study	Accept		Add new Section: Door thresholds.	
DSAAC 01/19-11B-42-8	<u>11B-809.8.2</u>	Further Study	Accept		Add new Section: Door opening force.	
DSAAC 01/19-11B-42-9	<u>11B-809.8.3</u>	Further Study	Accept		Add new Section: Door maneuvering clearances.	
DSAAC 01/19-11B-42-10	<u>11B-809.8.4</u>	Further Study	Accept		Add new Section: Door signal devices.	
DSAAC 01/19-11B-42-11	<u>11B-809.9</u>	Further Study	Accept		Add new Section: Kitchens.	
DSAAC 01/19-11B-42-12	<u>11B-809.9.1</u>	Further Study	Accept		Add new Section: Clear floor space.	
DSAAC 01/19-11B-42-13	<u>11B-809.9.2</u>	Further Study	Accept		Add new Section: Clear width.	
DSAAC 01/19-11B-42-14	<u>Figure 11B-809.9.2</u>	Further Study	Accept		Add new Figure: Clear width at kitchens.	
DSAAC 01/19-11B-42-15	<u>11B-809.9.3</u>	Further Study	Accept		Add new Section: Removable base cabinets.	
DSAAC 01/19-11B-42-16	<u>11B-809.9.4</u>	Further Study	Accept		Add new Section: Work surfaces.	
DSAAC 01/19-11B-42-17	<u>11B-809.9.5</u>	Further Study	Accept		Add new Section: Lower shelving.	
DSAAC 01/19-11B-42-18	<u>11B-809.9.6</u>	Further Study	Accept		Add new Section: Controls.	
DSAAC 01/19-11B-42-19	<u>11B-809.9.7</u>	Further Study	Accept		Add new Section: Exposed pipes and surfaces.	
DSAAC 01/19-11B-42-20	<u>11B-809.10</u>	Further Study	Accept		Add new Title: Toilet and bathing rooms.	
DSAAC 01/19-11B-42-21	<u>11B-809.10.1</u>	Further Study	Accept		Add new Section: General.	
DSAAC 01/19-11B-42-22	<u>11B-809.10.2</u>	Further Study	Accept		Add new Section: Number of complying bathing rooms and fixtures.	
DSAAC 01/19-11B-42-23	<u>11B-809.10.3</u>	Further Study	Accept		Add new Section: Powder rooms.	

Item Number 11B.42	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-42-24	<u>11B-809.10.4</u>	Further Study	Accept		Add new Section: Sufficient maneuvering space.	
DSAAC 01/19-11B-42-25	<u>11B-809.10.5</u>	Further Study	Accept		Add new Section: Bathtubs.	
DSAAC 01/19-11B-42-26	<u>11B-809.10.5.1</u>	Further Study	Accept		Add new Section: Clear floor space.	
DSAAC 01/19-11B-42-27	<u>11B-809.10.5.2</u>	Further Study	Accept		Add new Section: Reinforcement for grab bars.	
DSAAC 01/19-11B-42-28	<i>Figure</i> <u>11B-809.10.5.2</u>	Further Study	Accept		Add new Figure: Reinforcement for grab bars.	
DSAAC 01/19-11B-42-29	<u>11B-809.10.5.3</u>	Further Study	Accept		Add new Section: Controls.	
DSAAC 01/19-11B-42-30	<u>11B-809.10.5.4</u>	Further Study	Accept		Add new Section: Bathtub enclosures.	
DSAAC 01/19-11B-42-31	<u>11B-809.10.6</u>	Further Study	Accept		Add new Section: Showers.	
DSAAC 01/19-11B-42-32	<u>11B-809.10.6.1</u>	Further Study	Accept		Add new Section: Size	
DSAAC 01/19-11B-42-33	<i>Figure</i> <u>11B-809.10.6.1</u>	Further Study	Accept		Add new Figure: Showers.	
DSAAC 01/19-11B-42-34	<u>11B-809.10.6.2</u>	Further Study	Accept		Add new Section: Slope	
DSAAC 01/19-11B-42-35	<u>11B-809.10.6.3</u>	Further Study	Accept		Add new Section: Floor Space	
DSAAC 01/19-11B-42-36	<u>11B-809.10.6.4</u>	Further Study	Accept		Add new Section: Reinforcement for grab bars.	
DSAAC 01/19-11B-42-37	<i>Figure</i> <u>11B-809.10.6.4</u>	Further Study	Accept		Add new Figure: Reinforcement for grab bars.	
DSAAC 01/19-11B-42-38	<u>11B-809.10.6.5</u>	Further Study	Accept		Add new Section: Thresholds.	
DSAAC 01/19-11B-42-39	<u>11B-809.10.6.6</u>	Further Study	Accept		Add new Section: Controls.	
DSAAC 01/19-11B-42-40	<u>11B-809.10.6.7</u>	Further Study	Accept		Add new Section: Shower enclosures.	
DSAAC 01/19-11B-42-41	<u>11B-809.10.7</u>	Further Study	Accept		Add new Section: Water closets.	

Item Number 11B.42	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-42-42	<u>11B-809.10.7.1</u>	Further Study	Accept		Add new Section: Floor space.	
DSAAC 01/19-11B-42-43	<u>Figure 11B-809.10.7.1</u>	Further Study	Accept		Add new Figure: Floor space.	
DSAAC 01/19-11B-42-44	<u>11B-809.10.7.2</u>	Further Study	Accept		Add new Section: Location.	
DSAAC 01/19-11B-42-45	<u>11B-809.10.7.3</u>	Further Study	Accept		Add new Section: Reinforcement for grab bars.	
DSAAC 01/19-11B-42-46	<u>Figure 11B-809.10.7.3</u>	Further Study	Accept		Add new Figure: Reinforcement for grab bars.	
DSAAC 01/19-11B-42-47	<u>11B-809.10.7.4</u>	Further Study	Accept		Add new Section: Seat height.	
DSAAC 01/19-11B-42-48	<u>11B-809.10.7.5</u>	Further Study	Accept		Add new Section: Controls.	
DSAAC 01/19-11B-42-49	<u>11B-809.10.8</u>	Further Study	Accept		Add new Section: Lavatories, vanities, mirrors and towel bars.	
DSAAC 01/19-11B-42-50	<u>11B-809.10.8.1</u>	Further Study	Accept		Add new Section: Location.	
DSAAC 01/19-11B-42-51	<u>11B-809.10.8.2</u>	Further Study	Accept		Add new Section: Floor space.	
DSAAC 01/19-11B-42-52	<u>11B-809.10.8.3</u>	Further Study	Accept		Add new Section: Cabinets.	
DSAAC 01/19-11B-42-53	<u>11B-809.10.8.4</u>	Further Study	Accept		Add new Section: Knee and toe clearance.	
DSAAC 01/19-11B-42-54	<u>11B-809.10.8.5</u>	Further Study	Accept		Add new Section: Plumbing protection.	
DSAAC 01/19-11B-42-55	<u>11B-809.10.8.6</u>	Further Study	Accept		Add new Section: Controls.	
DSAAC 01/19-11B-42-56	<u>11B-809.10.8.7</u>	Further Study	Accept		Add new Section: Mirrors and towel bars.	
DSAAC 01/19-11B-42-57	<u>11B-809.11</u>	Further Study	Accept		Add new Section: Washing machines and clothes dryers.	
DSAAC 01/19-11B-42-58	<u>11B-809.12</u>	Further Study	Accept		Add new Section: Electrical outlets, controls and switches.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES, AND ELEMENTS.**

Amend Section 11B Electric vehicle charging stations.

Item Number 11B.43	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-43	<b>11B-812.3</b>	Approve as Submitted	Accept		Amend section for consistency with changes in other proposed sections.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES, AND ELEMENTS.**

Amend Section 11B Electric vehicle charging stations.

Item Number 11B.44	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-44	<b>11B-812.7</b>	Approve as Submitted	Accept		Amend section to state the access aisle may be shared between accessible parking space and electric vehicle charging station.	
DSAAC 01/19-11B-44-1	<b>11B-812.7.2</b>	Approve as Submitted	Accept		Amend section to add an exception, parking space and one electric vehicle charging space share access aisle and comply with section 11B-502.3.3.	

**CHAPTER 11B – DIVISION 8: SPECIAL ROOMS, SPACES, AND ELEMENTS.**

Amend Section 11B Electric vehicle charging stations.

Item Number 11B.45	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
DSAAC 01/19-11B-45	<b>11B-812.9</b>	Approve as Submitted	Accept		Amend term “ <del>parking space</del> ” to “vehicle space” for consistency.	