

**COMMISSION ACTION MATRIX
 2019 CALIFORNIA MECHANICAL CODE, TITLE 24, PART 4
 AGENCY: THE OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT [OSHPD 05/19]**

LEGEND:

CAC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve as Amended, Approve as Submitted, Disapprove, Further Study

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

GREEN-PEME AD HOC CODE ADVISORY COMMITTEE

CHAPTER 1 – ADMINISTRATION

DIVISION I – CALIFORNIA ADMINISTRATION

Amend sections listed below

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-1-1	1.10.1 OSHPD 1 and OSHPD 1R., Application.	Approve as Submitted	Accept		Amend code section to add the term “SPC or freestanding” to align with Title24, Part 2.	
OSHPD 05/19-2-1	1.10.4 OSHPD 4., Enforcement agency.	Approve as Submitted	Accept		Amend code section to clarify proper authority having jurisdiction for OSHPD 4 facilities.	

CHAPTER 2 – DEFINITIONS

SECTION 203.0 – A –

Amend sections listed below

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-2-1	Authority Having Jurisdiction. [OSHPD 1, 1R, 2, 3, & 4 & 5]	Approve as Submitted	Accept		Add banners 1R and 5. Repeal banner 4.	

CHAPTER 3 – GENERAL REGULATIONS

Amend sections listed below

Item Number3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-3-1	<u>301.7 OSHPD 1R</u> <u>[OSHPD 1R].</u>	Approve as Submitted	Accept		Add new code section regarding General requirements.	
OSHPD 05/19-3-2	303.2 Closet or Alcove Installations., [OSHPD 1, 1R, 2, 3, 4 & 5], Exception: [OSHPD 1, 1R, 2, 3, 4 & 5]	Approve as Submitted	Accept		Code section is not adopted by OSHPD and repealing banners, text and exception.	
OSHPD 05/19-3-3	<u>306.2 Building Automation Systems.</u> <u>[OSHPD 1]</u>	Approve as Submitted	Accept		Add new code section for Building Automation Systems.	
OSHPD 05/19-3-4	318.2 Services/System and Utilities.	Approve as Submitted	Accept		Amend code section to add a new reference to CBC sections.	
OSHPD 05/19-3-5	320.3.1	Approve as Submitted	Accept		Editorial correction for the term “humidities.”	
OSHPD 05/19-3-6	320.4 Telephone and Technology Equipment Centers Data Equipment Rooms. [OSHPD 1 & 4]	Approve as Submitted	Accept		Amend the code section title.	
OSHPD 05/19-3-7	<u>320.4.4</u>	Approve as Submitted	Accept		Add new code section for Technology Equipment Centers.	
OSHPD 05/19-3-8	321.1	Approve as Submitted	Accept		Amend codes section to add fans in certain areas that are to be on essential power.	

Item Number3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-3-9	321.2	Approve as Submitted	Accept		Amend language to add fans to code section.	
OSHPD 05/19-3-10	<u>323.0 Mechanical Equipment Schedules.</u> <u>[OSHPD 1, 1R, 2, 4 & 5]</u>	Approve as Submitted	Accept		Add new code section for requirements in mechanical equipment schedules on construction documents.	

CHAPTER 4 – VENTILATION AIR

Amend sections listed below

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-4-1	402.0 Ventilation Air. [Not Permitted for OSHPD 1, 2, 3 & 4]	Approve as Submitted	Accept		Amend code Section 402 to repeal the “Not permitted” banner to correct a clerical error in the banner from a previous cycle.	
OSHPD 05/19-4-2	402.1 Occupiable Spaces.	Approve as Submitted	Accept		Add a banner for OSHPD 1, 1R, 2, 3, 4 & 5 facilities with occupiable spaces listed in Table 4-A	
OSHPD 05/19-4-3	402.1.3 Ventilation in Health Care Facilities.	Approve as Submitted	Accept		Amend code section to repeal code language. OSHPD does not adopt this standard	
OSHPD 05/19-4-4	<u>402.1.3(1)</u>	Approve as Submitted	Accept		Add new code subsection to clarify Ventilation rates for areas not specified in Table 4.	
OSHPD 05/19-4-5	402.2 Natural Ventilation.	Approve as Submitted	Accept		Add clarification with a banner stipulating that this code section does not apply to certain OSHPD facilities.	
OSHPD 05/19-4-6	402.3 Mechanical Ventilation.	Approve as Submitted	Accept		Add clarification with a banner stipulating that this code section does not apply to certain OSHPD facilities.	

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-4-7	403.0 Ventilation Rates.	Approve as Submitted	Accept		Add clarification with a banner stipulating that this code section does not apply to certain OSHPD facilities listed in Table 4A.	
OSHPD 05/19-4-8	<u>407.4.1.7 Recirculating Room Units.</u>	Approve as Submitted	Accept		Add this new code subsection for Ventilation System Details.	
OSHPD 05/19-4-9	408.2.2, 408.2.3, 408.2.4	Approve as Submitted	Accept		Amend these code sections to add MERV requirements.	
OSHPD 05/19-4-10	408.3.3	Approve as Submitted	Accept		Amend this code section to add MERV requirements.	
OSHPD 05/19-4-11	411.0 through 417.0	Approve as Submitted	Accept		Repeal 1R banner.	
OSHPD 05/19-4-12	TABLE 4-A	Approve as Submitted	Accept		Amend table to repeal the 100%-outdoor air column. See ET and ISOR.	
OSHPD 05/19-4-13	<i>Notes for Table 4-A; a. & b., f & ab.</i>	Approve as Submitted	Accept		Amend Table 4-A footnotes.	

CHAPTER 5 – EXHAUST SYSTEMS

PART II – COMMERCIAL HOODS AND KITCHEN VENTILATION.

Amend sections listed below

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-5-1	<u>507.7 Pharmaceutical Compounding Exhaust Discharge.</u> [OSHPD 1, 2, 3, 4 & 5]	Approve as Submitted	Accept		Add new code section for Pharmaceutical Compounding Exhaust Discharge.	

CHAPTER 6 – DUCT SYSTEMS

604.0 Insulation of ducts.

Amend sections listed below

Item Number 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-6-1	604.2 [OSHPD 1, 1R, 2, 3 (surgical clinics), 4 & 5]	Approve as Submitted	Accept		Repeal the word “terminal,” for surgical clinics.	

CHAPTER 10 – BOILERS AND PRESSURE VESSELS

1001.2 Boiler rooms and enclosures.

Amend sections listed below

Item Number 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-7-1	<u>1001.2.1</u> <u>[OSHPD 1, 1R, 2, 3, 4, & 5]</u>	Approve as Submitted	Accept		Add new code section to specify requirements to correlate with NFPA 99 for boiler rooms.	

CHAPTER 11 -- REFRIGERATION

1104.0 Requirements for refrigerant and refrigeration system use.

Amend sections listed below

Item Number 8	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 05/19-8-1	1104.3 Institutional Occupancies., [OSHPD 1 & 4] <u>Exception:</u>	Approve as Submitted	Accept		Add new exception for technology equipment centers, OSHPD 1 & 4.	