

COMMISSION ACTION MATRIX -- YELLOW

**2022 CALIFORNIA BUILDING CODE (CBC), TITLE 24, PART 2 VOLUME 1, 2021 INTERNATIONAL BUILDING CODE (IBC)
 AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT (OSHPD 04/21)**

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

HEALTH FACILITIES CODE ADVISORY COMMITTEE – AUGUST 11, 2021

CHAPTER 12 INTERIOR ENVIRONMENT

Item Number 9 through Item Number 38

OSHPD proposes to adopt 2021 IBC Chapter 12 for OSHPD 1, 1R, 2, 3, 4, and 5, and carry forward existing 2019 CBC California amendments with the following modifications listed below:

Item Number 11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-11-0*	1224.4 GENERAL CONSTRUCTION.	*	*	45-Day comment: L. Srebnik, MITA Further Study, Criteria #2	* Subsection was not proposed for amendment this cycle. CAM numbering adjusted to allow Agency Response and Commission action on related items. General comment for further study based on unintended costs and limitations to patient care.	
OSHPD 04/21-11-4	1224.4.4.1.4.1 General. (New)	Approve as Amended	Accept	45-Day comment: L. Wu, Kaiser Permanente Disapprove, Criteria #1	New subsection. General. CAC: AA under criteria #8 - no amendments suggested for this subitem, the only other suggested amendment is in subitem 11-5. 45-Day comment: Item (2) Location. Commenter suggests location requirements of Procedure room conflict with definition of Semi-restricted area.	

Item Number 11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-11-5	1224.4.4.1.4.2 Space requirements. (New)	Approve as Amended	Accept	45-Day comment: L. Srebnik, MITA Approve as Amended, Criteria #8	New subsection. Space requirements. CAC: AA under criteria #8 - suggested to amend (2)(b) to stipulate 6 feet "minimum" dimension. Editorial correction to correct metric conversion. (2) For Procedure rooms/Class 2 Imaging Rooms, Commenter suggests adding an exception from the proposed increased clearance. Please read original comments and FSOR.	

Item Number 14	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-14-3	TABLE 1224.4.11.4a (New)	Approve as Amended	Accept	45-Day comment: P. Hope, MITA Further Study L. Srebnik, MITA Further Study J. Polachowski, Kaiser Permanente (KP), Disapprove, Criteria #6.	OSHPD proposes a new table for room classifications. Approve as Amended, Criteria #6. Post CAC: Punctuation and grammar revisions adding the word "or" regarding the Use column "Invasive procedures." For Operating room and Class 3 imaging room. MITA Commenters are concerned that changes would add financial challenges regarding services provided in imaging rooms. Please read original comments. KP commenter suggests that there are discrepancies regarding the procedures and safety requirements.	

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-16-5	1224.14.2.10 Nourishment area.	Approve	Accept	45-Day comment: A. Alcantara Disapprove, Criteria #6	Editorial amendment. Commenter suggests editorial revision to the requirement in nursing	

Item Number 25	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-25-1	1224.29.2.6 Area.	Approve	Accept	45-Day comment: A. Alcantara Approve as Amended. Criteria #6	Editorial amendment regarding minimum headwall width. Commenter suggests revisions to the clearances and circulation in this section. HCD revised this item and submitted for 15-Day public comment. No comments received.	

Item Number 28	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 04/21-28-1	1224.32.3.2.1 Postpartum bed ratio. Exceptions	Approve	Accept	45-Day comment: A. Alcantara Approve as Amended	Editorial amendment regarding requirements per section 1224.32.3.2. Commenter uncertain as to the specific ratio of postpartum beds.	

[END of CHAPTER 12 Commission Action Items]