

COMMISSION ACTION MATRIX – SALMON

**2022 CALIFORNIA BUILDING CODE, TITLE 24, PART 2 VOLUME 2, 2021 INTERNATIONAL BUILDING CODE
 AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT (OSHPD 06/21)**

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

STRUCTURAL DESIGN/LATERAL FORCES (SDLF) CODE ADVISORY COMMITTEE – JULY 28 & 29, 2021

CHAPTER 19A CONCRETE

Adopt 2021 International Building Code (IBC) Chapter 19A for OSHPD 1 & 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 13	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-13-4	1905A.1.7 ACI 318, Section 14.1.4	Further Study	Withdraw		Bring forward and modify 2021 IBC Chapter 19, Section 1905.1.7 into Chapter 19A and include new amendment for OSHPD 2B regarding plain concrete. Further Study based on Criteria #1. Post CAC: OSHPD Withdraws this amendment. This item is associated with Item 13-0 above.	

CHAPTER 21A MASONRY

Adopt 2021 International Building Code (IBC) Chapter 21A for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-16-11	2105A.4 Masonry core testing. Exceptions:	Approve	Accept	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Disapprove, Criteria #5	Amend Exception 1 in this section to revise design values. Comment: Maintain 2,000 psi minimum design threshold when core testing is required. Post 45-Day: Proposed exception 1 is Withdrawn after 45-Day day comment period.	

CHAPTER 22A STEEL

Adopt 2021 International Building Code (IBC) Chapter 22A for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 18	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-18-3	2213A.2 Tests of end-welded studs.	Further study	Withdraw		Add OSHPD 1 & 4 banner. Further Study based on Criteria #1. Post CAC: Coordinated with DSA. Proposal to add banner is Withdrawn .	

CHAPTER 23 WOOD

Adopt 2021 International Building Code (IBC) Chapter 22 for OSHPD 1, 1R, 2, 4 and 5, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-19-1	2303.1.3.1 Additional requirements. (Repealed)	Disapprove	Withdraw		Add referenced to Section 1705A.5.4. Further Study based on Criteria #6, 7, 8. Post CAC: Coordinated with DSA. Proposal to repeal this section is Withdrawn .	