

APPROVED BY THE CALIFORNIA BUILDING STANDARDS COMMISSION JANUARY 18, 2022

COMMISSION ACTION MATRIX – SOS Filing

2022 CALIFORNIA BUILDING CODE, TITLE 24, PART 2 VOLUME 2, 2021 INTERNATIONAL BUILDING CODE

AGENCY: OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT (OSHPD 06/21)

LEGEND:

CAC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Agency Responses: Accept, Disagree, Withdraw

CBSC Actions: Approve, Disapprove, Approve as Amended, Further Study Required

Matrix Paper Color (for commission action only): GREEN = uncontested items, YELLOW = challenged items, SALMON = withdrawn, no action required

STRUCTURAL DESIGN/LATERAL FORCES (SDLF) CODE ADVISORY COMMITTEE – JULY 28 & 29, 2021

CHAPTER 16 STRUCTURAL DESIGN

Adopt 2021 International Building Code (IBC) Chapter 16 for OSHPD 1R, 2, 3 and 5 and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 1	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-1-1	1605.2 (Formerly 1605A.3.2)	Approve	Accept		Amend section regarding load combinations.	Approve
OSHPD 06/21-1-2	TABLE 1613.2.3(1), footnote c	Approve	Accept		Amend Table and footnote c regarding ASCE 7.	Approve
OSHPD 06/21-1-3	TABLE 1613.2.3(2), footnote c	Approve	Accept		Amend Table and footnote c regarding ASCE 7.	Approve

CHAPTER 16A STRUCTURAL DESIGN

Adopt 2021 International Building Code (IBC) Chapter 16A for OSHPD 1 and 4 and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-2-1	1605A.2 (Formerly 1605A.3.2)	Approve	Accept		Amend section regarding ASCE 7 and load combinations.	Approve
OSHPD 06/21-2-2	1605A.3 (Renumbered)	Approve	Accept		Renumber sub sections per model code revisions.	Approve
OSHPD 06/21-2-3	1605A.3.1 (Renumbered)	Approve	Accept		Renumber sub sections per model code revisions.	Approve

Item Number 2	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-2-4	1605A.3.2 (Renumbered)	Approve	Accept		Renumber sub sections per model code revisions.	Approve
OSHPD 06/21-2-5	1606A.6 (Renumbered)	Approve	Accept		Renumber sub sections per model code revisions.	Approve
OSHPD 06/21-2-6	1607A.14.4.5 (Renumbered)	Approve	Accept		Renumber sub sections per model code revisions.	Approve
OSHPD 06/21-2-7	1607A.14.5 (Renumbered)	Approve	Accept		Renumber sub sections per model code revisions.	Approve
OSHPD 06/21-2-8	1607A.16 (Renumbered)	Approve	Accept		Model code Section renumbered. Editorial revision regarding allowable stress design.	Approve
OSHPD 06/21-2-9	1607A.19	Approve	Accept		Editorial revision regarding reference to Section 1605.3 for load combinations.	Approve
OSHPD 06/21-2-10	TABLE 1613.2.3(1), footnote c	Approve	Accept		Amend Table and footnote c regarding ASCE 7.	Approve
OSHPD 06/21-2-11	TABLE 1613.2.3(2), footnote c	Approve	Accept		Amend Table and footnote c regarding ASCE 7.	Approve

CHAPTER 16A STRUCTURAL DESIGN

Adopt 2021 International Building Code (IBC) Chapter 16A for OSHPD 1 and 4 with the following modifications:

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-3-1	1617A.1.3 (Formerly Reserved)	Approve	Accept		Proposed new amendment to section regarding ASCE 7, Section 11.4 and load combinations. Coordinate hyphen in term "multi-period."	Approve
OSHPD 06/21-3-2	1617A.1.5 ASCE 7, (New)	Approve	Accept		Proposed new amendment.	Approve
OSHPD 06/21-3-3	1617A.1.5.1 ASCE 7, Section 12.2.3. (New)	Approve	Accept		Proposed new amendment.	Approve
OSHPD 06/21-3-4	1617A.1.5.2 (Formally 1617A.1.5)	Approve	Accept		Reformat and revise number sub sections per proposed new amendments.	Approve

Item Number 3	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-3-5	1617A.1.5.3 ASCE 7, Section 12.2.3.2. (New)	Approve	Accept		OSHPD proposes amending this subsection regarding ASCE 7, Section 12.2.3.2 item a and adding items f, g and h. OSHPD proposes to relocate 1617A1.6, requirement f to 1617A.1.5.3 as item h. Post CAC: OSHPD Banner moved to end of line item f.	Approve
OSHPD 06/21-3-6	1617A.1.6 Reserved	Approve	Accept		Proposes to have Section 1617A.1.6 Reserved.	Approve
OSHPD 06/21-3-7	1617A.1.10, ASCE 7, Section 12.3.3.1. Exceptions:	Approve	Accept		OSHPD Proposes Exception 2 regarding structures having horizontal structural irregularities.	Approve
OSHPD 06/21-3-8	1617A.1.14 (Formally Reserved)	Approve	Accept		Repeal "Reserved" and relocate amendment text from 1617A.1.15.	Approve
OSHPD 06/21-3-9	1617A.1.15 ASCE 7, Section 12.13.1. (Renumbered)	Approve	Accept		Renumber 1617A.1.16 to 1617A.1.15.	Approve
OSHPD 06/21-3-10	1617A.1.16 ASCE 7, Section 12.13.9.2.	Approve	Accept		OSHPD proposes to modify ASCE 7 section 12.13.9.2 and amend item b.	Approve
OSHPD 06/21-3-11	1617A.1.18 ASCE 7, Section 13.1.4.	Approve	Accept		Renumbering ASCE section and revise OSHPD banner to remove 1R. Add Item 10.	Approve
OSHPD 06/21-3-12	1617A.1.26 ASCE 7, Section 13.6.7.3.	Approve	Accept		Amend Item 1.	Approve
OSHPD 06/21-3-13	1617A.1.27 ASCE 7, Section 13.6.11.1.1	Approve	Accept		Amend regarding elevator guide rail supports and allowable stress design load.	Approve
OSHPD 06/21-3-14	1617A.1.28 ASCE 7, Section 13.6.11.4	Approve	Accept		Amend Item 1 and Item 6 regarding retainer plates and allowable stress design load.	Approve

CHAPTER 17 SPECIAL INSPECTIONS AND TESTS

Adopt 2021 International Building Code (IBC) Chapter 17 for OSHPD 1R, 2 and 5 with the following modifications:

Item Number 4	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-4-1	1705.3.9 Shotcrete. (Formerly 1705.19)	Approve	Accept		Reformat and revise numbered sub sections.	Approve
OSHPD 06/21-4-2	1705.3.9.1 (Formerly 1705.19.1)	Approve	Accept		Reformat and revise numbered sub sections.	Approve
OSHPD 06/21-4-3	1705.3.9.2 (New)	Further Study	Accept		Proposed new amendment regarding shotcrete mockup test panels. CAC Criteria #1. Post CAC: Sentence relocated regarding No. 5 bars. Coordinated with DSA.	Approve
OSHPD 06/21-4-4	1705.5.5, Exception (Renumbered)	Approve	Accept		Reformat and revise numbered sub sections per proposed new amendment to the exception regarding laminated timber inspections. Post Public Comment Periods: OSHPD corrected the Express Terms text to align with <i>Section 17055A.5.5</i> .	Approve

CHAPTER 17A SPECIAL INSPECTIONS AND TESTS

Adopt 2021 International Building Code (IBC) Chapter 17A for OSHPD 1 and 4 with the following modifications:

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-5-1	1704A.5	Approve	Accept		Editorial revisions to coordinate with model code reformatting and renumbering. Amend references in Items 4 and 7.	Approve
OSHPD 06/21-5-2	1705A.2.1 Structural steel.	Approve	Accept		Editorial amendments.	Approve
OSHPD 06/21-5-3	TABLE 1705A.2.1	Further Study	Accept		Proposed new amendments revising Tables 1705A2.1 and Table 1705A3. Amend footnote a to correct reference to Section 1705A.13. CAC Criteria #1. Post CAC: Item 1c CBC reference re-sequenced in table cell.	Approve
OSHPD 06/21-5-4	TABLE 1705A.2.3	Approve	Accept		Amend footnote a to correct reference to Section 1705A.13.	Approve

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-5-5	1705A.2.5	Approve	Accept		Editorial amendment.	Approve
OSHPD 06/21-5-6	1705A.2.6	Further study	Accept		Editorial amendment. Criteria #1. CAC Post CAC: Rearranged item 1.c CBC references, for Section 1705A.2.6 by adding OSHPD banner. Coordinated with DSA.	Approve
OSHPD 06/21-5-7	TABLE 1705A.3	Approve	Accept		Proposed new amendments revising Tables 1705A2.1 and Table 1705A3. Post CAC: CAC recommendation for editorial correction to section reference in item 14 in the table.	Approve
OSHPD 06/21-5-8	1705A.3.2 Material tests.	Approve	Accept		Editorial amendment and revised code reference.	Approve
OSHPD 06/21-5-9	1705A.3.9 Shotcrete. (Formerly 1705A.19)	Approve	Accept		Reformat and revise numbered sub sections.	Approve
OSHPD 06/21-5-10	1705A.3.9.1 (Formerly 1705A.19.1)	Approve	Accept		Reformat and revise numbered sub sections.	Approve
OSHPD 06/21-5-11	1705A.3.9.2 Preconstruction tests. (New)	Further Study	Accept		Proposed new amendment regarding shotcrete mockup test panels. Relocated requirements from deleted model code and incorporation of amendments Chapters 19 and 19A. Criteria #1. CAC Post CAC: Coordinated with DSA. Reformat of sentence regarding No. 5 rebar.	Approve
OSHPD 06/21-5-12	1705A.5.3 Mass timber construction.	Approve	Accept		Editorial amendment.	Approve
OSHPD 06/21-5-13	TABLE 1705A.5.3	Approve	Accept		Editorial amendment to denote A in the Title for Table 1705A.5.3.	Approve
OSHPD 06/21-5-14	TABLE 1705A.5.3	Approve	Accept		Relocating 3.1-3.5 item numbering from repealed Table 1705A.5.7.	Approve

Item Number 5	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-5-15	1705A.5.5 (Renumbered)	Approve	Accept		Reformat and revise numbered sub sections per proposed new amendment to the exception regarding laminated timber inspections.	Approve
OSHPD 06/21-5-16	1705A.5.7 (Repealed)	Approve	Accept		Repeal of Mass Timber and Tall Wood California amendments to coordinate with other agencies and the 2021 ICC model adoption of those provisions.	Approve
OSHPD 06/21-5-17	TABLE 1705A.5.7 (Repealed)	Approve	Accept		Repeal of Mass Timber and Tall Wood amendment – adopt model.	Approve
OSHPD 06/21-5-18	1705A.6.3 Vibro stone columns.	Approve	Accept		Amend section reference.	Approve
OSHPD 06/21-5-19	1705A.8.1 Micropile tests. (New)	Approve	Accept		New amendment.	Approve
OSHPD 06/21-5-20	1705A.9.1 Helical pile tests. (New)	Approve	Accept		New amendment.	Approve
OSHPD 06/21-5-21	1705A.10	Approve	Accept		Editorial renumbering amendment to denote A for this section in Chapter 17A.	Approve
OSHPD 06/21-5-22	1705A.13.4 (Renumbered)	Approve	Accept		Renumber and amend section reference.	Approve
OSHPD 06/21-5-23	1705A.13.5 (Renumbered)	Approve	Accept		Renumbered.	Approve
OSHPD 06/21-5-24	1705A.13.5.1 (Renumbered)	Approve	Accept		Renumbered.	Approve
OSHPD 06/21-5-25	1705A.13.5.2 (New)	Approve	Accept		New amendment.	Approve
OSHPD 06/21-5-26	1705A.13.14.2 (Renumbered)	Approve	Accept		Renumbered.	Approve
OSHPD 06/21-5-27	1705A.13.14.2.1 (New)	Approve	Accept		New amendment regarding structural sealant glazing testing .	Approve
OSHPD 06/21-5-28	1705A.20 (Repealed)	Approve	Accept		Repeal of Mass Timber and Tall Wood amendment – adopt model.	Approve

CHAPTER 18 SOILS AND FOUNDATIONS

Adopt 2021 International Building Code (IBC) Chapter 18 for OSHPD 1R, 2 and 5 and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 6	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-6-1	1810.3.1.5.1.	Approve	Accept		Amend section regarding helical piles and seismic requirements.	Approve
OSHPD 06/21-6-2	1810.3.3.1.9 Helical piles., #3	Approve	Accept		Amend #3 to include OSHPD banners.	Approve
OSHPD 06/21-6-3	1810.3.8 Precast concrete Piles. Exceptions	Approve	Accept		Amend Exceptions to include OSHPD banners. Relocate Exception from 1810.3.8.3.4.	Approve
OSHPD 06/21-6-4	1810.3.10.4.1 Seismic requirements.	Approve	Accept		Editorial amendment and code reference update.	Approve
OSHPD 06/21-6-5	1810.3.11.2 Seismic Design Categories D through F.	Approve	Accept		Amend #3 Exception 2 to include OSHPD banners. Post CAC: OSHPD coordinated location of banner.	Approve
OSHPD 06/21-6-6	1810.3.12 Grade beams.	Approve	Accept		Amend Exception to include OSHPD banners and reference to ACI standards.	Approve
OSHPD 06/21-6-7	1811.3 Geotechnical requirements.	Approve	Accept		Amend Item 7 to include 2 year compliance to corrosion requirement.	Approve
OSHPD 06/21-6-8	1811.4 Structural Requirements.	Approve	Accept		Amend Item 3 to include reference to ASCE 7.	Approve
OSHPD 06/21-6-9	1812.4.1	Approve	Accept		Amend Item 6 extend temporary anchor service life.	Approve
OSHPD 06/21-6-10	1812.4.2	Approve	Accept		Amend Item 2 to include reference to ASCE 7 for structural requirements.	Approve

CHAPTER 18A SOILS AND FOUNDATIONS

SECTION 1807A FOUNDATION WALLS, RETAINING WALLS AND EMBEDDED POSTS AND POLES

SECTION 1808A FOUNDATIONS

Adopt 2021 International Building Code (IBC) Chapter 18A, *Sections 1807A and 1808A* for OSHPD 1 and 4 and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-7-1	1807A.2.5 (Renumbered)	Approve	Accept		Renumber and update reference to ASCE 7, Section 15.6.8 and add OSHPD banners.	Approve

Item Number 7	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-7-2	1808A.8.2 Concrete cover.	Approve	Accept		Update reference to Standard ACI 318, Section 20.5.1.3.5.	Approve
OSHPD 06/21-7-3	TABLE 1808A.8.2	Approve	Accept		Update references to Standard ACI 318.	Approve

**CHAPTER 18A SOILS AND FOUNDATIONS
SECTION 1810A DEEP FOUNDATIONS**

Adopt 2021 International Building Code (IBC) Chapter 18A, *Section 1810A* for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 8	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-8-1	1810A.3.1.5.1. 1810A.3.3.1.9	Approve	Accept		Editorial update regarding helical piles and seismic requirements in section 1617A.1.15 and repeal part of item 3.	Approve
OSHPD 06/21-8-2	1810A.3.6 Splices.	Approve	Accept		Repeal Exception.	Approve
OSHPD 06/21-8-3	1810A.3.8 Precast concrete piles.	Approve	Accept		Repeal Exceptions. Relocate Exception from 1810A.3.8.3.4.	Approve
OSHPD 06/21-8-4	1810.3.8.1 Reinforcement. (Repealed)	Approve	Accept		Repeal subsection.	Approve
OSHPD 06/21-8-5	1810A.3.9.4	Approve	Accept		Repeal reference to Design Category C and Section 1810A.3.9.4.1.	Approve
OSHPD 06/21-8-6	1810A.3.9.4.1	Approve	Accept		Repeal model reference to Design Category C.	Approve
OSHPD 06/21-8-7	1810A.3.10.4 Seismic requirements.	Approve	Accept		Editorial revisions and update reference to ACI Standard 318, Section 18.13.5	Approve
OSHPD 06/21-8-8	1810A.3.11.2 Seismic Design Categories D through F.	Approve	Accept		Amend compliance requirement #3 to repeal Exception #2.	Approve
OSHPD 06/21-8-9	1810A.3.12 Grade beams.	Approve	Accept		Amend Exception to include reference to ACI Standard 318, Section 18.13.3.	Approve

CHAPTER 18A SOILS AND FOUNDATIONS

SECTION 1811A PRESTRESSED ROCK AND SOIL FOUNDATION ANCHORS

Adopt 2021 International Building Code (IBC) Chapter 18A, *Section 1811A* for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 9	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-9-1	1811A.3 Geotechnical requirements.	Approve	Accept		Amend Item 7 to include 2 year compliance to corrosion requirement.	Approve
OSHPD 06/21-9-2	1811A.4 Structural Requirements.	Approve	Accept		Amend Item 3 to include reference to ASCE 7.	Approve

CHAPTER 18A SOILS AND FOUNDATIONS

SECTION 1812A EARTH RETAINING

Adopt 2021 International Building Code (IBC) Chapter 18A, *Section 1812A* for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 10	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-10-1	1812A.4.1	Approve	Accept		Amend Item 6 extend temporary anchor service life.	Approve
OSHPD 06/21-10-2	1812A.4.2	Approve	Accept		Amend Item 2 to include reference to ASCE 7 for structural requirements.	Approve
OSHPD 06/21-10-3	1812A.4.3	Approve	Accept		Relocate Items 2 and 3 to Section 1812A.5, Items 15 and 16, respectively.	Approve
OSHPD 06/21-10-4	1812A.5	Approve	Accept		Amend item 13 to reference Section 1812A.4.1, Item 7. Relocate Items 2 and 3 to Section 1812A.5, Items 15 and 16, respectively.	Approve
OSHPD 06/21-10-5	1812A.6	Approve	Accept *		Amend section regarding periodic visits to job sites. * Post CAC: Disagree with CAC approval. In further review and coordination, OSHPD requested (and DSA agreed) to remove a phrase from the Express Terms based on Criteria #1 and related to other CAC recommendations for Further Study. See Section 1910A.5.5.	Approve
OSHPD 06/21-10-6	1812A.7	Approve	Accept		Repeal adoption and remove banners from Section 1812A.7.	Approve

CHAPTER 18A SOILS AND FOUNDATIONS

SECTION 1813A VIBRO STONE COLUMNS FOR GROUND IMPROVEMENT

Adopt 2021 International Building Code (IBC) Chapter 18A, Section 1813A for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 11	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-11-1	1813A.3	Approve	Accept		Amend Item 2 to repeal phrase referring to deep foundation elements.	Approve
OSHPD 06/21-11-2	1813A.5	Approve	Accept		Add Item 6 regarding reference to Section 1813A.2, Item 9.	Approve

CHAPTER 19 CONCRETE

Adopt 2021 International Building Code (IBC) Chapter 19 for OSHPD 1R, 2 and 5, and carry forward existing 2019 CBC amendments with the following modifications

Item Number 12	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-12-1	1901.3.4.3 Test Frequency, Exceptions	Further Study	Accept		Amend Section to include new Exception Item 6, OSHPD 2B. Further Study based on Criteria #6. Post CAC: Re-word amendment for clarity regarding grammar and intent to align with DSA amendment.	Approve
OSHPD 06/21-12-1.1	1901.3.4.5 1901.3.4.5 Test acceptance criteria.	Approve	Accept		Amend Section regarding anchor embedment depth and add a new Exception under #1 Hydraulic ram method. Item 12.1 added during CAC.	Approve
OSHPD 06/21-12-2	1905.1.7 ACI 318, Section 14.1.4	Approve	Accept		Add OSHPD banners. New amendment regarding plain concrete.	Approve
OSHPD 06/21-12-3	1908.1 General.	Approve	Accept		Amend Item 6 to include reference to ACI for structural requirements. Post CAC: Include <i>ACI</i> to reference 506.4R.	Approve
OSHPD 06/21-12-4	1908.2 Tests and Inspections. (New)	Approve	Accept		New amendment to section regarding shotcrete application and references to ACI 318 standards.	Approve
OSHPD 06/21-12-5	1908.3 (Renumbered)	Approve	Accept		Renumbered from 1908.11.	Approve
OSHPD 06/21-12-6	1908.12 Placing. [OSHPD 1R, 2 & 5] (Repealed)	Approve	Accept		Repeal subsection.	Approve
OSHPD 06/21-12-7	1910.3.4 ACI 318, Table 21.2.2.	Approve	Accept		Amend Table 21.2.2 for Net tensile strain. Amend footnote 2	Approve

CHAPTER 19A CONCRETE

Adopt 2021 International Building Code (IBC) Chapter 19A for OSHPD 1 & 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 13	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-13-0*	1901A.2 Reinforced concrete.	*	*		* This item was not reviewed by CAC. Post CAC: OSHPD coordination effort with DSA as part of Further Study of sub-items in Item 13. OSHPD has added this section to the Express Terms. BSC has assigned an Item number to include this section for review by the Commission. Associated with Item 13-4 below.	Approve
OSHPD 06/21-13-0.1*	1903A.2 Special inspections.	Approve	Accept		* Item was a correction to CAM discussed at CAC and Approve as Submitted. Post CAC: No amendment is proposed. BSC has assigned an Item number to match Express Terms.	Approve
OSHPD 06/21-13-1	1903A.8	Approve	Accept		Update ACI 318 reference from Section 26.6.4.1(b) to Section 26.6.4.2(b)	Approve
OSHPD 06/21-13-2	1905A.1 General.	Approve	Accept		Update reference from Section 1905A.1.15 to Section 1905A.1.17.	Approve
OSHPD 06/21-13-3	1905A.1.3 ACI 318, Section 9.6.1.3.	Approve	Accept		Modify format and amend section to add Items 1 and 2.	Approve
OSHPD 06/21-13-4	1905A.1.7 ACI 318, Section 14.1.4	Further Study	Withdraw		Bring forward and modify 2021 IBC Chapter 19, Section 1905.1.7 into Chapter 19A and include new amendment for OSHPD 2B regarding plain concrete. Further Study based on Criteria #1. Post CAC: OSHPD Withdraws this amendment. This item is associated with Item 13-0 above.	No Action Taken
OSHPD 06/21-13-4.1*	1905A.1.8 ACI 318, Section 17.10.	*	*		* Post CAC: BSC added this item to the CAM to coordinate with the Express Terms. BSC has assigned an Item number to include this section for a correction to a referenced section in ACI 318.	Approve
OSHPD 06/21-13-5	1905A.1.9 1905A.1.10 1905A.1.11 (Renumbered)	Approve	Accept		Renumber from_1905A.1.10 to 1905A.1.9 Renumber from_1905A.1.11 to 1905A.1.10 Renumber from_1905A.1.12 to 1905A.1.11.	Approve

Item Number 13	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-13-6	1905A.1.12 ACI 318, Section 19.2.1.1 and Table 19.2.1.1. Renumbered)	Approve	Accept		Renumber from <i>1905A.1.9</i> to <i>1905A.1.12</i> . Reorganization of provisions.	Approve
OSHPD 06/21-13-7	1905A.1.13 ACI 318, Table 21.2.2	Approve	Accept		Amend Table 21.2.2 for Net tensile strain. Amend footnote 2	Approve
OSHPD 06/21-13-8	1905A.1.15 ACI 318, Section 25.2.10.	Approve	Accept		Language added back in regarding previously deleted language from IBC for spirally tied rebar in columns.	Approve
OSHPD 06/21-13-9	1905A.1.16 ACI 318, Section 26.5.2.	Approve	Accept		Text Relocated from 2019 CBC 1908A.7 Text Relocated from 2019 CBC 1908A.1	Approve
OSHPD 06/21-13-9.1	1905A.1.17 ACI 318, Section ACI 318, Section 26.12.2.1(a). (Renumbered)	Approve	Accept		Renumber from <i>1905A.1.15</i> to <i>1905A.1.17</i> .	Approve
OSHPD 06/21-13-10	1908A.1 General.	Approve	Accept		Amend Item 6 to include reference to ACI for structural requirements.	Approve
OSHPD 06/21-13-11	1908A.2 Tests and Inspections. (New)	Approve	Accept		New amendment to section regarding shotcrete application and references to ACI 318 standards.	Approve
OSHPD 06/21-13-12	1908A.3 (Renumbered)	Approve	Accept		Editorial reformatting. Renumbered from <i>1908A.11</i> .	Approve
OSHPD 06/21-13-13	1908A.12 Placing. [OSHPD 1R, 2 & 5] (Repealed)	Approve	Accept		Repeal subsection.	Approve
OSHPD 06/21-13-14	1910A.5.3, Test frequency. Exception 6. (New)	Further Study	Accept		New amendment to section to add Exception 6 with OSHPD 4 banner regarding tension testing and post installed anchors. Further Study based on Criteria #6. Post CAC: Re-word amendment for clarity regarding grammar and intent to align with DSA amendment.	Approve
OSHPD 06/21-13-15	1910A.5.5 Test acceptance criteria.	Further Study	Accept		Amend section and add Exception regarding adhesive anchors and documentation of compliance with ACI 318 on construction drawings. Further Study based on Criteria #1. Post CAC: Re-word amendment for clarity regarding grammar and intent to align with DSA amendment.	Approve

CHAPTER 20 ALUMINUM

Adopt 2021 International Building Code (IBC) Chapter 20 for OSHPD 1R, 2, 4 and 5, and carry forward existing 2019 CBC amendments without modifications.

Item Number 14	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-14-1	CHAPTER 20	Approve	Accept		Adopt 2021 Chapter 20 and carry forward 2019 CBC amendments without modifications.	Approve

CHAPTER 21 MASONRY

Adopt 2021 International Building Code (IBC) Chapter 21 for OSHPD 1R, 2, 4 and 5, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 15	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-15-1	2101.2.2 Prohibition.	Approve	Accept		Add reference to TMS402/602.	Approve
OSHPD 06/21-15-2	2103.1	Approve	Accept		Relocated OSHPD bannered amendment from 2104.1.	Approve
OSHPD 06/21-15-3	2103.4	Approve	Accept		Add bannered OSHPD amendment.	Approve
OSHPD 06/21-15-4	2103.5	Approve	Accept		OSHPD proposes to strike stipulation of compliance.	Approve
OSHPD 06/21-15-5	2104.1	Approve	Accept		Relocate OSHPD bannered amendment from 2103.1.	Approve
OSHPD 06/21-15-6	2104.2 Reinforced Grouted masonry.	Approve	Accept		Add term "Reinforced" to section title.	Approve
OSHPD 06/21-15-7	2104.2.1 through 2104.2.5	Approve	Accept		OSHPD proposes to amend TMS402/602 by reorganizing these sections. See ISOR.	Approve
OSHPD 06/21-15-8	2105.2 Compressive Strength	Approve	Accept	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Approve as Amended, Criteria #5	Amend this section to update and revise references to TMS 602 Article 1.4 B.3. Comment from Masonry Institute of America and Concrete Masonry Assoc of California and Nevada (MIA, CMA-CA-NEV). Maintain 2,000 psi minimum design threshold when prism testing is required.	Approve
OSHPD 06/21-15-9	2105.3 Mortar and grout tests.	Further Study	Accept		Amend this section to update and revise references to various TMS and ASTM standards. Further Study based on Criteria #1. Post CAC: Coordinate language of amendment with DSA. Coordinate with CAM Item 16-10 below.	Approve

Item Number 15	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-15-10	2105.4 Masonry core testing.	Approve	Accept	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Disapprove, Criteria #5	Amend Exception 1 in this section to revise design values. Comment Maintain 2,000 psi minimum design threshold when core testing is required.. Item regarding the exception is withdrawn post 45-Day at 15-Day. Amendment to include OSHPD 2B in subsection banner remains.	Approve
OSHPD 06/21-15-11	2105.5 Masonry prism method testing. Repealed	Approve	Accept		OSHPD proposes to repeal this section. See ISOR.	Approve
OSHPD 06/21-15-12	2105.6 Unit strength method testing.	Approve	Accept		OSHPD proposes to repeal this section. See ISOR.	Approve
OSHPD 06/21-15-13	2106.1 through 2106.1.3	Approve	Accept		OSHPD proposes to amend TMS402/602 by reorganizing these sections. See ISOR.	Approve
OSHPD 06/21-15-14	2107.1 General.	Approve	Accept		Revise section numbering.	Approve
OSHPD 06/21-15-15	2107.5	Approve	Accept		OSHPD proposes to amend TMS402/602 by reorganizing this section. See ISOR.	Approve
OSHPD 06/21-15-16	2107.7 Masonry Compressive Strength. (New)	Approve	Accept		New amendment. Include text from 2105.2.	Approve
OSHPD 06/21-15-17	2108.1 General.	Approve	Accept		Editorial revision and OSHPD proposes to delete model Exception regarding compliance to specific standards.	Approve
OSHPD 06/21-15-18	2108.4	Approve	Accept		Amend TMS402/602 to include revised strength values and text from Section 2105.2.	Approve

CHAPTER 21A MASONRY

Adopt 2021 International Building Code (IBC) Chapter 21A for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-16-1	2101A.3 Prohibition.	Approve	Accept		Add reference to TMS402/602.	Approve
OSHPD 06/21-16-2	2103A.1	Approve	Accept		Relocated amendment from 2104A.1.	Approve

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-16-3	2103A.4	Approve	Accept		Amend section regarding bar reinforcement.	Approve
OSHPD 06/21-16-4	2103A.5	Approve	Accept		OSHPD proposes to strike stipulation of compliance.	Approve
OSHPD 06/21-16-5	2104A.1	Approve	Accept		Relocate amendment from 2103A.1.	Approve
OSHPD 06/21-16-7	2104A.2 Reinforced Grouted masonry.	Approve	Accept		Add term "Reinforced" to section title.	Approve
OSHPD 06/21-16-8	2104A.1.3.1 through 2104A.1.3.11.2	Approve	Accept		OSHPD proposes to amend TMS402/602 by reorganizing these sections. See ISOR.	Approve
OSHPD 06/21-16-9	2105A.2 Compressive Strength . . .	Approve	Accept	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Approve as Amended, Criteria #5 15-Day comment: G. Acero & C. Briceno SEAOSC Seismology Committee Approve as Amended, Criteria #1	Amend this section to update and revise references to TMS 602 Article 1.4 B.3. Comment from Masonry Institute of America and Concrete Masonry Assoc of California and Nevada (MIA, CMA-CA-NEV). Maintain 2,000 psi minimum design threshold. when prism testing is required. SEAOSC comment regarding applicability of Seismic Design Categories D, E or F.	Approve
OSHPD 06/21-16-10	2105A.3 Mortar and grout tests.	Further Study	Accept		Amend this section to update and revise references to various TMS and ASTM standards. Further Study based on Criteria #1. Post CAC: Coordinate language of amendment with DSA. Coordinate with CAM Item 15-9 above.	Approve
OSHPD 06/21-16-11	2105A.4 Masonry core testing. Exceptions:	Approve	Accept	45-Day comment: J. Chrysler, K. Siggard (MIA, CMA-CA-NEV) Disapprove, Criteria #5	Amend Exception 1 in this section to revise design values. Comment: Maintain 2,000 psi minimum design threshold when core testing is required. Post 45-Day: Proposed exception is Withdrawn after 45 Day comment period.	No Action Taken
OSHPD 06/21-16-12	2105A.5 Masonry prism method testing. (Repealed)	Approve	Accept		OSHPD proposes to repeal this section. See ISOR.	Approve

Item Number 16	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-16-13	2105A.6 Unit strength method testing. (Repealed)	Approve	Accept		OSHPD proposes to repeal this section. See ISOR.	Approve
OSHPD 06/21-16-14	2106A.1 through 2106A.1.3	Approve	Accept		OSHPD proposes to amend TMS402/602 by reorganizing these sections. See ISOR.	Approve
OSHPD 06/21-16-15	2107A.4 TMS 402, Section 8.3.4.4 Walls.	Approve	Accept		OSHPD proposes to reorganize this section to coordinate with revised standard. See ISOR.	Approve
OSHPD 06/21-16-16	2107A.6 Masonry Compressive Strength. (New)	Approve	Accept		New amendment. Include text from 2105A.2.	Approve
OSHPD 06/21-16-17	2108A.1 General.	Approve	Accept		Editorial revision and OSHPD proposes to delete model Exception regarding compliance to specific standards.	Approve
OSHPD 06/21-16-18	2108A.4	Approve	Accept		New amendment to TMS402/602 in this section to include revised strength values and text from Section 2105A.2.	Approve

CHAPTER 22 STEEL

Adopt 2021 International Building Code (IBC) Chapter 22 for OSHPD 1R, 2 and 5, and carry forward existing 2019 CBC amendments without modifications.

Item Number 17	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-17-1	CHAPTER 22	Approve	Accept		Adopt 2021 Chapter 22 and carry forward 2019 CBC amendments without modifications.	Approve

CHAPTER 22A STEEL

Adopt 2021 International Building Code (IBC) Chapter 22A for OSHPD 1 and 4, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 18	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-18-1	2211A.1.3 Truss design.	Approve	Accept		Amend section regarding engineering analysis.	Approve
OSHPD 06/21-18-2	2213A.1	Further study	Accept		Add reference to Section 1705A.2.6. Further Study based on Criteria #1. Post CAC: Coordinated with DSA to add OSHPD banner.	Approve

Item Number 18	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-18-3	2213A.2 Tests of end-welded studs.	Further study	Withdraw		Add OSHPD 1 & 4 banner. Further Study based on Criteria #1. Post CAC: Coordinated with DSA. Proposal to add banner is Withdrawn .	No Action Taken

CHAPTER 23 WOOD

Adopt 2021 International Building Code (IBC) Chapter 22 for OSHPD 1, 1R, 2, 4 and 5, and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 19	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-19-1	2303.1.3.1 Additional requirements. (Repealed)	Disapprove	Withdraw		Add referenced to Section 1705A.5.4. Further Study based on Criteria #6, 7, 8. Post CAC: Coordinated with DSA. Proposal to repeal this section is Withdrawn .	No Action Taken
OSHPD 06/21-19-2	2304.10.1.2 (Repealed)	Approve	Accept		Repeal amendment. Adopt model.	Approve
OSHPD 06/21-19-3	2304.10.2.1 (Renumbered)	Approve	Accept		Renumber from 2304.10.1.1 to 2304.10.2.1	Approve

CHAPTER 24 GLASS AND GLAZING

Adopt 2021 International Building Code (IBC) Chapter 24 for OSHPD 2, and Chapter 24 for OSHPD 1, 1R, 4, and 5 and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 20	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-20-1	2410.1.2 Testing and inspection. Item #1	Approve	Accept		Renumber items and amend #1 to include relocated amendment from Section 2410.1.2.f.	Approve
OSHPD 06/21-20-2	2410.1.3 Monitoring.	Approve	Accept		Update and revise references to include ASTM C1394.	Approve
OSHPD 06/21-20-3	2410.1.4 Construction documents.	Approve	Accept		Add Item 15 with reference to Section 2410.1.3.	Approve

CHAPTER 25 GYPSUM BOARD, GYPSUM PANEL PRODUCTS AND PLASTER

Adopt 2021 International Building Code (IBC) Chapter 25 for OSHPD 1, 1R, 2, 4, and 5 and carry forward existing 2019 CBC amendments without modifications.

Item Number 21	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-21-1	CHAPTER 25	Approve	Accept		Adopt IBC Chapter 25 and carry forward 2019 CBC existing amendments without modifications.	Approve

CHAPTER 26 PLASTIC

Adopt 2021 International Building Code (IBC) Chapter 26 for OSHPD 1, 1R, 2, 3, 4, and 5 and carry forward existing 2019 CBC amendments without modifications.

Item Number 22	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-22-1	CHAPTER 26	Approve	Accept		Adopt IBC Chapter 26 and carry forward 2019 CBC existing amendments without modifications.	Approve

CHAPTER 27 ELECTRICAL**CHAPTER 28 MECHANICAL SYSTEMS****CHAPTER 29 PLUMBING SYSTEMS**

OSHPD does not adopt 2021 International Building Code (IBC) Chapters 27, 28, 29.

Item Number 23	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-23-1	CHAPTER 27 CHAPTER 28 CHAPTER 29	Approve	Accept		OSHPD does not adopt 2021 International Building Code (IBC) Chapters 27, 28, 29.	Approve

CHAPTER 30 ELEVATORS AND CONVEYING SYSTEMS

Adopt 2021 International Building Code (IBC) Chapter 30 for OSHPD 1R, 2, 4 and 5, and carry forward existing 2019 CBC amendments for OSHPD 1 without modifications.

Item Number 24	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-24-1	CHAPTER 30	Approve	Accept		Adopt Chapter 30 and carry forward 2019 CBC existing amendments without modification.	Approve

CHAPTER 31 SPECIAL CONSTRUCTION

Adopt 2021 International Building Code (IBC) Chapter 31 for OSHPD 1R, 2, 3, 4 and 5 with a new amendment as follows:

Item Number 25	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-25-1	CHAPTER 31	Approve	Accept		Adopt 2021 IBC Chapter 31.	Approve
OSHPD 06/21-25-2	Section 3115	Approve	Accept		Add amendment to section to provide a note that this section is not permitted by OSHPD.	Approve

CHAPTER 31A SYSTEMS FOR WINDOW CLEANING OR EXTERIOR BUILDING MAINTENANCE**CHAPTER 31B PUBLIC POOLS****CHAPTER 31C RADIATION**OSHPD does not adopt *Chapters 31A, 31B and 31C.*

Item Number 26	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-26-1	CHAPTER 31A CHAPTER 31B CHAPTER 31C	Approve	Accept		OSHPD does not adopt <i>Chapters 31A, 31B and 31C.</i>	Approve

CHAPTER 31D FOOD ESTABLISHMENTSAdopt *Chapter 31D* for OSHPD 1 and 4 without modification.

Item Number 27	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-27-1	CHAPTER 31D	Approve	Accept		Adopt <i>Chapter 31D</i> for OSHPD 1 and 4 without modification.	Approve

CHAPTER 31F [SLC] MARINE OIL TERMINALSOSHPD does not adopt *Chapter 31F.*

Item Number 28	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-28-1	CHAPTER 31F	Approve	Accept		OSHPD does not adopt <i>Chapters 31F.</i>	Approve

CHAPTER 32 ENCROACHMENTS INTO THE PUBLIC RIGHT-OF-WAY

Adopt 2021 International Building Code (IBC) Chapter 32 for OSHPD 1 and 4 without modification.

Item Number 29	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-29-1	CHAPTER 32	Approve	Accept		Adopt 2021 IBC Chapter 32.	Approve

CHAPTER 33 SAFEGUARDS DURING CONSTRUCTION

Adopt 2021 International Building Code (IBC) Chapter 33 for OSHPD 1, 1R, 2, 3, 4 and 5 without modification.

Item Number 30	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-30-1	CHAPTER 33	Approve	Accept		Adopt 2021 IBC Chapter 33.	Approve

CHAPTER 35 REFERENCED STANDARDS

Adopt 2021 International Building Code (IBC) Chapter 35 for OSHPD 3, and Chapter 35 for OSHPD 1, 1R, 2, 4, and 5 and carry forward existing 2019 CBC amendments with the following modifications:

Item Number 31	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-31-0a	AAMA 501.4-18 (Updated)	Approve	Accept		Update and amend AAMA 501.4-09 to AAMA 501.4-18.	Approve
OSHPD 06/21-31-0b	AAMA 501.6-18 (Updated)	Approve	Accept		Update and amend AAMA 501.6-09 to AAMA 501.6-18.	Approve
OSHPD 06/21-31-1	ACI 355.2-19 (Updated)	Approve	Accept		Update ACI 355.2-07 to ACI 355.2-19 Include reference to Section 1901.3.2	Approve
OSHPD 06/21-31-2	ACI 355.4-19 (Updated)	Approve	Accept		Update ACI 355.4-11 to ACI 355.4-19 Include reference to Section 1901.3.3	Approve
OSHPD 06/21-31-3	ACI 506R-16	Approve	Accept		Update per revisions to Code references.	Approve
OSHPD 06/21-31-4	ACI 506.4R-94 (New)	Approve	Accept		New Referenced Standard.	Approve
OSHPD 06/21-31-5	ACI 506.6T-17 (New)	Approve	Accept		New Referenced Standard.	Approve
OSHPD 06/21-31-6	AISC 358/s1-18	Approve	Accept		Update code references to include Section 1705A.2.1.	Approve
OSHPD 06/21-31-7	APA ANSI/APA PRG 320-2019 (Updated)	Approve	Accept		Update per revisions to Code references.	Approve

Item Number 31	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-31-8	ASCE/SEI 7-16 (Updated)	Approve	Accept		Amendment to adopt Supplements 2 and 3, in addition to Supplement 1.	Approve
OSHPD 06/21-31-9	ASCE/SEI 49-12 (Updated)	Approve	Accept		Repeal California amendment and update to adopt model.	Approve
OSHPD 06/21-31-10	ASTM A153/153M— 2016A	Approve	Accept		Update code reference from 2304.10.1 to 2304.10.2.	Approve
OSHPD 06/21-31-11	ASTM A722/A722M-15 (Updated)	Approve	Accept		Update and amend ASTM A722/A722M-12 to A722/A722M-15.	Approve
OSHPD 06/21-31-12	ASTM A1064-17	Approve	Accept		Add code reference.	Approve
OSHPD 06/21-31-13	ASTM B 695 (2016) (Updated)	Approve	Accept		Repeal California amendment and update to adopt model and revise code reference.	Approve
OSHPD 06/21-31-14	ASTM C 94/C94M- 2017 (Updated)	Approve	Accept		Repeal California amendment and update to adopt model.	Approve
OSHPD 06/21-31-15	ASTM C150-2018 (Updated)	Approve	Accept		Repeal California amendment and update to adopt model.	Approve
OSHPD 06/21-31-16	ASTM C270-14a (Updated)	Approve	Accept		Repeal California amendment and update to adopt model.	Approve
OSHPD 06/21-31-17	ASTM C595-2018 (Updated)	Approve	Accept		Repeal California amendment and update to adopt model.	Approve
OSHPD 06/21-31-18	ASTM C1157/C1157M- 2017 (Updated)	Approve	Accept		Repeal California amendment and update to adopt model.	Approve
OSHPD 06/21-31-19	ASTM C 1249-18 (Updated)	Approve	Accept		Update and amend ASTM C1249-06a (2010) to C1249-18.	Approve
OSHPD 06/21-31-20	ASTM C1392-20 (Updated)	Approve	Accept		Update and amend ASTM C1392-00 to C1392-20.	Approve
OSHPD 06/21-31-22	ASTM C1394-20 (Updated)	Approve	Accept		Update and amend ASTM C1394-03 (2012) to C1394-20.	Approve
OSHPD 06/21-31-23	ASTM D1586-20 (Updated)	Approve	Accept		Update and amend ASTM D1586-11 to D1586-20.	Approve
OSHPD 06/21-31-24	ASTM D5778-20 (Updated)	Approve	Accept		Update and amend ASTM D5778-12 to D5778-20.	Approve
OSHPD 06/21-31-25	AWPA U1-20 (Updated)	Approve	Accept		Update and amend AWPA U1-17 to AWPA U1-20.	Approve
OSHPD 06/21-31-26	AWS D1.2-14 (Updated)	Approve	Accept		Update and amend AWS D1.2-15 to AWS D1.2-14.	Approve
OSHPD 06/21-31-27	AWS D1.4-2018	Approve	Accept		Delete code reference.	Approve

Item Number 31	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-31-28	FM ANSI/FM 1950-16	Approve	Accept		Revise code references.	Approve
OSHPD 06/21-31-29	ICC-ES AC 01 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 01 – 18 to ICC-ES AC 01 – 21*.	Approve
OSHPD 06/21-31-30	ICC-ES AC 58 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 58 – 18 to ICC-ES AC 58 – 21*.	Approve
OSHPD 06/21-31-31	ICC-ES AC 70 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 70 - 18 to ICC-ES AC 70 – 21*.	Approve
OSHPD 06/21-31-32	ICC-ES AC 106 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 106 – 18 to ICC-ES AC 106 – 21*.	Approve
OSHPD 06/21-31-33	ICC-ES AC 125 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 125 – 18 to ICC-ES AC 125 – 21*.	Approve
OSHPD 06/21-31-34	ICC-ES AC 156 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 156 – 18 to ICC-ES AC 156 – 21*. Revise code reference.	Approve
OSHPD 06/21-31-35	ICC-ES AC 178 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 178 – 18 to ICC-ES AC 178 – 21*.	Approve
OSHPD 06/21-31-36	ICC-ES AC 193 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 193 – 18 to ICC-ES AC 193 – 21*.	Approve
OSHPD 06/21-31-37	ICC-ES AC 232 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 232 – 18 to ICC-ES AC 232 – 21*.	Approve
OSHPD 06/21-31-38	ICC-ES AC 308 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 308 – 18 to ICC-ES AC 308 – 21*.	Approve
OSHPD 06/21-31-39	ICC-ES AC 358 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 358 – 18 to ICC-ES AC 358 – 21*.	Approve
OSHPD 06/21-31-39a	ICC-ES AC 446 – 21* (Updated)	Approve	Accept		Update and amend ICC-ES AC 446 – 18 to ICC-ES AC 446 – 21*.	Approve
OSHPD 06/21-31-40	ISO 9001-15	Approve	Accept		Revise code reference.	Approve
OSHPD 06/21-31-41	NEHRP FEMA P-2082-1	Approve	Accept		Adopt New NEHRP standard regarding recommended seismic conditions.	Approve
OSHPD 06/21-31-42	TMS 402-2016	Approve	Accept		Revise and update code references.	Approve
OSHPD 06/21-31-43	TMS 602-2016	Approve	Accept		Revise and update code references.	Approve
OSHPD 06/21-31-44	UL 587 – 13	Approve	Accept		Revise code reference.	Approve
OSHPD 06/21-31-45	61730-1—2017:	Approve	Accept		Revise code reference.	Approve
OSHPD 06/21-31-46	61730-2—2017:	Approve	Accept		Revise code reference.	Approve

APPENDIX A EMPLOYEE QUALIFICATIONS
APPENDIX B BOARD OF APPEALS
APPENDIX C GROUP U—AGRICULTURAL BUILDINGS
APPENDIX D FIRE DISTRICTS
APPENDIX E RESERVED
APPENDIX F RODENTPROOFING
APPENDIX G FLOOD-RESISTANT CONSTRUCTION
APPENDIX H SIGNS
APPENDIX I PATIO COVERS
APPENDIX J GRADING

OSHPD does not adopt APPENDICES A, B, C, D, E, F, G, H, I and J.

Item Number 32	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-32-1	APPENDICES A through J	Approve	Accept		OSHPD does not Appendices A through J.	Approve

APPENDIX K ADMINISTRATIVE PROVISIONS

OSHPD proposes to not adopt the 2021 IBC Appendix K Administrative Provisions.

APPENDIX K GROUP R-3 AND GROUP R-3.1 OCCUPANCIES PROTECTED BY THE FACILITIES OF THE CENTRAL VALLEY FLOOD PROTECTION PLAN

OSHPD proposes to carry forward existing amendments of the 2019 CBC and adopt *Appendix K* for OSHPD 2 into the 2022 CBC.

Item Number 33	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-33-1	APPENDIX K	Further Study	Accept		Adopt <i>Appendix K</i> for OSHPD 2. Further study based on Criteria #6. Post CAC: Coordinated with BSC for revised ET and ISOR language.	Approve

APPENDIX L EARTHQUAKE RECORDING INSTRUMENTATION

Adopt entire 2021 International Building Code (IBC) Appendix L and carry forward existing amendments of the 2019 California Building Code (CBC) for OSHPD 1 and 4.

Item Number 34	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-34-1	APPENDIX L	Approve	Accept		Adopt Appendix L for OSHPD 1 and 4.	Approve

APPENDIX M TSUNAMI-GENERATED FLOOD HAZARD
APPENDIX N REPLICABLE BUILDINGS
APPENDIX O PERFORMANCE-BASED APPLICATION
APPENDIX P EMERGENCY HOUSING (FORMALLY 2019 CBC APPENDIX O)
 OSHPD does not adopt APPENDICES M, N, N O and P.

Item Number 35	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-35-1	APPENDICES M and N	Approve	Accept		OSHPD does not adopt Appendices M and N.	Approve
OSHPD 06/21-35-2	APPENDIX O	Approve	Accept		OSHPD does not adopt 2021 IBC Appendix O.	Approve
OSHPD 06/21-35-3	APPENDIX P	Approve	Accept		OSHPD does not adopt 2022 CBC <i>Appendix P</i> .	Approve

RESOURCE A RECOMMENDED PRACTICES FOR REMOTE VIRTUAL INSPECTIONS (RVI)

OSHPD does not adopt RESOURCE A of the 2021 IBC.

Item Number 36	Code Section	CAC Action	Agency Response	Public Comments	Annotations	CBSC Action
OSHPD 06/21-36-1	RESOURCE A	Approve	Accept		OSHPD does not adopt 2021 IBC Resource A.	Approve